

- **Requirement for SCR in Nearly All of California**
- **Higher Criteria Pollutant Emissions from WHRU Burners**
- **Unfired CHP is not the Optimal Configuration for GHG Emissions Reductions**
- **Optimizing Gas Turbine Simple Cycle Efficiency Can Limit Thermal Range of CHP Applications**
- **Currently Achievable NO_x Emissions Levels Are Probably at the Limit of DLN Technology**