

**TABLE 2-A. WATER CONSUMPTION BY WATER-
USING PLUMBING PRODUCTS AND APPLIANCES –
1980 TO 2012**

Water-using Fixture or Appliance	1980s Water Use	1990 Requirement	EPAct 1992 Requirement	2009 Baseline Plumbing Code	2012 'Green Code' Requirement	% Reduction in avg water use since 1980s
Residential Bathroom Lavatory Faucet	3.5+ gpm	2.5 gpm	2.2 gpm	2.2 gpm	1.5 gpm	57%
Showerhead	3.5+ gpm	3.5 gpm	2.5 gpm	2.5 gpm	2.0 gpm	43%
Toilet – Residential	5.0+ gpf	3.5 gpf	1.6 gpf	1.6 gpf	1.28 gpf	74%
Toilet - Commercial	5.0+ gpf	3.5 gpf	1.6 gpf	1.6 gpf	1.6 gpf ¹	68%
Urinal	1.5 to 3.0+ gpf	1.5 to 3.0 gpf	1.0 gpf	1.0 gpf	0.5 gpf	67%
Commercial Lavatory Faucet	3.5+ gpm	2.5 gpm	2.2 gpm	0.5 gpm	0.5 gpm	86%
Food Service Pre-rinse Spray Valve	5.0+ gpm	No requirement	1.6 gpm (EPAct 2005)	No requirement	1.3 gpm	74%
Residential Clothes Washer	51 gallons/load	No requirement	26 gallons/load (2012 standard)	No requirement	16 gallons/load	67%
Residential Dishwasher	14 gallons/cycle	No requirement	6.5 gallons/cycle (2012 standard)	No requirement	5.0 gallons/cycle (ASHRAE S191P)	64%

gpm: gallons per minute

gpf: gallons per flush