From: Edwards, Jan
To: Loyer, Joe@Energy;
Subject: FW: Radient Barrier installation
Date: Friday, June 27, 2014 3:56:33 PM

Joe,

I have read the letter that the previous Building Official submitted and I, as the new CBO, will abide by the limitation stated in the submittal letter that the radiant barrier amendment to the Glendale Building and Safety Code, 2014, will apply only to new residential structures.

Included in this e-mail is the notice I sent to plan check and inspection staff informing them of this limitation in the enforcement of the Green Building Standards Code section 4.203.

Please let me know if this is adequate to move forward with this as an agenda item at your next business meeting, currently scheduled for July 22, 2014.

Sincerely,
Jan Edwards, P.E., CBO
Building Official
City of Glendale

From: Edwards, Jan
Sent: Friday, June 27, 2014 3:21 PM
To: Agus, Chris; Hairapetian, Sarkis; Lapraik, Michael; Lhotsky, Miroslav; Leung, Colin; Billing, Ronald; Minjares, Alex; Edmonson, Jon; Hernandez, Jose; Abejo, Antonino; Newman, Mark; Cook, Michael J; Chriss, Tony; Samvelyan, Ninet
Cc: Bear, Jan; Valaer, Charles; Comer, Chris
Subject: Radient Barrier installation

Everyone,

On July 1, 2014 the 2013 California Energy Code will go into effect. At that time the provisions of the Green Building Standards Code that were energy related and were based on the 2013 Energy Code will also go into effect with one exception.
The requirement in Volume IX, Section 4.203, Glendale Building and Safety Code, 2014, regarding radiant barriers will apply **only to new residential buildings**. It will **not be applicable** to commercial structures or residential additions or alterations, even though expressly stated in the Code section.

However, if there are energy documents that require a radiant barrier in order to demonstrate compliance with the 2013 energy code for residential additions or

alterations or for commercial buildings then the radiant barrier shall be enforced as specified in the energy documents for that particular project.

Please see me for questions,

Jan Edwards, P.E., CBO
Building Official