

**LABORATORY EXHAUST**

CEC-NRCC-PRC-09-E (Revised 01/16)



CERTIFICATE OF COMPLIANCE

NRCC-PRC-09-E

Laboratory Exhaust

(Page 1 of 2)

Project Name:

Date Prepared:

System air flow as designed : \_\_\_\_\_ ACH

**Equipment Tags and System Description<sup>2</sup>****PRESCRIPTIVE MEASURES*****T-24 Sections******Reference to the Requirements in the Contract Documents<sup>3</sup>***

Exhaust system with VAV hood

140.9(c)

Exhaust system without VAV hood – Exc. 1c

140.9(c)  
Exception 1

Exhaust system without VAV hood – Exc. 1c

140.9(c)  
Exception 2**Notes:**

1. Enter the designed system air flow rate in Air Changes per Hour (ACH) for all Laboratory systems under this permit.
2. Provide equipment tags (e.g. EF-1 to x and AHU 1 to y) for all systems that are covered by these requirements. This includes systems that are VAV flow Hoods as well as system that are exempted as per sections 1 or 2 under section 140.9(c).
3. Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system. Explicitly list which exception is used (if used).



<b>CERTIFICATE OF COMPLIANCE</b>		NRCC-PRC-09-E
Laboratory Exhaust		(Page 2 of 2)
Project Name:	Date Prepared:	

<b>DOCUMENTATION AUTHOR'S DECLARATION STATEMENT</b>	
1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/HERS Certification Identification (if applicable):
City/State/Zip:	Phone:

<b>RESPONSIBLE PERSON'S DECLARATION STATEMENT</b>	
I certify the following under penalty of perjury, under the laws of the State of California:	
<ol style="list-style-type: none"> <li>1. The information provided on this Certificate of Compliance is true and correct.</li> <li>2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).</li> <li>3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.</li> <li>4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.</li> <li>5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.</li> </ol>	
Responsible Designer Name:	Responsible Designer Signature:
Company :	Date Signed:
Address:	License:
City/State/Zip:	Phone:

### NRCC-PRC-09-E User Instructions

This is the primary compliance document for laboratory exhaust, which provides compliance information for the use of the enforcement agency's field inspectors. This compliance document must be included on the plans. A copy of this compliance document should also be submitted to the enforcement agency along with the rest of the compliance submittal at the time of building permit application.

#### Project Description

PROJECT ADDRESS is the address of the project as shown on the plans and known to the enforcement agency.

DATE is the last revision date of the plans. If the plans are revised after this date, it may be necessary to re-submit the compliance documentation to reflect the altered design. Note that it is the enforcement agency's discretion whether to require new compliance documentation or not.

SYSTEM AIRFLOW - Enter the designed system air flow rate in Air Changes per Hour (ACH) for all Laboratory systems under this permit.

#### Prescriptive Measures

The prescriptive measures must be incorporated into the construction documents. Left column list the measures and the section numbers in the Building Energy Efficiency Standards where the requirements for those measures are specified. The columns labeled *Indicate Page Reference on Plans or Schedule* are for designating the specific sheet on the plans or specification section(s) where the measures used to comply with the Standards are documented. In each column, the documentation author shall identify where each of the required measures are specified on the plans or in the project specifications. Where a measure is not applicable to the specific system, the letters "NA" (for not applicable) are placed in the cell. Groups of similar systems can be entered in a single column where appropriate.

#### Documentation Author's Declaration Statement

The CERTIFICATE OF COMPLIANCE is signed by both the Documentation Author and the Principal Designer who is responsible for preparation of the plans of building. This latter person is also responsible for the energy compliance documentation, even if the actual work is delegated to a different person acting as Documentation Author. It is necessary that the compliance documentation be consistent with the plans.

DOCUMENTATION AUTHOR is the person who prepared the energy compliance documentation and who signs the Declaration Statement. The person's telephone number is given to facilitate response to any questions that arise. A Documentation Author may have additional certifications such as a Certified Energy Analyst or a Home Energy Rating System certification number. Enter number in the CEA# or HERS# field provided.

#### Declaration Statement of Principle Designer

The Declaration Statement is signed by the person responsible for preparation of the plans for the building and the documentation author. This principal designer is also responsible for the energy compliance documentation, even if the actual work is delegated to someone else (the Documentation Author as described above). It is necessary that the compliance documentation be consistent with the plans. The Business and Professions Code governs who is qualified to prepare plans and therefore to sign this statement. See Section 2.2.2 Permit Application for applicable text from the Business and Professions Code.