



MONUMENT #1 (N1550', E1000')

MONUMENT #2 (N1550', E1610')

MONUMENT #3 (N1000', E1000')

NEC CLASS 1, DIVISION 2, GAS COMPRESSOR AREA

HAND-HELD FIRE EXTINGUISHERS LOCATED THROUGHOUT PLANT AREA

FIRE WALL

FIRE HYDRANTS SPACED @ 300 FT ON FIRE LOOP

FE-25 FIRE SUPPRESSION SYSTEM FOR ELECTRICAL EQUIPMENT ENCLOSURE

CTG CO₂ FLOOD SYSTEM

GSU SPILL CONTAINMENT AND FIRE SEPARATION WALLS

19% AQUEOUS AMMONIA STORAGE TANK 10,000 GALLONS WITH SPILL CONTAINMENT

FIRE WATER LOOP

BLACK START GENERATOR W/WET SPRINKLER

CTG AUXILIARY SKID OIL SPILL CONTAINMENT W/ DELUGE SPRINKLER SYSTEM

FE-25 FIRE SUPPRESSION SYSTEM FOR ELECTRICAL EQUIPMENT ENCLOSURE

FIRE WALL SEPARATION AND SPILL CONTAINMENT FOR TRANSFORMERS



CONTROL ROOM AREA HAND-HELD EXTINGUISHERS AND PREACTION SPRINKLERS. REST OF BUILDING WET PIPE SPRINKLERS

PLANT CENTRAL FIRE ALARM PANEL

EAST MIRALOMA AVENUE

14" WATER SUPPLY

PLANT FUEL SUPPLY AUTO SHUTOFF VALVE



PB Power, Inc. A Parsons Brinckerhoff Company <small>303 SECOND STREET, SUITE 700 NORTH, SAN FRANCISCO, CALIFORNIA 94107</small>									
SOUTHERN CALIFORNIA PUBLIC POWER AUTHORITY									
CANYON POWER PLANT PROJECT ANAHEIM, CALIFORNIA									
FIRE PROTECTION SYSTEM FIGURE 3-12									
DR. JJB DES. JJB CHK. SB	<table border="1"> <tr> <td>APPROVED</td> <td>DATE</td> </tr> <tr> <td>DECEMBER 2007</td> <td></td> </tr> <tr> <td>PRINCIPAL IN CHARGE</td> <td>DATE</td> </tr> <tr> <td>SHEET 8</td> <td>OF</td> </tr> </table>	APPROVED	DATE	DECEMBER 2007		PRINCIPAL IN CHARGE	DATE	SHEET 8	OF
APPROVED	DATE								
DECEMBER 2007									
PRINCIPAL IN CHARGE	DATE								
SHEET 8	OF								

N:\Anaheim\AFC FIGURES\FIGURE 3-12.dwg
 Date 12-11-07 Tuesday Plotted by: wong