

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: **Visual Resources**

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.13.1 Section 5.13.2 Section 5.13.3 Section 5.13.4		
Appendix B (g) (6) (A)	Descriptions of the existing visual setting of the vicinity of the proposed project site and the proposed routes for any project-related linear facilities. Include:	Section 5.13.1.1 Figure 15.3-3 Figure 15.3-4 Figure 15.3-5 Figure 15.3-6		
Appendix B (g) (6) (A) (i)	Topographic maps at a scale of 1:24,000 that depict directions from which the project would be seen, the view areas most sensitive to the potential visual impacts of the project, and the locations where photographs were taken for (g)(6)(C); and	Figure 5.13-1		
Appendix B (g) (6) (A) (ii)	Description of the existing visual properties of the topography, vegetation, and any modifications to the landscape as a result of human activities, including existing water vapor plumes, above-ground electrical transmission lines, and nighttime lighting levels in the project viewshed.	Section 5.13.1 Section 5.13.2.2.2		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: **Visual Resources**

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (B)	An assessment of the visual quality of those areas that would be affected by the proposed project. For projects proposed to be located within the coastal zone, the assessment should also describe how the proposed project would be sited to protect views to and along the ocean and scenic coastal areas, would minimize the alteration of natural land forms, would be visually compatible with the character of surrounding areas.	Section 5.13.1 Section 5.13.1.4.3 Figure 5.13-7 Figure 5.13-8 Figure 5.13-9 Figure 5.13-10		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: Visual Resources

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (C)	In consultation with Energy Commission staff, identify: i) any designated scenic roadways or scenic corridors and any visually sensitive areas that would be affected by the proposed project, including recreational and residential areas; and ii) the locations of the key observation points to represent the most critical viewing locations from which to conduct detailed analyses of the visual impacts of the proposed project. Indicate the approximate number of people using each of these sensitive areas and the estimated number of residences with views of the project. Also identify any major public roadways and trails of local importance that would be visually impacted by the project and indicate the types of travelers (e.g., local residents, recreationists, workers, commuters, etc.) and the approximate number of vehicles, bicyclists, and/or hikers per day.	Section 5.13.1 Section 5.13.1.3 Section 5.13.1.4 Figure 5.13-1		
Appendix B (g) (6) (D)	A table providing the dimensions (height, length, and width, or diameter) and, proposed color(s), materials, finishes, patterns, and other proposed design characteristics of each major component visible from off the project site, including any project-related electrical transmission line and/or offsite aboveground pipelines and metering stations.	Table 5.13-4		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: Visual Resources

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (E)	Provide the cooling tower and heat recovery steam generator (HRSG) exhaust design parameters that affect visible plume formation. For the cooling tower, data shall include heat rejection rate, exhaust temperature, exhaust mass flow rate, liquid to gas mass flow ratio, and, if the tower is plume-abated, moisture content (percent by weight) or plume-abated fogging curve(s). The parameters shall account for a range of ambient conditions (temperature and relative humidity) and proposed operating scenarios, such as duct firing and shutting down individual cells. For the heat recovery steam generator exhausts, data shall include moisture content (percent by weight), exhaust mass flow rate, and exhaust temperature. The parameters must correspond to full-load operating conditions at specified ambient conditions, and shall account for proposed operating scenarios, such as power augmentation (i.e., evaporative coolers, inlet foggers, or steam injection) and duct firing, or proposed HRSG visible plume abatement, such as the use of an economizer bypass. For simple-cycle projects, provide analogous data for the exhaust stack(s).	Not applicable. The project does not include cooling towers or heat recovery steam generators.		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: **Visual Resources**

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (F)	Provide: i) full-page color photographic reproductions of the existing site, and ii) full-page color simulations of the proposed project at life-size scale when the picture is held 10 inches from the viewer's eyes, including any project-related electrical transmission lines, in the existing setting from each key observation point. If any landscaping is proposed to comply with zoning requirements or to mitigate visual impacts, include the landscaping in simulation(s) representing sensitive area views, depicting the landscaping five years after installation; and estimate the expected time until maturity is reached.	Figure 5.13-12 to Figure 5.13-23 Figure 3.4-1 Figure 3.4-2 Figure 3.4-3		
Appendix B (g) (6) (G)	An assessment of the visual impacts of the project, including light, glare, and any modeling of visible plumes. Include a description of the method and identify any computer model used to assess the impacts. Provide an estimate of the expected frequency and dimensions (height, length, and width) of the visible cooling tower and/or exhaust stack plumes. Provide the supporting assumptions, meteorological data, operating parameters, and calculations used.	Section 5.13.2  The project will not have plumes associated with operational activities.		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: **Visual Resources**

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (H)	If any landscaping is proposed to reduce the visual impacts of the project, provide a conceptual landscaping plan at a 1:40 scale (1"=40'). Include information on the type of plant species proposed, their size, quantity, and spacing at planting, expected heights at 5 years and maturity, and expected growth rates.	Section 5.13.2.2.4 Section 5.13.4		
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.13.5 Table 5.13-6		
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.13.5.4 Section 5.13.5.5 Table 5.13-7 No permits required for visual resources.		

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate \_\_\_\_\_

**DATA ADEQUACY WORKSHEET**

Revision No. 0 Date \_\_\_\_\_

Technical Area: **Visual Resources**

Project: Carrizo Energy Solar Farm (CESF)

Technical Staff: \_\_\_\_\_

Project Manager: \_\_\_\_\_

Docket: \_\_\_\_\_

Technical Senior: \_\_\_\_\_

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Table 5.13-7		
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.13.5.5		

*This page intentionally left blank*