



- NOTES:
1. ALL FLOWS IN LITERS PER MINUTE
 2. A = AVERAGE (24 HRS) DAILY FLOW, P= PEAK FLOW, TYPICAL DURING HOURS OF OPERATION (13 HRS / DAY)
 3. AIR COOLED CONDENSER WASH IS EXPECTED TO BE PERFORMED ONCE A YEAR AT A RATE OF 9464 LITERS / CELL / HOUR
 4. 0.24% OF BOILER BLOWDOWN IS RECOVERED AS FLASH STEAM NOT SHOWN HERE

G:\gis\projects\1577\22239470\mxd\patch_fig_2_13.mxd
 10/10/07 10:00 AM

THIS DRAWING WAS PREPARED BY PATCH SERVICES FOR A SPECIFIC PROJECT, USING INFO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM PATCH SERVICES AND PROJECT CLIENT IS OBTAINED.
--

REV	DATE	DESCRIPTION	BY	CHK	APP
01	07/19/07	REVISED FOR DI WATER SOURCE			
02	08/25/07	REVISED FOR SMALLER FIELD			
03	08/08/07	PRELIMINARY			

PATCH SERVICES

* ENGINEERING *

CALIFORNIA 424 EXECUTIVE COURT NORTH SUITE: 4240 FAIRFIELD, CA 94534 PHONE: 707-864-5000 FAX: 707-864-8079	TEXAS 1701 NORTH GREENVILLE AVE. SUITE: 800 RICHARDSON, TX 75081 PHONE: 972-231-4080 FAX: 972-231-4089
---	---

WATER BALANCE
CARRIZO ENERGY SOLAR FARM (CESF)

URS	CREATED BY: PATCH	DATE: 09-12-07	FIG. NO:
	PM: AL	PROJ. NO: 22239472	3.4-17