

SECTION 4.0

Natural Gas Supply

The Chula Vista Energy Upgrade Project will use the existing 8-inch-diameter natural gas pipeline that current serves the project site for its gas supply. For this reason, no new offsite natural gas supply facilities will be necessary.

Section 2.1.6 describes the onsite project facilities that are related to natural gas consumption and use.