



Call Two Working Days Before You Dig  
1-800-227-2600

PRELIMINARY  
NOT FOR CONSTRUCTION  
01/01/2004

PARLIER POWER PLANT  
TERTIARY TREATMENT  
KINGS RIVER CONSERVATION DISTRICT  
FRESNO COUNTY



DESIGN ENGINEER:  
ADH  
LICENSE NO:  
54072

DRAFTED BY: MSM  
CHECKED BY: XYZ

SCALE: AS SHOWN  
DATE: 12/26/06  
JOB NO: 13640603  
DWS. NO:  
SHEET

1 OF 1

- NOTES:
- LAYOUT BASED ON FLOW = 4.2 MGD, W/ 3 FILTER UNITS ON AND 1 STANDBY.
  - INLET FLOW CONTROL SYSTEM NOT SHOWN.
  - STORAGE FACILITIES, IF NEEDED, NOT SHOWN.
  - ROOF STRUCTURE ABOVE FILTERS, NOT SHOWN FOR CLARITY.
  - CHEMICAL STORAGE VOLUMES ARE APPROXIMATE FOR 14 DAYS OPERATION.
  - CHLORINE CONTACT TANK WATER DEPTH = 22 FEET, VOLUME APPROXIMATE FOR 45 MIN, EACH SIDE, AT 4.2 MGD.

Figure 8.5-3