

**M e m o r a n d u m**

Date: January 15, 1999

Telephone ATSS

To : William J. Keese, Chairman  
David A. Rohy, Ph.D, Vice Chair  
Jananne Sharpless, Commissioner  
Michal C. Moore, Commissioner  
Robert A. Laurie, Commissioner

From : California Energy Commission                      Kent Smith  
1516 Ninth Street    Acting Executive Director  
Sacramento 95814-5512

Subject : **DELTA ENERGY CENTER--DATA ADEQUACY RECOMMENDATION**

We have reviewed the Delta Energy Center Application for Certification (AFC) filed by Calpine Corporation and Bechtel Enterprises on December 18, 1999. We do not believe that the AFC meets the requirements of Cal. Code of Regs., tit. 20, § 1704, Appendix B and are recommending that the Energy Commission find that the AFC is inadequate. There are several sections of the AFC that we believe require additional information for data adequacy: Section 2.0—Project Description, Section 8.1—Air Quality, Section 8.2—Biology, Section 8.3—Cultural Resources, Section 8.4—Land Use, Section 8.8—Socioeconomics, Section 8.9—Soils, Section 8.11—Visual Resources, Section 8.14—Water, Section 8.15—Geologic Resources, and Section 9.1—Facility Design. Enclosed is a summary table and data adequacy worksheets for each section of the AFC. The worksheets for the aforementioned sections identify the additional information that we believe is necessary to fulfill the AFC data adequacy requirements.

Calpine/Bechtel anticipate filing supplemental materials prior to the February 3, 1999 Business Meeting that they believe will make the AFC along with the supplemental filing data adequate. If the required 125 copies are filed on a timely basis we may be able to complete our review of the supplemental filing and report on our findings at the Business Meeting.

One comment letter (see attached) was received from the City of Antioch expressing a concern with air quality, loss of potential economic development, safe operation of the plant and potential impacts due to a seismic event. We will work with the City of Antioch and other agencies to address their concerns in our analysis of the project.

If you have any questions, please call Paul Richins, Energy Commission's Project Manager, at (916) 654-4074.

**Attachments**

cc: Susan Strachan, Doug Buchaan, Marc Joseph

## DELTA ENERGY CENTER DATA ADEQUACY DETERMINATION

TECHNICAL AREA	ADEQUATE	INADEQUATE	PAGE NUMBERS
1. Air Quality		√	1
2. Biological Resources		√	7
3. Cultural Resources		√	11
4. Efficiency	√		15
5. Facility Design		√	17
6. Geological Hazards		√	20
7. Hazardous Materials Handling	√		22
8. Land Use		√	25
9. Noise	√		29
10. Paleontologic Resources	√		33
11. Project Overview	√		36
a. Alternatives	√		--
b. Project Description		√	--
c. Demand Conformance	√		--
d. Closure & Compliance	√		--
12. Public Health	√		41
13. Reliability	√		44
14. Socioeconomics		√	46
15. Soils		√	50
16. Traffic and Transportation	√		52
17. Transmission	√		56
18. Visual Resources		√	60
19. Waste Management	√		64
20. Water		√	67
21. Worker Safety	√		71

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate **X**

Revision No. 0 Date January 14, 1999

Technical Area: **Air Quality**

Project: Delta Energy Center

Technical Staff: Magdy Badr

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pages 8.1-1 to 8.1-20 Pages 8.1-43, 8.1-50 and 51 Pages 8.1-28 to 8.1-39 Page 8.1 50 Appendixes 8.1 E, 8.1 H, 8.1G Section 2.1 Pages 2.1 to 2.4	YES	
Appendix B (g) (8) (A)	The information necessary for the air pollution control district where the project is located to complete a Determination of Compliance.	Pages 8.1-44 to 8.1-47	No	Awaiting completeness finding by the Bay Area Air Quality Management District (BAAQMD). Applicant has recently filed an application with the air district and will include it in its supplemental filing with the CEC.
Appendix B (g) (8) (B)	The heating value and chemical characteristics of the proposed fuels, the stack height and diameter, the exhaust velocity and temperature, the heat rate and the expected capacity factor of the proposed facility.	Appendixes 8.1 A, 8.1 B, 8.1C.	NO	Please provide the chemical characteristics and the heating value of the natural gas (proposed fuel) utilized in this project.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate **X**

Revision No. 0 Date January 14, 1999

Technical Area: **Air Quality**

Project: Delta Energy Center

Technical Staff: Magdy Badr

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (C)	A description of the control technologies proposed to limit the emission of criteria pollutants.	Pages 2-23 to 2-24 Appendix 8.1 F	YES	
Appendix B (g) (8) (D)	A description of the cooling system, the estimated cooling tower drift rate, the rate of water flow through the cooling tower, and the maximum concentrations of total dissolved solids.	Pages 2-35 to 2-36 Appendix 8.1 A	YES	
Appendix B (g) (8) (E)	The emission rates of criteria pollutants from the stack, cooling towers, fuels and materials handling processes, delivery and storage systems, and from all secondary emission sources.	Appendix 8.1 A and 8.1 C	YES	
Appendix B (g) (8) (F)	A description of typical operational modes, and start-up and shutdown modes for the proposed project, including the estimated frequency of occurrence and duration of each mode, and estimated emission rate for each criteria pollutant during each mode.	Appendix 8.1 A	NO	Please describe the different operating modes that you considered to derive the worst daily emission scenario.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Air Quality  

Project:   Delta Energy Center  

Technical Staff:   Magdy Badr  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (G)	The ambient concentrations of all criteria pollutants for the previous three years as measured at the three Air Resources Board certified monitoring stations located closest to the project site, and an analysis of whether this data is representative of conditions at the project site. The applicant may substitute an explanation as to why information from one, two, or all stations is either not available or unnecessary.	Pages 8.1-10 to 8.1-20	YES	
Appendix B (g) (8) (H)	One year of meteorological data collected from either the Federal Aviation Administration Class 1 station nearest to the project or from the project site, or meteorological data approved by the California Air Resources Board or the local air pollution control district.	Electronic files	YES	
Appendix B (g) (8) (H) (i)	If the data is collected from the project site, the applicant shall demonstrate compliance with the requirements of the U.S. Environmental Protection Agency document entitled "On-Site Meteorological Program Guidance for Regulatory Modeling Applications" (EPA - 450/4-87-013 (August 1995), which is incorporated by reference in its entirety.)	Pages 8.1-40 to 8.1-43	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate **X**

Revision No. 0 Date January 14, 1999

Technical Area: **Air Quality**

Project: Delta Energy Center

Technical Staff: Magdy Badr

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (H) (ii)	The data shall include quarterly wind tables and wind roses, ambient temperatures, relative humidity, stability and mixing heights, upper atmospheric air data, and an analysis of whether this data is representative of conditions at the project site.	Pages 8.1-2 to 8.1-8	YES	
Appendix B (g) (8) (I)	An evaluation of the project's direct and cumulative air quality impacts, consisting of the following:			
Appendix B (g) (8) (I) (i)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct inert pollutant impacts of project construction activities on ambient air quality conditions, including fugitive dust (PM <sub>10</sub> ) emissions from grading, excavation and site disturbance, as well as the combustion emissions [nitrogen oxides (NO <sub>x</sub> ), sulfur dioxide (SO <sub>2</sub> ), carbon monoxide (CO), and particulate matter less than 10 microns in diameter (PM <sub>10</sub> )] from construction-related equipment;	Appendixes 8.1 E, 8.1 H Pages 8.1-29 to 8.1-41	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Air Quality  

Project:   Delta Energy Center  

Technical Staff:   Magdy Badr  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (I) (ii)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct inert criteria pollutant (NO <sub>x</sub> , SO <sub>2</sub> , CO and PM <sub>10</sub> ) impacts on ambient air quality conditions of the project during typical (normal) operation, and during shutdown and startup modes of operation. Identify and include in the modeling of each operating mode the estimated maximum emissions rates and the assumed meteorological conditions; and	Pages 8.1-33 to 8.1-35	YES	
Appendix B (g) (8) (I) (iii)	A protocol for a cumulative air quality modeling impacts analysis of the project's typical operating mode in combination with other stationary emissions sources within a six mile radius which have received construction permits but are not yet operational, or are in the permitting process. The cumulative inert pollutant impact analysis should assess whether estimated emissions concentrations will cause or contribute to a violation of any ambient air quality standard.	Appendix 8.1 H Pages 8.1-28 to 8.1-35	YES	
Appendix B (g) (8) (J)	If an emission offset strategy is proposed to mitigate the project's impacts under subsection (g)(1), provide the following information:			

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Air Quality  

Project:   Delta Energy Center  

Technical Staff:   Magdy Badr  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (J) (i)	The quantity of offsets needed;	Page 8.1-47 Appendix 8.1 G	YES	
Appendix B (g) (8) (J) (ii)	Potential offset sources, including location, and quantity of emission reductions; and	Appendix 8.1 G	YES	
Appendix B (g) (8) (J) (iii)	Method of emission reduction.		YES	
Appendix B (g) (8) (K)	A topographic map containing contour and elevation data, at a scale of 1:24,000, showing the area within 6 miles of the power plant site.	Attachment in section 6	YES	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Appendix 8.1 F, 8.1-44 to 8.1-50.	NO	Please provide a table which identifies the laws, regulations, ordinances, standards (LORS) applicable to the proposed project, and a discussion of the applicability of each. The table should reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Air Quality  

Project:   Delta Energy Center  

Technical Staff:   Magdy Badr  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.		NO	Please provide tables which identify each agency such as Bay Area Air Quality management District (BAAQMD), Environmental Protection Agency (EPA) with jurisdiction to issue applicable permits or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Appendix 8.1 F, 8.1-44 to 8.1-50.	YES	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.		NO	Please provide a list of the names, titles, phone numbers, and addresses, of the official within each agency who will serve as a contact person for the agency.
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.		NO	Please provide a schedule indicating when you plan to file an application with the BAAQMD, EPA and any other agency.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  **Biological Resources**

Project:  Delta Energy Center

Technical Staff:  Marc Sasaki & Rick York

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pages 8.2-1 to 8.2-59 (Section 8.2) and Appendix 8.2  Mitigation & Monitoring: pages 8.2-47 to 51 (Section 8.2.3)	Yes	
Appendix B (g) (13) (A)	A regional overview and discussion of biological resources, with particular attention to sensitive biological resources near the project and a map at a scale of 1:100,000 (or some other suitable scale) showing their location in relation to the project.	Regional overview and sensitive species: Pages 8.2-1 to 8.2-21 (Section 8.2.1.1)  Maps: Figure 8.2-1 and Figures 8.2-2A to 2K	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Biological Resources

Project:  Delta Energy Center

Technical Staff:  Marc Sazaki & Rick York

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (B)	A discussion and detailed maps at a scale of 1:6,000, of the biological resources at the site of the proposed project and related facilities, and in areas adjacent to them, out to a mile from the site and 1000 feet from the outer edge of linear facility corridors. Include a list of the species actually observed and those with a potential to occur. The discussion and maps shall address the distribution of community types, denning or nesting sites, population concentrations, migration corridors, breeding habitats, and the presence of sensitive biological resources.	Maps: Figure 8.2-1 and Figures 8.2-2A to 2K  Species seen: Tables 8.2-3 (Plants) & 8.2-4 (Wildlife)  Discussion of project site and out to one mile: Pages 8.2-23 & 24 (Section 8.2.1.3)	Yes	
Appendix B (g) (13) (C)	A description of all studies and surveys used to provide biological information about the project site, including seasonal surveys and copies of the California Department of Fish and Game's Natural Diversity Data Base Survey Forms, "California Native Species Field Survey Forms", and "California Natural Community Field Survey Forms", completed by the applicant. Include the dates and duration of the studies, methods used to complete the studies, and the names and qualifications of individuals conducting the studies.	Methods: pages 8.2-21 to 23 (Section 8.2.1.2)  Native Species Field Survey Forms: Appendix 8.G  Dates/duration of studies: Page 8.2-21 & 22, Table 8.2-2  Names & qualifications of individuals completing studies: Appendix 8.2H	No	Provide copies of Native Species Field Survey Forms for all sensitive plant occurrences seen during field surveys.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Biological Resources

Project:  Delta Energy Center

Technical Staff:  Marc Sazaki & Rick York

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (D)	A discussion of all permanent and temporary impacts to biological resources from site preparation, construction activities, and plant operation. Discussion of impacts must consider impacts from cooling tower drift, and from the use and discharge of water during construction and operation. For facilities which use once-through cooling or take or discharge water directly from or to natural sources, discuss impacts resulting from entrainment, impingement, thermal discharge, effluent chemicals, type of pump (if applicable), temperature, volume and rate of flow at intake and discharge location, and plume configuration in receiving water.	Impacts: Pages 8.2-39 to 47, (Section 8.2-2)  Cooling tower drift: Pages 8.2-41, 42 (Section 8.2.2.1.3)  Water discharge, etc.: Pages 8.2-42 & 43 (Section 8.2.2.1.4)	Yes	
Appendix B (g) (13) (E)	A discussion of the following:	--	--	--
Appendix B (g) (13) (E) (i)	All measures proposed to avoid and/or reduce any adverse impacts;	Pages 8.2-47 to 51 (Section 8.2.3)	Yes	
Appendix B (g) (13) (E) (ii)	All measures proposed to mitigate any adverse impacts, including any proposals for off-site mitigation; and	Page 8.2-49 (Section 8.2.3)	Yes	
Appendix B (g) (13) (E) (iii)	Any educational programs proposed to enhance employee awareness in order to protect biological resources.	Page 8.2-49 to 51 (Section 8.2.3)	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Biological Resources

Project:  Delta Energy Center

Technical Staff:  Marc Sazaki & Rick York

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (F)	A discussion of compliance and monitoring programs proposed to ensure the effectiveness of mitigation measures incorporated into the project.	Page 8.2-49 to 51 (Section 8.2.3)	Yes	
Appendix B (g) (13) (G)	A discussion of native fish and wildlife species of commercial and/or recreational value that could be impacted by the project.	Pages 8.2-13 & 14 (Section 8.2.1.1.3)	Yes	
Appendix B (g) (13) (H)	For purposes of this section, sensitive biological resources are one of the following:	--	--	--
Appendix B (g) (13) (H) (i)	Species listed under state or federal Endangered Species Acts;	Pages 8.2-34 to 39 (Sections 8.2.1.3.4, 8.2.1.4.4, & 8.2.1.5.4)	Yes	
Appendix B (g) (13) (H) (ii)	Resources defined in sections 1702 (q) and (v) of Title 20 of the California Code of Regulations; and	Pages 8.2-34 to 39 (Sections 8.2.1.3.4, 8.2.1.4.4, & 8.2.1.5.4)	Yes	
Appendix B (g) (13) (H) (iii)	Species or habitats identified by legislative acts as requiring protection.	Pages 8.2-34 to 39 (Sections 8.2.1.3.4, 8.2.1.4.4, & 8.2.1.5.4)	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Biological Resources

Project:  Delta Energy Center

Technical Staff:  Marc Sazaki & Rick York

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Pages 8.2-52 to 56 (Table 8.2-6)	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Pages 8.2-52 to 56 (Table 8.2-6)	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Page 8.2-52 (Section 8.2.5)	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Pages 8.2-47 to 48 (Table 8.2-5, Section 8.2.3)	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Biological Resources

Project: Delta Energy Center

Technical Staff: Marc Sazaki & Rick York

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Dr. Jim Brownell

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Pages 8.2-52 to 56 (Table 8.2-6)	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Cultural Resources

Project: Delta Energy Center

Technical Staff: Gary Walker

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sections 8.3 through 8.3.4; pp.8.3-2 through 8.3-30.	NO	<p>The AFC (p.8.3-11) states that archival sources “show that 17 cultural resources lie either within or adjacent to the DEC project site (Figure 8.3-4).” However, the figure only identifies five sites, and the subsequent discussion only addresses 12 or 13 sites. Please provide a description of all 17 sites, and provide a map or maps identifying all 17 sites.</p> <p>Please provide a discussion of the potential impacts due to the proposed power plant, natural gas supply line, and electric transmission line. The discussion on pp.8.3-25 and 8.3-26 in Section 8.3.2.1 is titled “DEC Plant Site and Construction Laydown Area” but only addresses resources found during the survey of the linear facilities. The discussion of resources found during the survey of the linear facilities addresses only two of the three resources found. The discussion should also include the potential impacts of the project on resources identified during archival research.</p>

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Cultural Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (A)	A brief summary of the ethnology, prehistory, and history of the region in which the project site and related facilities are located and maps at a scale of 1:24,000, indicating areas of ethnographic occupation. The region may vary depending on the extent of the territory occupied or used by prehistoric cultures indigenous to the area in which the project is located.	Sections 8.3.1.2 through 8.3.1.4, pp.8.3-4 through 8.3-11.	YES	
Appendix B (g) (2) (B)	A description of all literature searches and field surveys used to provide information about known cultural resources in the project vicinity. If survey records of the area potentially physically affected by the project are not available, and the area has the potential for containing significant cultural resources, the applicant shall submit a new or revised survey for any portion of the area lacking comprehensive survey data. A discussion of the dates of the surveys, methods used in completing the surveys, and the identification and qualification of the individuals conducting the surveys shall be included.	Section 8.3.1.5, pp.8.3-11 through 8.3-25.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Cultural Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (C)	A discussion of the sensitivity of the project area described in subsection (g)(2)(A) and the presence and significance of any known archeological sites and other cultural resources that may be affected by the project. Information on the specific location of archeological resources shall be included in a separate appendix to the application and submitted to the Commission under a request for confidentiality pursuant to Title 20, California Code of Regulations, § 2501 et seq.	Sections 8.3.2 and 8.3.4, pp.8.3-25 through 8.3-27; Confidential Appendix.	NO	Please provide a discussion of the sensitivity of the power plant site and the site construction laydown area.
Appendix B (g) (2) (D)	A summary of contacts and communications with, and responses from, Native American representatives who may have an interest in heritage lands and/or resources potentially affected by the proposed project.	Section 8.3.1.5.4, pp.8.3-21 and 8.3-22.	NO	Please provide a summary of the results of consultations with Native American representatives.
Appendix B (g) (2) (E)	In the discussion on mitigation and monitoring prepared pursuant to subsection (g)(1), a discussion of any educational programs proposed to enhance awareness of potential impacts to archeological resources by employees and contractors, measures proposed for mitigation of impacts to known cultural resources, and a set of contingency measures for mitigation of potential impacts to previously unknown cultural resources.	Section 8.3.4, pp.8.3-26 through 8.3-30.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Cultural Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 8.3.5, Table 8.3-3.	YES	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.3.5, Table 8.3-4.	NO	P.8.3-32 states that "If a previously undiscovered archaeological site were found during construction on lands owned by the federal government, and the site required evaluation, the PA would need to secure a permit to conduct scientific archaeological excavations under ARPA. The federal land-owning agency would issue this permit." Please identify the federal agencies that own lands crossed by the proposed project.
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Sections 8.3.4 and 8.3.5, pp.8.3-25 through 8.3-32.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Cultural Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 8.3.6, Table 8.3-4, p.8.3-32.	NO	Please provide the name, title, phone number, and address of the official in each federal agency that owns lands crossed by the project, who will serve as a contact person for the agency.
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.3.7, pp.8.3-32 and 8.3-33.	YES	

Adequacy Issue: Adequate   X   Inadequate       

## DATA ADEQUACY WORKSHEET

Revision No.   0   Date   January 14, 1999  

Technical Area:   Efficiency  

Project:   Delta Energy Center  

Technical Staff:   Steve Baker  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (4) (A)	Heat and mass balance diagrams for design conditions for each mode of operation.	Figure 2.2-3	Yes	
Appendix B (i) (4) (B)	Annual fuel consumption in BTUs for each mode of operation.	§ 2.2.7; Appendix 8.1B, Table 8.1B-2	Yes	
Appendix B (i) (4) (C)	Annual net electrical energy produced in MWh for each mode of operation.	§ 9.3	Yes	
Appendix B (i) (4) (D)	Number of hours the plant will be operated in each mode of operation in each year.	§ 2.2.17, 2.4.1, 9.3	Yes	
Appendix B (i) (4) (E)	If the project will be a cogeneration facility, calculations showing compliance with applicable efficiency and operating standards.	§ 1.1	N/A	
Appendix B (i) (4) (F)	A discussion of alternative generating technologies available for the project, including the projected efficiency of each, and an explanation why the chosen equipment was selected over these alternatives.	§ 5.5, 5.6.1, 5.6.2	Yes	

Adequacy Issue: Adequate      <sup>X</sup> Inadequate     

## DATA ADEQUACY WORKSHEET

Revision No.   0   Date   January 14, 1999  

Technical Area:   Efficiency   Project:   Delta Energy Center   Technical Staff:   Steve Baker    
 Project Manager:   Paul Richins   Docket:   98-AFC-3   Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	N/A	N/A	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	N/A	N/A	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	N/A	N/A	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	N/A	N/A	

Adequacy Issue: Adequate        <sup>X</sup> Inadequate       

## DATA ADEQUACY WORKSHEET

Revision No.   0   Date   January 14, 1999  

Technical Area:   **Efficiency**   Project:   Delta Energy Center   Technical Staff:   Steve Baker    
 Project Manager:   Paul Richins   Docket:   98-AFC-3   Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	N/A	N/A	

## DATA ADEQUACY WORKSHEET

January 14, 1999

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No   0   Date \_\_\_\_\_

Technical Area:   Facility Design  

Project:   Delta Energy Center  

Technical Staff:   Kisabuli  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (A)	A description of the site conditions and investigations or studies conducted to determine the site conditions used as the basis for developing design criteria. The descriptions shall include, but not be limited to, seismic and other geologic hazards, adverse conditions that could affect the project's foundation, adverse meteorological and climatic conditions, and flooding hazards, if applicable.	Appendix 9G	No	Please provide the information for appendix 9G. We have reviewed a preliminary version of Appendix 9G that you provided electronically. It is sufficient for data adequacy purposes.  Also, please provide a discussion of the existing site conditions (fill material, if any, soil bearing characteristics etc);
Appendix B (i) (1) (B)	A discussion of any measures proposed to improve adverse site conditions.	Page 8.15-11	No	Provide specific mitigation measures to deal with the identified geologic hazards such as (1) measures proposed to mitigate adverse soil conditions at the site; (2) a discussion of the effectiveness of the proposed mitigation measures; and (3) any monitoring plans to verify the effectiveness of the mitigation. (See High Desert Power Project's Engineering Appendices for a guide.)

## DATA ADEQUACY WORKSHEET

January 14, 1999

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No   0   Date \_\_\_\_\_

Technical Area:   Facility Design  

Project:   Delta Energy Center  

Technical Staff:   Kisabuli  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (C)	A description of the proposed foundation types, design criteria (including derivation), analytical techniques, assumptions, loading conditions, and loading combinations to be used in the design of facility structures and major mechanical and electrical equipment.	Appendixes 9A, 9B and 9G	No	Please provide a description of the proposed foundation types (pile, spread footings, mat foundations etc), design criteria (including derivation), analytical techniques, assumptions, loading conditions, and loading combinations to be used in the design of facility structures and major mechanical and electrical equipment.
Appendix B (i) (1) (D)	For each of the following facilities and/or systems, provide a description including drawings, dimensions, surface-area requirements, typical operating data, and performance and design criteria for protection from impacts due to adverse site conditions:			
Appendix B (i) (1) (D) (i)	The power generation system;	Section 2.2.4, Appendix 9C	Yes	
Appendix B (i) (1) (D) (ii)	The heat dissipation system;	Section 2.2.9, Appendix 9C	Yes	
Appendix B (i) (1) (D) (iii)	The cooling water supply system, and, where applicable, pre-plant treatment procedures;	Section 2.2.8, Appendix 9F	Yes	
Appendix B (i) (1) (D) (iv)	The atmospheric emission control system;	Sections 2.2.12 and 8.1	Yes	
Appendix B (i) (1) (D) (v)	The waste disposal system and on-site disposal sites;	Sections 2.2.10 and 8.13.	Yes	

## DATA ADEQUACY WORKSHEET

January 14, 1999

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No   0   Date \_\_\_\_\_

Technical Area:   **Facility Design**  

Project:   Delta Energy Center  

Technical Staff:   Kisabuli  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (D) (vi)	The noise emission abatement system;	Sections 8.5 Appendix 9C	Yes	
Appendix B (i) (1) (D) (vii)	The geothermal resource conveyance and re-injection lines (if applicable);	N/A		
Appendix B (i) (1) (D) (viii)	Switchyards/transformer systems; and	Sections 2.2.6 and 6.0, Appendix 9D	Yes	
Appendix B (i) (1) (D) (ix)	Other significant facilities, structures, or system components proposed by the applicant.	Section 2	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;		No	Please provide a table that identifies the laws, regulations, ordinances, and standards, adopted local, regional, state, and federal, and permits applicable to the proposed project, and a discussion of the applicability of each.

## DATA ADEQUACY WORKSHEET

January 14, 1999

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No   0   Date \_\_\_\_\_

Technical Area:   **Facility Design**  

Project:   Delta Energy Center  

Technical Staff:   Kisabuli  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Page 9-5	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).		No	Provide a discussion of the conformity of the project to LORS identified on page 9.4 of the AFC.
Appendix B (h) (3)	The name, title, telephones number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Page 9-5	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.		No	Please provide a schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Geological Hazards

Project:  Delta Energy center

Technical Staff:  Robert Anderson

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Volume 1, page 8.15.1, Section 8.15 and 8.15.1	Yes	
Appendix B (g) (17) (A)	A summary of the geology, seismicity, and geologic resources of the project site and related facilities;	Volume 1, Pages 8.15-1 through 8.15-9, Sections 8.15.2.1.2 through 8.15.2.1.1	Yes	
Appendix B (g) (17) (B)	A map at a scale of 1:24,000 and description of all recognized stratigraphic units, geologic structures, and geomorphic features within 2 miles of the project site. Include an analysis of the likelihood of ground rupture, seismic shaking, mass wasting and slope stability, liquefaction, subsidence, and expansion or collapse of soil structures.	Volume 1, Figure 8.15-3, and Volume 1, Page 8.15.-1 Section 8.15.1.2, Page 8-15-7, Section 8.15.1.3.2 , and Volume 2 Appendix 9G, Pages 9G-5 Section 9G.1, 9G.2, and 9G.3	No	Appendix 9G was not included in the hard copy transmittal of the Application For Certification. However, I was given a copy of the contents of Appendix 9G via e-mail and have found it to be adequate. The Applicant is to send 125 copies of the contents of Appendix 9G to the CEC as directed by the CEC project manager.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Geological Hazards

Project:  Delta Energy center

Technical Staff:  Robert Anderson

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (17) (C)	A map and description of geologic resources of recreational, commercial, or scientific value which may be affected by the project. Include a discussion of the techniques used to identify and evaluate these resources.	Volume 1, Page 8.15-9, Section 8.15.1.5	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Volume 1, Page 8.15-12, Section 8.15.4	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Volume 1, Page 8.15-12, Table 8.15-3	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: **Geological Hazards**

Project: Delta Energy center

Technical Staff: Robert Anderson

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Volume 1, Page 8.15-12 Section 8.15.4	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Volume 1, Page 8.15-12, Table 8.15-3	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Hazardous Materials Handling Project: Delta Energy Center

Technical Staff: Rick Tyler

Project Manager: Paul Richins Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 8.12	Yes	
Appendix B (g) (10) (A)	A list of all materials used or stored on-site which are hazardous or acutely hazardous, as defined in Title 22, California Code of Regulations, § 66261.20 et seq., and a discussion of the toxicity of each material.	Section 8.12.2.2.1 pp. 7-12	Yes	
Appendix B (g) (10) (B)	A map at a scale of 1:24,000 depicting the location of schools, hospitals, day-care facilities, emergency response facilities and long-term health care facilities, within the area potentially affected by any release of hazardous materials.	Section 8.12 Figures 8.12-1A, 1B and 1C	Yes	
Appendix B (g) (10) (C)	A discussion of the storage and handling system for each hazardous material used or stored at the site.	Table 8.12-1 and 2 and pp. 19 and 20	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Hazardous Materials Handling   Project:   Delta Energy Center  

Technical Staff:   Rick Tyler  

Project Manager:   Paul Richins   Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (10) (D)	The protocol that will be used in modeling potential consequences of accidental releases that could result in off site impacts. Identify the model(s) to be used, a description of all input assumptions, including meteorological conditions. The results of the modeling analysis can be submitted after the AFC is complete.	Section 8.12.3, p. 12	Yes	
Appendix B (g) (10) (E)	A discussion of whether a risk management plan (Health and Safety Code § 25531 et seq.) will be required, and if so, the requirements that will likely be incorporated into the plan.	Section 8.12.4.2, pp. 21 and 22	Yes	
Appendix B (g) (10) (F)	A discussion of measures proposed to reduce the risk of any release of hazardous materials.	Sections 8.12.6.2, 8.12.6.3, 8.12.6.4, pp. 18 – 22	Yes	
Appendix B (g) (10) (G)	A discussion of the fire and explosion risks associated with the project.	Sections 8.12.4, pp. 13 - 16	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Hazardous Materials Handling Project: Delta Energy Center

Technical Staff: Rick Tyler

Project Manager: Paul Richins Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 8.12.7, pp. 22 - 26	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.12.8, Table 8.12-7	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Section 8.12-7, pp. 22-26	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 8.12-7, page 26	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: **Hazardous Materials Handling**

Project: Delta Energy Center

Technical Staff: Rick Tyler

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.12-9 p. 27	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Land Use

Project:  Delta Energy Center

Technical Staff:  Eric Knight

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pages 8.4-13 – 8.4-16; Sections 8.4.5.1 – 8.4.5.5; and 8.4.6	Yes	
Appendix B (g) (3) (A)	A discussion of existing land uses and current zoning at the site, land uses and land use patterns within one mile of the proposed site and within one-quarter mile of any project-related linear facilities. Include:	Pages 8.4-1 – 8.4-9; Section 8.4.1 Pages 7-1 – 7-4; Section 7.1 Page 6-9; Section 6.2.2	No	Table 8.4-2 only identifies land uses within 50 feet of the proposed transmission line route, and Table 8.4-3 does not specify the distance from the gas pipeline route for the land uses identified. The sections cited in Chapters 6 and 7 of the AFC do not identify land uses within the required distance of ¼ mile of any project related linear facilities. Therefore, staff is unable to determine if all existing land uses were identified. In addition, there is no discussion of zoning designations within the proposed linear facility corridors. Please provide a complete discussion of existing land uses and zoning within a ½-mile wide corridor (¼ mile on either side) of the proposed linear facilities.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Land Use  

Project:   Delta Energy Center  

Technical Staff:   Eric Knight  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (A) (i)	An identification of residential, commercial, industrial, recreational, scenic, agricultural, natural resource protection, natural resource extraction, educational, religious, cultural, and historic areas, and any other area of unique land uses;	Page 8.4-6; Section 8.4.1.1 Pages 8.9-4 – 8.9-8; Sections 8.9.1.1 – 8.9.1.3 Pages 7-1 – 7-4; Section 7.1 Page 6-9; Section 6.2.2	Yes	
Appendix B (g) (3) (A) (ii)	A discussion of any trends in recent zoning changes and potential future land use development;	Page 8.4-9; Section 8.4.2	Yes	
Appendix B (g) (3) (A) (iii)	Identification of all discretionary reviews by public agencies initiated or completed within 18 months prior to filing the application for those changes or developments identified in subsection (g)(3)(A)(ii); and	Page 8.4-9; Section 8.4.3 Appendix 8.4A; Pages 8.4A-1 – 8.4A-2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Land Use  

Project:   Delta Energy Center  

Technical Staff:   Eric Knight  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (A) iv	Legible maps of the areas identified in subsection (g)(3)(A) potentially affected by the project, on which existing land uses, jurisdictional boundaries, general plan designations, specific plan designations, and zoning have been clearly delineated.	Figures 8.4-1 – 8.4-3; 8.9-1A; and 8.12-1A – 8.12-1C	No	Figure 8.4-1 is extremely gross and does not depict the boundaries between the different land uses. Many existing land uses (actual on-the-ground uses) that are identified in Section 8.4.1 and other sections of the AFC are not identified on Figure 8.4-1. No scale is provided on Figures 8.4-2 and 8.4-3, therefore staff is unable to determine if all zoning and general plan designations are provided within a 1-mile radius of the plant site. No map is provided depicting zoning and general plan designations within the linear facility corridors. Please provide maps which clearly delineate the following: 1) all existing land uses within a 1-mile radius of the site and within a ½-mile wide corridor (¼ mile on either side) of the proposed linear facilities; 2) general plan land-use designations within a 1-mile radius of the site and within a ½-mile wide corridor of the proposed linear facilities; 3) zoning designations within a 1-mile radius of the site and within a ½-mile wide corridor of the proposed linear facilities; and 4) jurisdictional boundaries for the Cities of Pittsburg and Antioch.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Land Use

Project:  Delta Energy Center

Technical Staff:  Eric Knight

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (B)	A discussion of the compatibility of the proposed facilities with present and expected land uses, and conformity with any long-range land use plans adopted by any federal, state, regional, or local planning agency. The discussion shall identify the need, if any, for variances or any measures that would be necessary to make the proposal conform with permitted land uses	Pages 8.4-13 – 8.4-15; Section 8.4.5	Yes	
Appendix B (g) (15) (B)	A map at a scale of 1:24,000 and written description of agricultural land uses found within all areas affected by the proposed project. The description shall include:	Figure 8.9-1A Pages 8.9-4 – 8.9-8; Sections 8.9.1.1 – 8.9.1.3	Yes	
Appendix B (g) (15) (B) (i)	Crop types, irrigation systems, and any special cultivation practices; and	Pages 8.9-4 – 8.9-8; Sections 8.9.1.1 – 8.9.1.4	Yes	
Appendix B (g) (15) (B) (ii)	Whether farmland affected by the project is prime, of statewide importance, or unique as defined by the Natural Resource Conservation Service of the California Department of Conservation.	Pages 8.9-4 – 8.9-8; Sections 8.9.1.1 – 8.9.1.3	Yes	
Appendix B (g) (15) (C)	An assessment of the effects of the proposed project on soil resources and agricultural land uses. This decision shall include:	Pages 8.9-12 – 8.9-14; Section 8.9.2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Land Use

Project:  Delta Energy Center

Technical Staff:  Eric Knight

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (15) (C) (ii)	Direct and indirect effects on agricultural land uses; and	Pages 8.9-12 – 8.9-14; Sections 8.9.2.1 – 8.9.2.3	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Pages 8.4-10 – 8.4-12; Section 8.4.4.2	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Page 8.4-10; Table 8.4-4 Page 8.4-14; Table 8.4-5	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Land Use  

Project:   Delta Energy Center  

Technical Staff:   Eric Knight  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Page 8.4-12; Section 8.4.4.2.4 Page 8.4-15; Section 8.4.5.6	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Page 9-5; Section 9.4.2	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Page 9-5; Section 9.4.3	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   **Noise**    
 Project Manager:   Paul Richins  

Project:   Delta Energy Center    
 Docket:   98-AFC-3  

Technical Staff:   Steve Baker    
 Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	§ 1.1, 1.2, 2.2.4.1, 2.2.8.5, 7.2, 8.4.6, 8.5.2, 8.5.3.2, 8.5.3.3, 8.5.3.5, 8.5.4; Tables 8.5-14, 8.5-15; § 8.5.4.1, 8.5.4.2	Yes	
Appendix B (g) (4) (A)	A land use map which identifies residences, hospitals, libraries, schools, places of worship, or other facilities where quiet is an important attribute of the environment within the area impacted by the proposed project. The area impacted by the proposed project is that area where there is a potential increase of 5 dB(A) or more, during either construction or operation, over existing background levels.	Figure 8.5-1	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Noise

Project: Delta Energy Center

Technical Staff: Steve Baker

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (4) (B)	A description of the ambient noise levels at those sites identified under subsection (g)(4)(A) which the applicant believes provide a representative characterization of the ambient noise levels in the project vicinity, and a discussion of the general atmospheric conditions, including temperature, humidity, and the presence of wind and rain at the time of the measurements. The existing noise levels shall be determined by taking noise measurements for a minimum of 25 consecutive hours at a minimum of one site. Other sites may be monitored for a duration at the applicant's discretion during the same 25-hour period. The results of the noise level measurements shall be reported in $L_{eq}$ (equivalent sound or noise level), $L_{dn}$ (day-night sound or noise level) or CNEL (Community Noise Equivalent Level) in units of dB(A). The $L_{10}$ , $L_{50}$ , and $L_{90}$ values (noise levels exceeded 10 percent, 50 percent, and 90 percent of the time, respectively) shall also be reported.	§ 8.5.2, Tables 8.5-3 through 8.5-10	Yes	
Appendix B (g) (4) (C)	A description of the major noise sources of the project, including the range of noise levels and the tonal and frequency characteristics of the noise emitted.	§ 8.5.3.3, 8.5.3.5, 8.5.4.1.2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Noise  

Project:   Delta Energy Center  

Technical Staff:   Steve Baker  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (4) (D)	An estimate of the project noise levels, during both construction and operation, at residences, hospitals, libraries, schools, places of worship, or other facilities where quiet is an important attribute of the environment, within the area impacted by the proposed project.	§ 8.5.3.2, 8.5.3.3, 8.5.3.5, 8.5.4.1.2, 8.5.4.3	Yes	
Appendix B (g) (4) (E)	An estimate of the project noise levels within the project site boundary during both construction and operation and the impact to the workers at the site due to the estimated noise levels.	§ 8.5.3.2, 8.5.3.3, 8.5.4.1, 8.5.4.1.2, 8.5.4.2	Yes	
Appendix B (g) (4) (F)	The audible noise from existing switchyards and overhead transmission lines that would be affected by the project, and estimates of the future audible noise levels that would result from existing and proposed switchyards and transmission lines. Noise levels shall be calculated at the property boundary for switchyards and at the edge of the rights-of-way for transmission lines.	§ 8.5.4.3	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Noise

Project: Delta Energy Center

Technical Staff: Steve Baker

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	§ 8.5.3.1, 8.5.5, Table 8.5-16	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.5-16	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	§ 8.5.3.1, 8.5.3.2, 8.5.4, 8.5.4.1, 8.5.4.1.2, 8.5.4.2	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 9.4-1	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Noise

Project: Delta Energy Center

Technical Staff: Steve Baker

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	§ 8.5.6	N/A	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Paleontologic Resources  

Project:   Delta Energy Center  

Technical Staff:   Robert Anderson  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Volume 1, Pages 8.16-7 through 10; Volume 2, Appendix 8.16A	Yes	
Appendix B (g) (16) (A)	Identification of the physiographic province and a brief summary of the geologic setting, formations, and stratigraphy of the project area. The area may vary depending on the depositional history of the area.	Volume 2, Appendix 8.16A Page 3 through 7	Yes	
Appendix B (g) (16) (B)	A discussion of the sensitivity of the project area described in subsection (g)(16)(A) and the presence and significance of any known paleontologic localities or other paleontologic resources within or adjacent to the project.	Volume 2, Appendix 8.16A Pages 9 and 11; Volume 2 Appendix 8.16A Table 2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Paleontologic Resources  

Project:   Delta Energy Center  

Technical Staff:   Robert Anderson  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (16) (C)	A summary of all literature searches and field surveys used to provide information about paleontologic resources in the project area described in subsection (g)(16)(A). Identify the dates of the surveys, methods used in completing the surveys, and the names and qualifications of the individuals conducting the surveys.	Volume 1, Page 8.16-3,4 and 5; Volume 2, Appendix 8.16A, Page 14	Yes	
Appendix B (g) (16) (D)	Information on the specific location of known paleontologic resources, survey reports, locality records, and maps at a scale of 1:24,000, shall be included in a separate appendix to the Application and submitted to the Commission under a request for confidentiality, pursuant to Title 20, California Code of Regulations, § 2501 et seq.	Volume 2, Appendix 8.16A, Appendix A	Yes	
Appendix B (g) (16) (E)	A discussion of any educational programs proposed to enhance awareness of potential impacts to paleontological resources by employees, measures proposed for mitigation of impacts to known paleontologic resources, and a set of contingency measures for mitigation of potential impacts to currently unknown paleontologic resources.	Volume 1, Pages 8.16-9 and 10, Section 8.16.4; Volume 2, appendix 8.16A, Page 13	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Paleontologic Resources  

Project:   Delta Energy Center  

Technical Staff:   Robert Anderson  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Volume 1, Page 8.16-11 Section 8.16.5, Table 8.16.2	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Volume 1, Page 8.16-11, Section 8.16.6	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Volume 1, Page 8.16-11, Section 8.16.5	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Volume 1, Page 8.16-11, Section 8.16.6	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Paleontologic Resources

Project: Delta Energy Center

Technical Staff: Robert Anderson

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Steve Baker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Volume 1. Page 8.16-11, Section 8.16.7	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Cal. Code Regs., tit. 20, § 1704, (a) (3) (A)	Descriptions of all significant assumptions, methodologies, and computational methods used in arriving at conclusions in the document.	AFC Vol. 1 & Vol. 2	Yes	
Cal. Code Regs., tit. 20, § 1704, (a) (3) (B)	Descriptions, including methodologies and findings, of all major studies or research efforts undertaken and relied upon to provide information for the document; and a description of ongoing research of significance to the project (including expected completion dates; and	AFC Vol. 1 & Vol. 2	Yes	
Cal. Code Regs., tit. 20, § 1704, (a) (3) (C)	A list of all literature relied upon or referenced in the documents, along with brief discussions of the relevance of each such reference	AFC Vol. 1 & Vol. 2	Yes	
Cal. Code Regs., tit. 20, § 1704, (a) (4)	Each principle subject area covered in a notice or application shall be set forth in a separate chapter or section, each of which shall identify the person or persons responsible for its preparation.	Vol. 1, p 1-11 and Vol. II 1c 1-2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (a) (1) (A)	A general description of the proposed site and related facilities, including the location of the site or transmission routes, the type, size and capacity of the generating or transmission facilities, fuel characteristics, fuel supply, water supply, pollution control systems, and other general characteristics.	Section 1 and 2	Yes	
Appendix B (a) (1) (B)	Identification of the location of the proposed site and related facilities by section, township, range, county and assessors parcel numbers.	Section 2	Yes	
Appendix B (a) (1) (C)	A description of and maps depicting the region, the vicinity, and the site and its immediate surroundings.	Section 2, 6, 7 and 8	Yes	
Appendix B (a) (1) (D)	A full-page color photographic reproduction depicting the visual appearance of the site prior to construction, and a full-page color simulation or artist's rendering of the site and all project components at the site, after construction.	Figure 1.1-3 Figure 1.1-4	Yes	
Appendix B (a) (1) (E)	In an appendix to the application, a list of current assessor's parcel numbers and owners' names and addresses for all parcels within 500 feet of the proposed transmission line and other linear facilities, and within 1000 feet of the proposed powerplant and related facilities.	Vol. II Appendices 1b	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (a) (2)	Project Schedule: Proposed dates of initiation and completion of construction, initial start-up, and full-scale operation of the proposed facilities.	Page 2-27	Yes	
Appendix B (a) (3) (A)	A list of all owners and operators of the site(s), the power plant facilities, and, if applicable, thermal host, the geothermal leasehold, the geothermal resource conveyance lines, and the geothermal re-injection system, and a description of their legal interest in these facilities.	pages 1-7 and 1-8	Yes	
Appendix B (a) (3) (B)	A list of all owners and operators of the proposed electric transmission facilities.	Section 1 & 2	No	Identify the owner of the proposed transmission line.
Appendix B (a) (3) (C)	A description of the legal relationship between the applicant and each of the persons or entities specified in subsections (a)(3)(A) and (B).	Section 1 & 2	No	Identify the owner of the natural gas line, the various water lines, discharge pipelines, transmission line to Dow and steam lines to Dow.
Appendix B (b) (1) (A)	Maps at a scale of 1:24,000 (1" = 2000'), along with an identification of the dedicated leaseholds by section, township, range, county, and county assessor's parcel number, showing the proposed final locations and layout of the power plant and all related facilities;	Figure 2.2-1 2.1-1a 2.1-1b	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (B)	Scale plan and elevation drawings depicting the relative size and location of the power plant and all related facilities;	Figure 2.2-2	Yes	
Appendix B (b) (1) (C)	A detailed description of the design, construction and operation of the facilities, specifically including the power generation, cooling, water supply and treatment, waste handling and control, pollution control, fuel handling, and safety, emergency and auxiliary systems, and fuel types and fuel use scenarios; and	Pages 2-1 through 2-38	Yes	
Appendix B (b) (1) (D)	A description of how the site and related facilities were selected and the consideration given to engineering constraints, site geology, environmental impacts, water, waste and fuel constraints, electric transmission constraints, and any other factors considered by the applicant.	Section 5	Yes	
Appendix B (b) (2) (A)	Maps at a scale of 1:24,000 of each proposed transmission line route, showing the settled areas, parks, recreational areas, scenic areas, and existing transmission lines within one mile of the proposed route(s).	Figure 6.3-1 Figure 6.0-2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (B)	A full-page color photographic reproduction depicting a representative above ground section of the transmission line route prior to construction and a full-page color photographic simulation of that section of the transmission line route after construction.	Figures 8.11-3a through 8.11-5b	Yes	
Appendix B (c)	In a section entitled, "Demand Conformance" provides a discussion explaining how the proposed project conforms with the requirements of Public Resources Code § 25524 or Public Resources Code § 25540.6(a)(5). If the provisions of Public Resources Code § 25523.5 are applicable, explain how the project conforms with the requirements of this section. Additional data adequacy requirements may be contained in the Electricity Report applicable pursuant to Title 20, California Code of Regulations, § 1720.5.	Section 3	Yes	
Appendix B (d) (1)	A copy of any study or analysis required by the terms of the Commission's Final Decision on the NOI, and a brief summary of the results of the study or analysis.	Section 1 & 2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Project Overview  

Project:   Delta Energy Center  

Technical Staff:   Paul Richins  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Roger Johnson  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (d) (2)	Updates of any significant information which has changed since the Commission's Final Decision on the NOI.	N/A	N/A	
Appendix B (e) (1)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Section 4	Yes	
Appendix B (f) (1)	A discussion of the range of reasonable alternatives to the project, or to the location of the project, including the no project alternative, which would feasibly attain most of the basic objectives of the project but would avoid or substantially lessen any of the significant effects of the project, and an evaluation of the comparative merits of the alternatives. In accordance with Public Resources Code section 25540.6(b), a discussion of the applicant's site selection criteria, any alternative sites considered for the project, and the reasons why the applicant chose the proposed site.	Pages 5-1 through 5-15, Section 5.0. Pages 6-16 through 6-26, Section 6.3 Pages 7-8 through 7-11, Section 7.4	Yes	
Appendix B (f) (2)	An evaluation of the comparative engineering, economic, and environmental merits of the alternatives discussed in subsection (f)(1).	Pages & sections noted for (f)(1)	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Public Health  

Project:   Delta Energy Center  

Technical Staff:   Mike Ringer  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sec. 8.1.1 Sec. 8.1.4.2 Sec. 8.6.1 Sec. 8.6.2.2 Sec. 8.6.2.3 Sec. 8.6.4.2	YES	
Appendix B (g) (9) (A)	A list of all toxic substances emitted by the project under normal operating conditions, which may cause an adverse public health impact as a result of acute, chronic, or sub-chronic exposure and to which members of the public may be exposed. This list should include, at a minimum, any pollutants emitted by the project that are listed pursuant to Health and Safety Code § 25249.8.	Table 8.1-19 Table 8.6-1	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Public Health  

Project:   Delta Energy Center  

Technical Staff:   Mike Ringer  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (9) (B)	A protocol describing the analysis which the applicant will conduct to determine the extent of potential public exposure to substances identified in subsection (g)(9)(A) resulting from normal facility operation. The analysis itself can be submitted after the AFC is complete.	Sec. 8.1.4.2 Appendix 8.1C Sec. 8.6.2.2	YES	
Appendix B (g) (9) (C)	A map at a scale of 1:24,000, showing all terrain areas exceeding the elevation of the stack within a 10 mile radius of the facility.	Fig. 8.6-1	YES	
Appendix B (g) (9) (D)	A map at a scale of 1:24,000, showing the distribution of population and sensitive receptors within the area exposed to the substances identified in subsection (g)(9)(A).	Figs. 8.12-1A,B,C	YES	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.6-6	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Public Health

Project: Delta Energy Center

Technical Staff: Mike Ringer

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.6-6	YES	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Table 8.1-33 Table 8.6-6	YES	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	N/A		
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	N/A		

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Reliability    
 Project Manager:   Paul Richins  

Project:   Delta Energy Center    
 Docket:   98-AFC-3  

Technical Staff:   Steve Baker    
 Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (3) (A)	A discussion of the sources and availability of the fuel or fuels to be used over the estimated service life of the facilities.	§ 1.1, 2.4.3	Yes	
Appendix B (i) (3) (B)	A discussion of the anticipated service life and degree of reliability expected to be achieved by the proposed facilities based on a consideration of:	--	N/A	
Appendix B (i) (3) (B) (i)	Expected annual and lifetime capacity factors;	§ 2.2.2, 2.2.17, 2.4.1, 9.2.2	Yes	
Appendix B (i) (3) (B) (ii)	The demonstrated or anticipated feasibility of the technologies, systems, components, and measures proposed to be employed in the facilities, including the power generation system, the heat dissipation system, the water supply system, the reinjection system, the atmospheric emission control system, resource conveyance lines, and the waste disposal system;	§ 1.1, 2.1, 2.2.2, 2.2.4, 2.2.5, 2.2.6, 2.2.8, 2.2.14.3, 2.2.17, 2.3.1, 2.4.1, Table 2.4-1, § 2.4.2, 2.4.3, 2.4.4, 2.4.5, 7.1, 9.2.1, 9.2.2	Yes	
Appendix B (i) (3) (B) (iii)	Geologic and flood hazards, meteorologic conditions and climatic extremes, and cooling water availability;	§ 1.1, 2.1, 2.3.1, 2.4.4, 8.15.1, 8.15.2, 9.2.2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Reliability  

Project:   Delta Energy Center  

Technical Staff:   Steve Baker  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (3) (B) (iv)	Special design features adopted by the applicant or resource supplier to ensure power plant reliability; and	§ 1.1, 2.2.2, 2.2.8.4, 2.2.14.3, 2.2.17, 2.3.1, Table 2.4-1, § 2.4.2, 2.4.3, 2.4.4, 2.4.5, 7.1, 8.15.3	Yes	
Appendix B (i) (3) (B) (v)	The expected power plant maturation period.	§ 9.2.2	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	N/A	N/A	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	N/A	N/A	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Reliability  

Project:   Delta Energy Center  

Technical Staff:   Steve Baker  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Steve Baker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	N/A	N/A	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	N/A	N/A	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	N/A	N/A	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Socioeconomics

Project:  Delta Energy Center

Technical Staff:  Amanda Stennick

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 8.8.1-8.8.6 Tables 8.8.-1 through 8.8-10	no	Provide a discussion of the cumulative impacts of this project and other known projects including the Pittsburg District Energy Facility for construction worker availability, school districts, and public services.
Appendix B (g) (7) (A)	A description of the socioeconomic circumstances of the vicinity and region affected by construction and operation of the project. Include:	see below	yes	
Appendix B (g) (7) (A) (i)	The economic characteristics, including the economic base, fiscal resources, and a list of the applicable local agencies with taxing powers and their most recent and projected revenues;	Sections 8.8.1.2; 8.8.1.4 Table 8.8-7	yes	
Appendix B (g) (7) (A) (ii)	The social characteristics, including population and demographic and community trends;	Section 8.8.1.1 Tables 8.8-1;-2;-3;-4	yes	
Appendix B (g) (7) (A) (iii)	Existing and projected unemployment rates;	Section 8.8.1.2 Table 8.8-5	yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Socioeconomics

Project:  Delta Energy Center

Technical Staff:  Amanda Stennick

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (A) (iv)	Availability of skilled workers by craft required for construction and operation of the project;	Table 8.8-9	no	Please complete the list in Table 8.8-9 for all workers by craft as listed in table 8.8-8
Appendix B (g) (7) (A) (v)	Availability of temporary and permanent housing; and	Section 8.8.1.3 Table 8.8-6	yes	
Appendix B (g) (7) (A) (vi)	Capacities, existing and expected use levels, and planned expansion of utilities (gas, water and waste) and public services, including fire protection, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. For projects outside metropolitan areas with a population of 500,000 or more, information for each school district shall include current enrollment and yearly expected enrollment by grade level groupings, excluding project-related changes, for the duration of the project construction schedule.	Section 8.8.1.5	yes	
Appendix B (g) (7) (B)	A discussion of the socioeconomic impacts caused by the construction and operation of the project, including:	see below	yes	
Appendix B (g) (7) (B) (i)	The number of workers to be employed each month by craft during construction and operation;	Table 8.8-8	yes	
Appendix B	An estimate of the number and percentage of	Section 8.8.2.3	yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Socioeconomics

Project:  Delta Energy Center

Technical Staff:  Amanda Stennick

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
(g) (7) (B) (ii)	workers who will commute daily, commute weekly, or relocate in order to work on the project;			
Appendix B (g) (7) (B) (iii)	An estimate of the potential population increase caused directly and indirectly by the project;	Section 8.8.2.5	yes	
Appendix B (g) (7) (B) (iv)	The potential impact of population increase on housing during the construction and operations phases;	Section 8.8.2.6	yes	
Appendix B (g) (7) (B) (v)	The potential impacts, including additional costs, on utilities (gas, water and waste) and public services, including fire, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. For projects outside metropolitan areas with a population of 500,000 or more, information on schools shall include project-related enrollment changes by grade level groupings and associated facility and staffing impacts by school district during the construction and operation phases;	Section 8.8.2	no	Provide a discussion of the cumulative impacts of this project and other known projects including the Pittsburg District Energy Facility for construction worker availability, school districts, and public services.
Appendix B (g) (7) (B) (vi)	An estimate of applicable school impact fees;	Section 8.8.5.3	yes	
Appendix B (g) (7) (B) (vii)	An estimate of the total construction payroll and an estimate of the total operation payroll;	Section 8.8.2.7	yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Socioeconomics  

Project:   Delta Energy Center  

Technical Staff:   Amanda Stennick  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (B) (viii)	An estimate of the expenditures for locally purchased materials for the construction and operation phases of the project; and	Section 8.8.2.7	yes	
Appendix B (g) (7) (B) (ix)	An estimate of the capital cost of the project of the potential impacts on tax revenues from construction and operation of the project.	Section 8.8.2.7	yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	not given	no	Please identify the LOR that includes provisions for levies against development projects near schools.
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.8.5.3	yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Socioeconomics  

Project:   Delta Energy Center  

Technical Staff:   Amanda Stennick  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Section 8.8.5.3	yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 8.8-11	yes	
Appendix (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.8.7	yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Soils  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pages 8.9-4 to 8.9-14	Yes	
Appendix B (g) (15) (A)	A map at a scale of 1:24,000 and written description of soil types and all agricultural land uses that will be affected by the proposed project. The description shall include:	Figure 8.9-1a, 1b	Yes	
Appendix B (g) (15) (A) (i)	The depth, texture, permeability, drainage, erosion hazard rating, and land capability class of the soil; and	Table 8.9-1	Yes	
Appendix B (g) (15) (A) (ii)	An identification of other physical and chemical characteristics of the soil necessary to allow an evaluation of soil erodibility, permeability, re-vegetation potential, and cycling of pollutants in the soil-vegetation system.	Pages 8.9-12 through 8.9-13	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Soils  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (15) (C)	An assessment of the effects of the proposed project on soil resources and agricultural land uses. This discussion shall include:	--	--	--
Appendix B (g) (15) (C) (i)	The quantification of accelerated soil loss due to wind and water erosion;	Table 8.9-3	Yes	
Appendix B (g) (15) (C) (iii)	The effect of power plant emissions on surrounding soil-vegetation systems.	Pages 8.2-41	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.9-5	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Soils  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.9-5	No	The City of Pittsburg's construction and grading permits were not included in the table. Provide an amended table including this information.
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Pages 8.9-15 to 16	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 8.9-6	Yes	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Page 8.9-16	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   x   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Traffic and Transportation  

Project:   Delta Energy Center  

Technical Staff:   David Flores  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	AFC Section 8.10.3, Pg. 8.10-15 AFC Section 8.10.2.3.1, Pg. 8.10-12 Table 8.10-6, Pg. 8.10-13 Table 8.10-7, Pg. 8.10-14	Yes	
Appendix B (g) (5) (A)	A regional transportation setting, on topographic maps (scale of 1:250,000), identifying the project location and major transportation facilities. Include a reference to the transportation element of any applicable local or regional plan.	AFC Section 8.10.2.3, Pg. 8.10-13, 14 AFC Section 8.10.5, Pg.8.10-7	Yes	
Appendix B (g) (5) (B)	An identification, on topographic maps at a scale of 1:24,000 and a description of existing and planned roads, rail lines, including light rail, bike trails, airports, bus routes serving the project vicinity, pipelines, and canals in the project area affected by or serving the proposed facility. For each road identified, include the following information, where applicable:	AFC Section 8.10.1.6, 8.10.1.7, 8.10.1.8, Pg. 8.10-7	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   x   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Traffic and Transportation  

Project:   Delta Energy Center  

Technical Staff:   David Flores  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (5) (B) (i)	Road classification and design capacity;	AFC Section 8.10.1.1, Pg. 8.10-1	Yes	
Appendix B (g) (5) (B) (ii)	Current daily average and peak traffic counts;	AFC Section 8.10.1.3 Table 8.10-1, Pg. 8.10-4, Figure 8.10-2	Yes	
Appendix B (g) (5) (B) (iii)	Current and projected levels of service before project development, during construction, and during project operation;	AFC Section 8.10.2.2.1, Pg. 8.10-9 Section 8.10.2.2.2, Pg.8.10-10 Section 8.10.2.2.3,4,5 Table 8.10-4, Pg. 8.10-12	Yes	
Appendix B (g) (5) (B) (iv)	Weight and load limitations;	AFC Section 8.10.1.2, Pg.8.10-3 Figure 8.10-2, Pg.8.10-5	Yes	
Appendix B (g) (5) (B) (v)	Estimated percentage of current traffic flows for passenger vehicles and trucks; and	AFC Section 8.10.1.3, Pg.8.10-3 Table 8.10-1, Pg. 8.10-4	Yes	
Appendix B (g) (5) (B) (vi)	An identification of any road features affecting public safety.	AFC Section 8.10.1.4, Pg.8.10-6	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Traffic and Transportation

Project: Delta Energy Center

Technical Staff: David Flores

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (5) (C)	A description of any new, planned, or programmed transportation facilities in the project vicinity, including those necessary for construction and operation of the proposed project. Specify the location of such facilities on topographic maps at a scale of 1:24,000.	AFC Section 8.10.1.5, Pg. 8.10-6 Table 8.10-3, Pg. 8.10-7	Yes	
Appendix B (g) (5) (D)	An assessment of the construction and operation impacts of the proposed project on the transportation facilities identified. Include anticipated project-specific traffic, estimated changes to daily average and peak traffic counts, levels of service, and traffic/truck mix, and the impact of construction of any facilities identified in subsection (g)(5)(C).	AFC Section 8.10.2.2.5, Pg. 8.10-11 Table 8.10-4, Pg. 8.10-12 AFC Section 8.10.2.3.1, Pg. 8.10-12 Table 8.10-5, Pg. 8.10-13 Table 8.10-6, Pg. 8.10-13, Table 8.10-7, Pg. 8.10-14	Yes	
Appendix B (g) (5) (E)	A discussion of project-related hazardous materials to be transported to or from the project during construction and operation of the project, including the types, estimated quantities, estimated number of trips, anticipated routes, means of transportation, and any transportation hazards associated with such transport.	AFC Section 8.10.2.2.1, Pg. 8.10-10 Section 8.10.2.3, Pg. 8.10-13, 14 Section 8.10-15, 16	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   x   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Traffic and Transportation  

Project:   Delta Energy Center  

Technical Staff:   David Flores  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	AFC Section 8.10.5, Sec. 8.10.5.1, 2 Pg. 8.10-16  Table 8.10-8, Pg. 8.10-17	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.10-8, Pg. 8.10-17	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	AFC Section 8.10.5.2, Pg. 8.10-16	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 8.10-16	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Traffic and Transportation

Project: Delta Energy Center

Technical Staff: David Flores

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	AFC Section 8.10.6, Table 8.10-9	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   TRANSMISSION  

Project:   Delta  

Technical Staff:   Ean O'Neill/ O.  

Project Manager:   Paul Richins  

Docket:   98 AFC-3  

Technical Senior:   Al McCuen/ Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2) (A)	A discussion of the need for the additional electric transmission lines, substations, or other equipment, the basis for selecting principal points of junction with the existing electric transmission system, and the capacity and voltage levels of the proposed lines, along with the basis for selection of the capacity and voltage levels.	Section 6.3.1, pages 6-23 through 6-26	Yes	
Appendix B (i) (2) (B)	A discussion of the extent to which the proposed electric transmission facilities have been designed, planned, and routed to meet the transmission requirements created by additional generating facilities planned by the applicant or any other entity.	Not Applicable		

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: TRANSMISSION

Project: Delta

Technical Staff: Ean O'Neill/ O.

Project Manager: Paul Richins

Docket: 98 AFC-3

Technical Senior: Al McCuen/ Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (C)	A detailed description of the design, construction, and operation of any electric transmission facilities, such as power lines, substations, switchyards, or other transmission equipment, which will be constructed or modified to transmit electrical power from the proposed power plant to the load centers to be served by the facility. Such description shall include the width of rights of way and the physical and electrical characteristics of electrical transmission facilities such as towers, conductors, and insulators. This description shall include power load flow diagrams which demonstrate conformance or nonconformance with utility reliability and planning criteria at the time the facility is expected to be placed in operation and five years thereafter; and	Section 6.1, pages 6-1 through 6-4 Section 6.2, pages 6-4 through 6-16  Section 6.4, Appendix 6.4A and 6.4B, pages 1-7	Yes	The Interconnection Study has not been completed by PG&E. A progress report, screening study and schedule have been completed and are provided in Appendix 6.4-B.
Appendix B (b) (2) (D)	A description of how the route and additional transmission facilities were selected, and the consideration given to engineering constraints, environmental impacts, resource conveyance constraints, and electric transmission constraints.	Section 6.3.1, pages 6-23 through 6-26	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: TRANSMISSION

Project: Delta

Technical Staff: Ean O'Neill/ O.

Project Manager: Paul Richins

Docket: 98 AFC-3

Technical Senior: Al McCuen/ Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 6.3.1, pages 6-23 through 6-26 Section 6.1.1, page 6-1 and Figure 6.0-1 Section 6.2.1, page 6-4	Yes	
Appendix B (g) (18) (A)	The locations and a description of the existing switchyards and overhead and underground transmission lines that would be affected by the proposed project.	Section 6.1.1, page 6-1 and Figure 6.0-1 Section 6.2.1, page 6-4	Yes	
Appendix B (g) (18) (B)	An estimate of the existing electric and magnetic fields from the facilities listed in (A) above and the future electric and magnetic fields that would be created by the proposed project, calculated at the property boundary of the site and at the edge of the rights of way for any transmission line. Also provide an estimate of the radio and television interference that could result from the project.	Sections 6.5.3.1 to 6.5.3.1.2, pages 6-29 to 32; Section 6.5.3.2.2, pages 39 to 40	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: TRANSMISSION

Project: Delta

Technical Staff: Ean O'Neill/ O.

Project Manager: Paul Richins

Docket: 98 AFC-3

Technical Senior: Al McCuen/ Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (18) (C)	Specific measures proposed to mitigate identified impacts, including a description of measures proposed to eliminate or reduce radio and television interference, and all measures taken to reduce electric and magnetic field levels.	Sections 6.5.3.1.3 to 6.5.3.1.4, pages 6-32 to 37; Sections 6.5.3.2.2, page 6-39 to 40; Sections 6.5.3.1.5 to 6.5.3.2.1, pages 6-37 to 39	Yes	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 6.6.1 to 6.6.7, pages 6-41 to 44	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 6.6.1, page 6-41	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   **TRANSMISSION**  

Project:   Delta  

Technical Staff:   Ean O'Neill/ O.  

Project Manager:   Paul Richins  

Docket:   98 AFC-3  

Technical Senior:   Al McCuen/ Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Appendix 9D, pages 9D-1 & 2  Sections 6.5.1 through 6.5.4; pages 6-26 to 40	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Not Applicable		
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Not Applicable		

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Visual Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 8.11, pp.8.11-1 through 8.11-29.	YES	
Appendix B (g) (6) (A)	Descriptions of the existing visual setting of the vicinity of the project, the region that can be seen from the vicinity of the project, and the proposed project site. Include:	See below.	See below.	
Appendix B (g) (6) (A) (i)	Topographic maps at a scale of 1:24,000 of the areas from which the project may be seen, identification of the view areas most sensitive to the potential visual impacts of the project, and the locations where photographs were taken for (g)(6)(E);	Section 8.11.1, Figure 8.11-1, p.8.11-3.	YES	
Appendix B (g) (6) (A) (ii)	Elevations of any existing structures on the site; and	Not applicable; see Section 8.11.1.2.1, p. 8.11-2.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   X  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Visual Resources  

Project:   Delta Energy Center  

Technical Staff:   Gary Walker  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dale Edwards  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (A) (iii)	The visual properties of the topography, vegetation, and any modifications to the landscape as a result of human activities.	Section 8.11.1, pp.8.11-1 through 8.11-8.11-17	YES	
Appendix B (g) (6) (B)	An assessment of the visual quality of those areas that will be impacted by the proposed project.	Section 8.11.1.4, pp.8.11-15 through 8.11-17.	NO	The AFC (p.8.11-15) states that for the area of the Pittsburg-Antioch Highway "although the visual quality of most areas along the highway is not high, the views northward across the Dow lands offer some visual interest." Please explain whether this statement means that for some areas along the highway visual quality is high, and if so, are they the views northward across the Dow lands. The AFC (p.8.11-16) states that views from the eastern fringes of the Dow property "were considered potentially sensitive" means that the visual quality of these views is high. If not, please provide an assessment of the visual quality of these views. The AFC (p.8.11-17) describes the visual setting of the views toward the proposed transition station from the residential area along East Santa Fe Avenue near Columbia Street. Please provide an assessment of the visual quality of these views.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Visual Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (C)	After discussions with staff and community residents who live in close proximity to the proposed project, identify the scenic corridors and any visually sensitive areas potentially affected by the proposed project, including recreational and residential areas. Indicate the approximate number of people using each of these sensitive areas and the estimated number of residences with views of the project. For purposes of this section, a scenic corridor is that area of land with scenic natural beauty, adjacent to and visible from a linear feature, such as a road, or river.	Section 8.11.1.4, pp.8.11-15 through 8.11-17.	NO	Please indicate the approximate number of residential units in the view area represented by Key Observation Point 1. Please estimate the frequency of use and the number of users of the Babe Ruth baseball facility in the view area represented by Key Observation Point 2. Please indicate the approximate number of residences in the view area represented by Key Observation Point 3.
Appendix B (g) (6) (D)	A description of the dimensions, color, and material of each major visible component of the project.	Section 8.11.2.2, pp.8.11-18 through 8.11-20; Section 6.2.2, pp.6-10 through 6-23.	YES	
Appendix B (g) (6) (E)	Full-page color photographic reproductions of the existing site, and full-page color simulations of the proposed project in the existing setting from each location representative of the view areas most sensitive to the potential visual impacts of the project.	Section 8.11.1.4, Figures 8.11-3a, 8.11-4a, and 8.11-5a; Section 8.11.2.3., Figures 8.11-3b, 8.11-4b, and 8.11-5b.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Visual Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (F)	An assessment of the visual impacts of the project, including light and glare, and visible plumes.	Section 8.11.2, pp.8.11-17 through 8.11-23.	YES	
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 8.11.6, Table 8.11-2, pp.8.11-24 through 8.11-27.	YES	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.11.6, Table 8.11-2.	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate  X

Revision No.  0  Date  January 14, 1999

Technical Area:  Visual Resources

Project:  Delta Energy Center

Technical Staff:  Gary Walker

Project Manager:  Paul Richins

Docket:  98-AFC-3

Technical Senior:  Dale Edwards

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Section 8.11.6, Tables 8.11-3 and 8.11-4, pp. 8.11-26 and 8.11-28.	NO	Table 8.11-2, p.8.11-25, states that conformance with the Antioch General Plan is discussed in Table 8.11-5, but the AFC does not contain Table 8.11-5. Please provide Table 8.11-5.
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Section 8.11.6, Table 8.11-2.	YES	
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 8.11.6, Tables 8.11-3 and 8.11-4, pp.8.11-26 and 8.11-28.	NO	The AFC (Table 8.11-4, p.8.11-28) states that a) "because the DEC stacks will be up to 144' high, a zoning variance will be required and will be applied for; b) "because the DEC will be located in the middle of the Dow property and 1,500 feet or more from the nearest public street, a variance will be requested to install the required landscaping along the edge of the Pittsburg-Antioch Highway...;" and c) "the project will undergo design review under the process established in the Pittsburg Zoning Ordinance." Please provide schedules for obtaining the permit(s) related to these requirements.

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Waste Management  

Project:   Delta Energy Center  

Technical Staff:   Mike Ringer  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (C)	A detailed description of the design, construction and operation of the facilities, specifically including the power generation, cooling, water supply and treatment, waste handling and control, pollution control, fuel handling, and safety, emergency and auxiliary systems, and fuel types and fuel use scenarios; and	Sec. 2.2.10 Sec. 8.13	YES	
Appendix B (e) (2)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Sec. 4 Sec. 8.13.4.3	YES	
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Appendix 8.13A Sec. 8.13.4.1 Sec. 8.13.4.2 Sec. 8.13.5 Sec. 8.13.6	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Waste Management

Project: Delta Energy Center

Technical Staff: Mike Ringer

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (12) (A)	A Phase I Environmental Site Assessment for the proposed power plant site using methods prescribed by the American Society for Testing and Materials (ASTM) document entitled "Standard Practice for Environmental Site Assessments: Phase 1 Environmental Site Assessment Process" (Designation: E 1527-93, May 1993), which is incorporated by reference in its entirety; or an equivalent method agreed upon by the applicant and the CEC Staff that provides similar documentation of the potential level and extent of site contamination.	Sec. 8.13.1 Appendix 8.13A	YES	
Appendix B (g) (12) (B)	A description of each waste stream estimated to be generated during project construction and operation, including origin, hazardous or nonhazardous classification pursuant to Title 22, California Code of Regulations, § 66261.20 et seq., chemical composition, estimated annual weight or volume generated, and estimated frequency of generation.	Sec. 2.2.10 Sec. 7.2 Sec. 8.13.2.1.1 Sec. 8.13.2.2.2 Sec. 8.13.2.2.3	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Waste Management  

Project:   Delta Energy Center  

Technical Staff:   Mike Ringer  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (12) (C)	A description of all waste disposal sites which may feasibly be used for disposal of project wastes. For each site, include the name, location, classification under Title 23, California Code of Regulations, § 2530 et seq., the daily or annual permitted capacity, daily or annual amounts of waste currently being accepted, the estimated closure date and remaining capacity, and a description of any enforcement action taken by local or state agencies due to waste disposal activities at the site.	Sec. 8.13.3.1 Sec. 8.13.3.2	YES	
Appendix B (g) (12) (D)	A description of management methods for each waste stream, including methods used to minimize waste generation, length of on- and off-site waste storage, re-use and recycling opportunities, waste treatment methods used, and use of contractors for treatment.	Sec. 2.2.10 Sec. 7.2 Sec. 8.13.2.1.1 Sec. 8.13.2.2.2 Sec. 8.13.2.2.3 Sec. 8.13.4	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Waste Management

Project: Delta Energy Center

Technical Staff: Mike Ringer

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.13-3	YES	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.13-4	YES	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Table 8.13-3	YES	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Table 8.13-4	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Waste Management

Project: Delta Energy Center

Technical Staff: Mike Ringer

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Sec. 8.13.4.2.2 Sec. 8.13.9	YES	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Water Resources    
 Project Manager:   Paul Richins  

Project:   Delta Energy Center    
 Docket:   98-AFC-3  

Technical Staff:   Joe O'Hagan    
 Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pages 8.14-1 through 8.14-14, Sections 8.14.1 through 8.14-7.	Yes	
Appendix B (g) (14) (A)	All information required by the Regional Water Quality Control Board in the region where the project will be located to apply for:	--	--	
Appendix B (g) (14) (A) (i)	Waste Discharge Requirements; and	N/A		
Appendix B (g) (14) (A) (ii)	a National Pollutant Discharge Elimination System Permit.	Page. 8.14-3, Section 8.14.1.2	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Water Resources  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (B)	A description of the hydrologic setting of the project. The information shall describe, in writing and on maps at a scale of 1:24,000, the chemical and physical characteristics of the following water bodies that may be affected by the proposed project:	Pages 8.14-1 to 8.14-4, Section 8.14.1; Fig. 6.1.1	Yes	
Appendix B (g) (14) (B) (i)	Ground water bodies and related geologic structures;	Pages 8.14-1 to 8.14-3, Section 8.14.1.1	Yes	
Appendix B (g) (14) (B) (ii)	Surface water bodies; and	Pages 8.14-3 through 8.14-7, Section 8.14.1.2; Figure 6.0-1	Yes	
Appendix B (g) (14) (B) (iii)	Water inundation zones, such as the 100-year flood plain and tsunami run-up zones.	Page 8.14-4, Section 8.14.1.3	No	Provide a discussion of the linear facilities in relation to the 100 year flood zone. Provide a map depicting all project facilities in relation to the 100 year flood zone.
Appendix B (g) (14) ©	A description of the water to be used and discharged by the project. This information shall include:	--	--	--

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Water Resources  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (C) (i)	Source of the water and the rationale for its selection, and if fresh water is to be used for power plant cooling purposes, a discussion of all other potential sources and an explanation why these sources were not feasible;	Water Supply; Pages 2-15 and 8.14-4, Sections 2.2.8.2 and 8.14.2.1	No	Provide an explanation of the rationale for using fresh water for non-domestic purposes.
Appendix B (g) (14) (C) (ii)	The physical and chemical characteristics of the source and discharge water;	Pages 8.2-42, 8.2-51, 8.14-3, 8.14-4 through 8.14-6, and 8.14-11; Sections 8.2.2.1.4, 8.2.3.3 and 8.14.1 through 8.14-4.	Yes	
Appendix B (g) (14) (C) (iii)	Average and maximum daily and annual water demand and waste water discharge for both the construction and operation phases of the project; and	Pages 2-15, 8.14-7 and 8.14-8, Sections 2.2.8.1 and 8.14.2.4	Yes	
Appendix B (g) (14) (C) (iv)	A description of all facilities to be used in water conveyance, treatment, and discharge. Include a water mass balance diagram.	Nonhazardous Wastewater: pg. 8.13-3 to 5, 2-16 to 2-17, Sections 8.13.2.2.1,	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Water Resources  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (14) (D)	A description of pre-, and post-construction runoff and drainage patterns, including:	--	--	--
Appendix B (g) (14) (D) (i)	Precipitation and storm runoff patterns; and	Pages 8.14-8 through 8.14-9, Section 8.14.3	Yes	
Appendix B (g) (14) (D) (ii)	Drainage facilities and design criteria.	Page 8.14-9, Section 8.14.3.4; Figure 8.14-1	Yes	
Appendix B (g) (14) (E)	An assessment of the effects of the proposed project on water resources. This discussion shall include:	--	--	--
Appendix B (g) (14) (E) (i)	The effects of project demand on the water supply and other users of this source;	Page 8.14-4, Section 8.14.2.1	Yes	
Appendix B (g) (14) (E) (ii)	The effects of construction activities and plant operation on water quality; and	Page 8.14-11, Section 8.14.4.2	Yes	
Appendix B (g) (14) (iii)	The effects of the project on the 100-year flood plain or other water inundation zones.	Pages 8.14-9 to 10, 8.14-14, Section 8.14.3.2 to 8.14.3.4 and 8.14.4.3	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   Water Resources  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Table 8.14-11	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 8.14-11	No	Provide an amended table which identifies each agency with jurisdiction to issue permits and enforce LORS that are located in Table 8.14-11.
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Pages 8.14-15 to 8.14-18, Sections 8.14.8 to 8.14.8.3	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Page 8.14-19, Section 8.14.11	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate \_\_\_\_\_ Inadequate   x  

Revision No.   0   Date   January 14, 1999  

Technical Area:   **Water Resources**  

Project:   Delta Energy Center  

Technical Staff:   Joe O'Hagan  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Dr. Jim Brownell  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Page 8.14-18, Section 8.14.9	Yes	

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Worker Safety  

Project:   Delta Energy Center  

Technical Staff:   Ellie Townsend-Smith  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 1, p. 1-2 Section 8.7.6, p. 8.7-16 Section 8.7.5, p. 8.7-16 Section 8.7.4, pg. 8.7-16	Yes	
Appendix B (g) (11) (A)	A description of the safety training programs which will be required for construction and operation personnel.	Section 8.7 pp. 8.7-6 & 8.7-7	Yes	
Appendix B (g) (11) (B)	A complete description of the fuel handling system and the fire suppression system.	Section 2.2., 2.3, pg. 2-14, pg. 2-4, pg. 2-31	Yes	



## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate   X   Inadequate       

Revision No.   0   Date   January 14, 1999  

Technical Area:   Worker Safety  

Project:   Delta Energy Center  

Technical Staff:   Ellie Townsend-Smith  

Project Manager:   Paul Richins  

Docket:   98-AFC-3  

Technical Senior:   Chris Tooker  

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	Section 8.7.8, pg. 8.7-17.21	Yes	
Appendix B (h) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 8.7.12, pg. 8.7-17 through 21	Yes	
Appendix B (h) (2)	A discussion of the conformity of the project with the requirements listed in subsection (h)(1)(A).	Sec. 8.7.12, pg. 8.7-7-21	Yes	
Appendix B (h) (3)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency.	Sec. 8.7-12, pg. 8.7-22	Yes	Additional Info: Richard Ryan, Fire Inspector, Contra Costa Fire Protection District, 2010 Geary Rd., Pleasant Hill, CA 94523 (925) 930-5589

## DATA ADEQUACY WORKSHEET

Adequacy Issue: Adequate  Inadequate

Revision No. 0 Date January 14, 1999

Technical Area: Worker Safety

Project: Delta Energy Center

Technical Staff: Ellie Townsend-Smith

Project Manager: Paul Richins

Docket: 98-AFC-3

Technical Senior: Chris Tooker

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Sec. 8.7.11, pg. 8.7-22	Yes	

**Comments from the City of Antioch are not available electronically.**

