

## 8.7 Worker Health and Safety

### 8.7.1 Introduction

The Eastshore Energy Center (Eastshore) will be a nominal 115.5-megawatt (MW) intermediate/peaking load facility operating up to 4,000 hours per year using natural gas-fired reciprocating engine technology. The Eastshore facility will be located at 25101 Clawiter Road in the City of Hayward, Alameda County, California, on a 6.22 acre parcel owned by Eastshore Energy, LLC, the project owner. Major features of the Eastshore project include the following:

- Demolition of the existing site building, foundations and paved surface,
- Grading of site and installation of new foundations, piping and utility connections,
- Fourteen (14) nominal 8.4 MW (gross) Wartsila model 20V34SG natural gas-fired reciprocating engine – generator sets,
- Fourteen (14) state-of-the-art air pollution control systems representing Best Available Control Technology (BACT), one system per each of the 14 engines, consisting of a selective catalytic reduction (SCR) unit for oxides of nitrogen (NO<sub>x</sub>) control and an oxidation catalyst unit for carbon monoxide (CO) and precursor organic compounds (POC) control,
- Fourteen (14) approximately 70-foot tall stacks, each with a separate continuous emissions monitoring system (CEMS),
- Acoustically-engineered main building enclosing all 14 engines,
- Closed loop cooling system consisting of multiple fan-cooled radiator assemblies outside of the main engine building,
- Two 10,000 gallon (each) aqueous (19% by weight) ammonia storage tanks and handling system serving the SCR units,
- One raw water storage tank, approximately 35,000 gallons,
- One nominal 225-kW diesel-fired emergency black start generator,
- One (1) either electric or 7.15 MMBtu/hr natural gas-fired heater (BAAQMD exempt), used for heating of the natural gas fuel to the reciprocating engines,
- Miscellaneous ancillary equipment,
- Pre-existing onsite water and wastewater service interconnections,
- Onsite 115 kV switchyard including switchgear and step-up voltage transformers,
- Approximately 1.1-mile 115 kV single-circuit transmission line interconnecting to PG&E's Eastshore Substation,
- Approximately 200-foot offsite natural gas line connection to PG&E Line 153,

- Chain-link security fencing enclosing the facility with a secured entrance on Clawiter Road, and
- 4.65-acre temporary construction laydown and parking area located immediately across Clawiter Road from the Eastshore site.

This section summarizes the health and safety issues that may be encountered during the construction and operation of the proposed project, a new nominal 118 MW (gross) power plant. The proposed project is called the Eastshore Power Plant and is located in the City of Hayward, California.

Subsection 8.7.2 contains worker safety information including the laws, ordinances, regulations, and standards (LORS) that apply to this project. It also contains separate sections outlining the safety training programs and general health and safety programs that will be prepared and implemented for this project, as well as information on the methods to control anticipated hazards, fire protection information, and general information on permitting agencies and contacts. Subsection 8.7.3 provides a brief description of the project setting, while Subsection 8.7.4 provides a discussion of the project impacts. Subsection 8.7.5 provides a list of involved agencies and agency contacts and Subsection 8.7.6 lists required permits and provides a permit schedule.

## 8.7.2 Laws, Ordinances, Regulations, and Standards

Construction and operation of the Eastshore facility will be conducted in accordance with all applicable LORS. Tables 8.7-1 through 8.7-4 summarize the LORS relating to worker health and safety. Table 8.7-1 provides a summary of federal LORS; Table 8.7-2 summarizes the state LORS; Table 8.7-3 lists the local (county) LORS; and Table 8.7-4 provides a summary of the applicable national consensus standards.

TABLE 8.7-1  
Federal Laws, Ordinances, Regulations, and Standards

Law, Ordinance, Regulation, or Standard	Applicability
Title 29 Code of Federal Regulations (CFR) Part 1910*	Contains the minimum occupational safety and health standards for general industry in the United States
Title 29 CFR Part 1926*	Contains the minimum occupational safety and health standards for the construction industry in the United States

\* Primary laws and regulations governing worker health and safety in California are provided in Table 8.7-2. These regulations are for reference and apply as referenced by California occupational safety and health regulations. Where a particular situation is not addressed by those regulations, the CFR will be consulted for guidance.

TABLE 8.7-2  
State Laws, Ordinances, Regulations, and Standards

Law, Ordinance, Regulation, or Standard	Applicability
California Occupational Safety and Health Act, 1970	Establishes minimum safety and health standards for construction and general industry operations in California
8 California Code of Regulations (CCR) 339	Requires list of hazardous chemicals relating to the Hazardous Substance Information and Training Act
8 CCR 450	Addresses hazards associated with pressurized vessels
8 CCR 750	Addresses hazards associated with high-pressure steam
8 CCR 1509	Addresses requirements for construction, accident, and prevention plans
8 CCR 1509, et seq., and 1684, et seq.	Addresses construction hazards, including head, hand, and foot injuries and noise and electrical shock
8 CCR 1528, et seq., and 3380, et seq.	Requirements for personal protective equipment (PPE)
8 CCR 1597, et seq., and 1590, et seq.	Requirements addressing the hazards associated with traffic accidents and earth-moving
8 CCR 1604, et seq.	Requirements for construction hoist equipment
8 CCR 1620, et seq., and 1723, et seq.	Addresses miscellaneous hazards
8 CCR 1709, et seq.	Requirements for steel reinforcing, concrete pouring, and structural steel erection operations
8 CCR 1920, et seq.	Requirements for fire protection systems
8 CCR 2300, et seq., and 2320, et seq.	Requirements for addressing low-voltage electrical hazards
8 CCR 2395, et seq.	Addresses electrical installation requirements
8 CCR 2700, et seq.	Addresses high-voltage electrical hazards
8 CCR 3200, et seq., and 5139, et seq.	Requirements for control of hazardous substances
8 CCR 3203, et seq.	Requirements for operational accident prevention programs
8 CCR 3270, et seq., and 3209, et seq.	Requirements for evacuation plans and procedures
8 CCR 3301, et seq.	Requirements for addressing miscellaneous hazards, including hot pipes, hot surfaces, compressed air systems, relief valves, enclosed areas containing flammable or hazardous materials, rotation equipment, pipelines, and vehicle-loading dock operations
8 CCR 3360, et seq.	Addresses requirements for sanitary conditions
8 CCR 3511, et seq., and 3555, et seq.	Requirements for addressing hazards associated with stationary engines, compressors, and portable, pneumatic, and electrically powered tools
8 CCR 3649, et seq., and 3700, et seq.	Requirements for addressing hazards associated with field vehicles
8 CCR 3940, et seq.	Requirements for addressing hazards associated with power transmission, compressed air, and gas equipment
8 CCR 5109, et seq.	Requirements for addressing construction accident and prevention programs
8 CCR 5110, et seq.	Requirements for the implementation of an ergonomics program
8 CCR 5139, et seq.	Requirements for addressing hazards associated with welding, sandblasting, grinding, and spray-coating
8 CCR 5150, et seq.	Requirements for confined space entry
8 CCR 5160, et seq.	Requirements for addressing hot, flammable, poisonous, corrosive, and irritant substances

TABLE 8.7-2  
State Laws, Ordinances, Regulations, and Standards

<b>Law, Ordinance, Regulation, or Standard</b>	<b>Applicability</b>
8 CCR 5192, et seq.	Requirements for conducting emergency response operations
8 CCR 5194, et seq.	Requirements for employee exposure to dusts, fumes, mists, vapors, and gases
8 CCR 5405, et seq.; 5426, et seq.; 5465, et seq.; 5500, et seq.; 5521, et seq.; 5545, et seq.; 5554, et seq.; 5565, et seq.; 5583, et seq.; and 5606, et seq.	Requirements for flammable liquids, gases, and vapors
8 CCR 5583, et seq.	Requirements for design, construction, and installation of venting, diking, valving, and supports
8 CCR 6150, et seq.; 6151, et seq.; 6165, et seq.; 6170, et seq.; and 6175, et seq.	Requirements for fire protection
24 CCR 3 et seq.	Incorporates current addition of Uniform Building Code
8 CCR, Part 6	Provides health and safety requirements for working with tanks and boilers
Health and Safety Code Section 25500, et seq.	Requires that every new or modified facility that handles, treats, stores, or disposes of more than the threshold quantity of any of the listed regulated substances prepare and maintain a Risk Management Plan (RMP)
Health and Safety Code Sections 25500 through 25541	Requires the preparation of a Hazardous Material Business Plan (HMBP) that details emergency response plans for a hazardous materials emergency at the facility

TABLE 8.7-3  
Local Laws, Ordinances, Regulations, and Standards Required by City of Hayward Fire Department

<b>Law, Ordinance, Regulation, or Standard</b>	<b>Applicability</b>
Specific hazardous material handling requirements	Provides response agencies with necessary information to address emergencies
Emergency Response Plan	Allows response agency to integrate Eastshore emergency response activities into any response actions
Business Plan	Provides response agency with overview of Eastshore purpose and operations
Risk Management Plan (Certified Unified Program Agency [CUPA])	Provides response agency with detailed review of risks and hazards located at Eastshore and mitigation implemented to control risks or hazards

TABLE 8.7-4  
Applicable National Consensus Standards

Law, Ordinance, Regulation, or Standard	Applicability
Uniform Fire Code, Article 80	Addresses the prevention, control, and mitigation of dangerous conditions related to storage, dispensing, use, and handling of hazardous materials and information needed by emergency response personnel
National Fire Protection Association (NFPA) 10, Standard for Portable Fire Extinguishers	Requirements for selection, placement, inspection, maintenance, and employee training for portable fire extinguishers
NFPA 13, Standard for Installation of Sprinkler Systems	Guidelines for selection and installation of fire sprinkler systems
NFPA 13A, Recommended Practice for the Inspection, Testing and Maintenance of Sprinkler Systems	Guidelines for inspection, testing, and maintenance of sprinkler systems
NFPA 14, Standard for the Installation of Standpipe and Hose Systems	Guidelines for selection and installation of standpipe and hose systems
NFPA 15, Standard for Water Spray Fixed Systems	Guidelines for selection and installation of water spray fixed systems
NFPA 17, Standard for Dry Chemical Extinguishing Systems	Guidance for selection and use of dry chemical extinguishing systems
NFPA 20, Standard for the Installation of Centrifugal Fire Pumps	Guidelines for selection and installation of centrifugal fire pumps
NFPA 22, Standard for Water Tanks for Private Fire Protection	Requirements for water tanks for private fire protection
NFPA 24, Standard for the Installation of Private Fire Service Mains and Their Appurtenances	Requirements for private fire service mains and their appurtenances
NFPA 26, Recommended Practice for the Supervision of Valves Controlling Water Supplies	Supervision guidance for valves controlling water supplies
NFPA 30, Flammable and Combustible Liquid Code	Requirements for storage and use of flammable and combustible liquids
NFPA 37, Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines	Fire protection requirements for installation and use of combustion engines and gas turbines
NFPA 54, National Fuel Gas Code	Fire protection requirements for use of fuel gases
NFPA 59A, Standard for the Storage and Handling of Liquefied Petroleum Gases	Requirements for storage and handling of liquefied petroleum gases
NFPA 68, Guide for Explosion Venting	Guidelines in design of facilities for explosion venting
NFPA 70, National Electric Code	Guidelines on safe selection and design, installation, maintenance, and construction of electrical systems
NFPA 70B, Recommended Practice for Electrical Equipment Maintenance	Guidelines on electrical equipment maintenance
NFPA 70E, Standard for Electrical Safety Requirements for Employee Workplaces	Employee safety requirements for working with electrical equipment
NFPA 71, Standard for the Installation, Maintenance, and Use of Central Station Signaling Systems	Requirements for installation, maintenance, and use of central station signaling systems

TABLE 8.7-4  
Applicable National Consensus Standards

Law, Ordinance, Regulation, or Standard	Applicability
NFPA 72A, Standard for the Installation, Maintenance and Use of Local Protective Signaling Systems for Guard's Tour, Fire Alarm and Supervisory Service	Requirements for installation, maintenance, and use of local protective signaling systems
NFPA 72E, Standard on Automatic Fire Detection	Requirements for automatic fire detection
NFPA 72F, Standard for the Installation, Maintenance and Use of Emergency Voice/Alarm of Communication Systems	Requirements for installation, maintenance, and use of emergency and alarm communications systems
NFPA 72H, Guide for Testing Procedures for Local, Auxiliary, Remote Station and Proprietary Protective Signaling Systems	Testing procedures for types of signaling systems anticipated for facility
NFPA 75, Standard for the Protection of Electronic Computer/Data Processing Equipment	Requirements for fire protection systems used to protect computer systems
NFPA 78, Lightning Protection Code	Lightning protection requirements
NFPA 80, Standard for Fire Doors and Windows	Requirements for fire doors and windows
NFPA 90A, Standard for the Installation of Air Conditioning and Ventilating Systems	Requirements for installation of air conditioning and ventilating systems
NFPA 101, Code for Safety to Life from Fire in Buildings and Structures	Requirements for design of means of exiting the facility
NFPA 291, Recommended Practice for Fire Flow Testing and Marking of Hydrants	Guidelines for testing and marking of fire hydrants
NFPA 850, Recommended Practice for Fire Protection for Fossil Fuel Steam Electric Generating Plants	Requirements for fire protection in fossil-fuel steam electric generating plants
NFPA 1961, Standard for Fire Hose	Specifications for fire hoses
NFPA 1962, Standard for the Care, Maintenance, and Use of Fire Hose Including Connections and Nozzles	Requirements for care, maintenance, and use of fire hose
NFPA 1963, Standard for Screw Threads and Gaskets for Fire Hose Connections	Specifications for fire hose connections
American National Standards Institute/American Society for Mechanical Engineers (ANSI/ASME), Boiler and Pressure Vessel Code	Specifications and requirements for pressure vessels
ANSI, B31.2, Fuel Gas Piping	Specifications and requirements for fuel gas piping

### 8.7.3 Setting

The Eastshore Energy Center (Eastshore) will be a nominal 115.5-megawatt (MW) intermediate/peaking load facility using natural gas-fired reciprocating engine technology. The Eastshore facility will be located at 25101 Clawiter Road in the city of Hayward, Alameda County, California, on a 6.22 acre parcel owned by Eastshore Energy, LLC, the project owner. Major features of the Eastshore project include the following:

- Demolition of the existing site building, foundations and paved surface,
- Grading of site and installation of new foundations, piping and utility connections
- Fourteen (14) nominal 8.4 MW (gross) Wartsila model 20V34SG natural gas-fired reciprocating engine – generator sets,
- Fourteen (14) state-of-the-art air pollution control systems representing Best Available Control Technology (BACT), one system per each of the 14 engines, consisting of a selective catalytic reduction (SCR) unit for oxides of nitrogen (NO<sub>x</sub>) control and an oxidation catalyst unit for carbon monoxide (CO) and precursor organic compounds (POC) control,
- Fourteen (14) approximately 70-foot tall, 48-inch diameter stacks, each with a separate exhaust silencer and continuous emissions monitoring system (CEMS),
- Acoustically-engineered main building enclosing all 14 engines, with stacks located outside the building,
- Closed loop cooling system consisting of multiple fan-cooled radiator assemblies outside of the main engine building,
- Two 10,000 gallon (each) aqueous ammonia storage tanks and handling system serving the SCR units,
- One raw water storage tank, approximately 35,000 gallons;
- Miscellaneous ancillary equipment,
- Onsite water and wastewater service interconnections,
- Onsite 115 kV switchyard including switchgear and step-up voltage transformers,
- Approximately 1-mile 115 kV single-circuit transmission line interconnecting to PG&E's Eastshore Substation,
- Approximately 200-foot offsite natural gas line connection to PG&E Line 153,
- Chain-link security fencing enclosing the facility with a secured entrance on Clawiter Road, and
- 4.65-acre temporary construction laydown and parking area located immediately across Clawiter Road from the Eastshore site on property owned by Berkeley Farms.

## 8.7.4 Impacts

### 8.7.4.1 Environmental Checklist

Impacts would generally be evaluated with respect to the California Environmental Quality Act (CEQA) checklist. The CEQA checklist does not have specific questions for worker health and safety. Related questions are addressed in the Hazardous Materials Management and Noise checklists.

### 8.7.4.2 Discussion of Impacts

During this project, workers will be exposed to construction safety and plant operation safety hazards. To evaluate these hazards and control measures, a hazard analysis has been prepared. The analysis identifies the hazards anticipated during construction and operation and indicates which safety programs should be developed and implemented to mitigate and appropriately manage those hazards. The hazard analysis prepared for construction activities is outlined in Table 8.7-5; the hazard analysis prepared for plant operation is outlined in Table 8.7-6. Since the types of hazards anticipated during plant construction and operation are similar, there is considerable duplication between the tables.

**8.7.4.2.1 Overview of Hazards and Related Programs and Training.** Programs are overall plans that set forth the method or methods that will be followed to achieve particular health and safety objectives. For example, the Fire Protection and Prevention Program will describe what has to be done to protect against and prevent fires. This will include equipment required, such as alarm systems and firefighting equipment, and procedures to follow to protect against fires. The Emergency Action Program/Plan will describe escape procedures, rescue and medical procedures, alarm and communication systems, and response procedures for very hazardous materials that can migrate, such as ammonia. The programs or plans are contained in written documents that are usually kept at specific locations within the facility.

Each program or plan will contain training requirements that are translated into detailed training courses. These courses are taught to plant construction and operating personnel, as needed. For example, all plant operating personnel will receive training in escape procedures under the Emergency Action Program/Plan, but only those working with flammables will receive training under the Fire Protection and Prevention Program.

Tables 8.7-5 and 8.7-6, which list construction and operation activities and associated hazards, also show (under the "Control" column) the program designed to reduce the occurrence of each hazard.

TABLE 8.7-5  
Construction Hazard Analysis

Activity	Hazard*	Control*
Motor vehicle and heavy equipment use	Employee injury and property damage from collisions between people and equipment	Motor Vehicle and Heavy Equipment Safety Program
Forklift operation	Same as heavy equipment	Forklift Operation Program
Trenching and excavation	Employee injury and property damage from the collapse of trenches and excavations	Excavation/Trenching Program
Working at elevated locations	Falls from the same level and elevated areas	Fall Prevention Program Scaffolding/Ladder Safety Program Articulating Boom Platforms Program
Use of cranes and derricks	Property damage from falling loads; employee injuries from falling loads; and injuries and property damage from contact with crane or derrick	Crane and Material Handling Program

TABLE 8.7-5  
Construction Hazard Analysis

Activity	Hazard*	Control*
Working with flammable and combustible liquids	Fire/spills	Fire Protection and Prevention Program; Housekeeping and Material Handling and Storage Program
Hot work (including cutting and welding)	Employee injury and property damage from fire; exposure to fumes during cutting and welding; ocular exposure to ultraviolet and infrared radiation during cutting and welding	Hot Work Safety Program; Respiratory Protection Program; Employee Exposure Monitoring Program; Personal Protective Equipment Program
Inspection and maintenance of temporary systems used during construction activities	Employee injury and property damage from contact with hazardous energy sources (electrical, thermal, mechanical, etc.)	Electrical Safety Program
Working on electrical equipment and systems	Employee contact with live electricity and energized equipment	Electrical Safety Program; Personal Protective Equipment Program
Exposure to hazardous waste	Personnel who are working with or have the potential to be exposed to contaminated soil, groundwater, or debris during construction	Hazardous Waste Program
Confined space entry	Employee injury from physical and chemical hazards	Permit-Required Confined-Space Entry Program
General construction activity	Employee injury from hand and portable power tools	Hand and Portable Power Tool Safety Program; Personal Protective Equipment Program
General construction activity	Employee injury/property damage from inadequate walking and work surfaces	Housekeeping and Material Handling and Storage Program
General construction activity	Employee exposure to occupational noise	Hearing Conservation Program Personal Protective Equipment Program
General construction activity	Employee injury from improper lifting and carrying of materials and equipment	Back Injury Prevention Program
General construction activity	Employee injury to head, eye/face, hand, body, foot, and skin	Personal Protective Equipment Program
General construction activity	Employee exposure to hazardous gases, vapors, dusts, liquids, and fumes	Hazard Communication Program; Respiratory Protection Program; Personal Protective Equipment Program; Air Monitoring Program
General construction activity	Employee exposure to various hazards; reporting of hazardous conditions during construction	Injury and Illness Prevention Program
General construction activity	Heat and cold stress	Heat and Cold Stress Monitoring and Control Program

TABLE 8.7-5  
Construction Hazard Analysis

Activity	Hazard*	Control*
Construction and testing of high-pressure steam and air systems	Employee injury and property damage due to failure of pressurized system components or unexpected release of pressure	Pressure Vessel and Pipeline Safety Program; Electrical Safety Program

\* The hazards and hazard controls provided are generic to construction activities. During various phases of construction, a hazard analysis will be performed to evaluate the hazards and develop appropriate controls.

TABLE 8.7-6  
Operation Hazard Analysis

Activity	Hazard*	Control*
Motor vehicle and heavy equipment use	Employee injury and property damage from collisions between people and equipment	Motor Vehicle and Heavy Equipment Safety Program
Forklift operations	Same as heavy equipment	Forklift Operation Program
Trenching and excavation	Employee injury and property damage from the collapse of trenches and excavations	Excavation/Trenching Program
Working at elevated locations	Falls from the same level and elevated areas	Fall Protection Program; Scaffolding/Ladder Safety Program
Use of cranes or derricks	Property damage from falling loads, employee injuries from falling loads, injuries and property damage from contact with crane or derrick	Crane and Material Handling Program
Working with flammable and combustible liquids	Fire/spills	Fire Protection and Prevention Program
Working with hazardous materials	Employee injury due to ingestion, inhalation, dermal contact	Hazard Communication Program
Hot work (including cutting and welding)	Employee injury and property damage from fire; exposure to fumes during cutting and welding; ocular exposure to ultraviolet and infrared radiation during cutting and welding	Hot Work Safety Program; Respiratory Protection Program; Employee Exposure Monitoring Program; Personal Protective Equipment Program; Fire Protection and Prevention Program
Troubleshooting and maintenance of plant systems and general operational activities	Employee injury and property damage from contact with hazardous energy sources (electrical, thermal, mechanical, etc.)	Electrical Safety Program
Working on electrical equipment and systems	Employee contact with live electricity	Electrical Safety Program; Personal Protective Equipment Program
Confined space entry	Employee injury from physical and chemical hazards	Permit-Required Confined-Space Entry Program

TABLE 8.7-6  
Operation Hazard Analysis

Activity	Hazard*	Control*
General plant operation activities	Employee injuries from hand and portable power tools	Hand and Portable Power Tool Safety Program; Personal Protective Equipment Program
General plant operation activities	Employee injury and property damage from inadequate walking and work surfaces	Housekeeping and Material Handling and Storage Program
General plant operation activities	Employee overexposure to occupational noise	Hearing Conservation Program; Personal Protective Equipment Program
General plant operation activities	Employee injury from improper lifting and carrying of materials and equipment	Back Injury Prevention Program
General plant operation activities	Employee injury and property damage from unsafe driving	Safe Driving Program
General plant operation activities	Employee overexposure to hazardous gases, vapors, dusts, liquids, and fumes	Hazard Communication Program; Respiratory Protection Program; Personal Protective Equipment Program; Employee Exposure Monitoring Program
General plant operation activities	Reporting and repair of hazardous conditions	Injury and Illness Prevention Program
General plant operation activities	Heat and cold stress	Heat and Cold Stress Monitoring and Control Program
General plant operation activities	Ergonomic injuries	Ergonomic Awareness Program
Maintenance and repair of high-pressure steam and air systems	Employee injury and property damage due to failure of pressurized system components or unexpected release of pressure	Pressure Vessel and Pipeline Safety Program; Electrical Safety Program
Ammonia storage	Ammonia release	Emergency Action Program/Plan; Risk Management Plan (see Section 8.12)

\* The hazard and hazard controls provided are generic to operational activities. This hazard analysis may have to be updated if plant operations change or new equipment is added that was not considered during this evaluation.

### 8.7.4.3 Health and Safety Programs

To protect the safety and health of workers during the construction and operation of the Eastshore facility, health and safety programs designed to mitigate hazards and comply with applicable regulations will be implemented. Periodic audits will be performed by qualified individuals to determine whether proper work practices are being used to mitigate hazardous conditions and to evaluate regulatory compliance.

The following subsections contain information on the anticipated content of the health and safety programs.

**8.7.4.3.1 Construction Health and Safety Program.** The following construction safety programs will be developed and implemented during construction of the Eastshore facility, as outlined in the following lists.

***Injury and Illness Prevention Program***

- Philosophy and safety commitment
- Safety leadership and responsibilities
- Accountability
- Specific core safety processes (see Construction Safety Programs later in this section)
- Employee communication
- Planning “job hazard analysis and pre-task”
- Compliance with work rules and safe work practices
- Measurement of compliance and effectiveness of prevention methods
- Communication of performance and implementation of necessary improvements
- Training and other communication requirements

***Fire Protection and Prevention Program***

- General requirements
- Housekeeping and proper material storage
- Employee alarm/communication system
- Portable fire extinguishers
- Fixed firefighting equipment
- Fire control and containment
- Flammable and combustible liquid storage
- Use of flammable and combustible liquids
- Dispensing and disposal of flammable liquids
- Service and refueling areas
- Training

***Personal Protective Equipment Program***

- Personal protective devices
- Head protection
- Eye/face protection
- Body protection
- Hand protection
- Foot protection
- Skin protection
- Fall protection
- High-voltage protection
- Respiratory protection
- Hearing protection
- Hazard analysis
- Training

***Emergency Action Program/Plan***

Emergency procedures for the protection of personnel, equipment, the environment, and materials:

- Fire and emergency reporting procedures
- Response actions for accidents involving personnel and or property
- Bomb threats
- Site assembly and emergency evacuation route procedures
- Natural disasters response

Reporting and notification procedures for emergencies; contacts, including offsite and local authorities:

- Alarm and communication systems
- Spill response, prevention, and control action plan
- Emergency response equipment
- Emergency personnel (response team) responsibilities and notification roster
- Training requirements

### *Construction Safety Programs*

#### **Motor Vehicle and Heavy Equipment Safety Program**

- Operation and maintenance of vehicles
- Inspection
- PPE
- Training

#### **Forklift Operation Program**

- Trained and certified operators
- Fueling operations
- Safe operating parameters
- Training

#### **Excavation/Trenching Program**

- Shoring, sloping, and benching requirements
- California Occupational Safety and Health Administration (Cal-OSHA) permit requirements
- Inspection
- Air monitoring
- Access and egress

#### **Fall Protection Program**

- Evaluation of fall hazards
- Protection devices
- Training

#### **Scaffolding/Ladder Safety Program**

- Construction and inspection of equipment
- Proper use
- Training

#### **Articulating Boom Platforms Program**

- Inspection of equipment
- Load ratings
- Safe operating parameters

- Operator training

#### **Crane and Material Handling Program**

- Certified and licensed operators
- Inspection of equipment
- Load ratings
- Safe operating parameters
- Training

#### **Hazardous Waste Program**

- Evaluation of hazard
- Training
- Air monitoring
- Medical surveillance
- Health and Safety Plan (HSP) preparation

#### **Hot Work Safety Program**

- Welding and cutting procedures
- Fire watch
- Hot work permit
- PPE
- Training

#### **Employee Exposure Monitoring Program**

- Exposure evaluation
- Monitoring requirements
- Reporting of results
- Medical surveillance
- Training

#### **Electrical Safety Program**

- Grounding procedure
- Lock-out/tag-out (LO/TO) procedures
- Overhead and underground utilities
- Utility clearance
- Training

#### **Permit-Required Confined Space Entry Program**

- Air monitoring and ventilation requirements
- Rescue procedures
- LO/TO and blocking, blinding, and blanking requirements
- Permit completion
- Training

#### **Hand and Portable Power Tool Safety Program**

- Guarding and proper operation
- Training

**Housekeeping and Material Handling and Storage Program**

- Storage requirements
- Walkways and work surfaces
- Equipment handling requirements
- Training

**Hearing Conservation Program**

- Identifying high-noise environments
- Exposure monitoring
- Medical surveillance requirements
- Hearing-protective devices
- Training

**Back Injury Prevention Program**

- Proper lifting and material handling procedures
- Training

**Hazard Communication Program**

- Labeling requirements
- Storage and handling
- Material Safety Data Sheets (MSDS)
- Chemical inventory
- Training

**Respiratory Protection Program**

- Selection and use
- Storage
- Fit testing
- Medical requirements
- Inspection and repair
- Training

**Heat and Cold Stress Monitoring and Control Program**

- Monitoring requirements
- Prevention and control

**Pressure Vessel and Pipeline Safety Program**

- Line-breaking program
- Equipment inspection and maintenance
- Blocking, bleeding, and blanking
- Training

**8.7.4.3.2 Operations Health and Safety Program.** Upon completion of construction and commencement of operations at Eastshore facility, the construction safety and health program will transition into an operations-oriented program reflecting the hazards and controls necessary during operation. The following text outlines the topics that will be included in the Operations Health and Safety Program.

***Injury and Illness Prevention Program***

- Personnel with the responsibility and authority for implementing the plan

- Safety and health policy
- Work rules and safe work practices
- System for ensuring that employees comply with safe work practices
- Employee communications
- Identification and evaluation of workplace hazards

Methods and/or procedures for correcting unsafe or unhealthy conditions, work practices, and work procedures in a timely manner based on the severity of the hazards

- Specific safety procedures (See Plant Operation Safety Program)
- Training and instruction

#### ***Fire Protection and Prevention Program***

- General requirements
- Fire hazard inventory, including ignition sources and mitigation
- Housekeeping and proper materials storage
- Employee alarm/communication system
- Portable fire extinguishers
- Fixed firefighting equipment
- Fire control
- Flammable and combustible liquid storage
- Use of flammable and combustible liquids
- Dispensing and disposal of liquids
- Training
- Personnel to contact for information on plan contents

#### ***Emergency Action Program/Plan (Part of the Risk Management Plan)***

- Emergency escape procedures and emergency escape route assignments
- Procedures to be followed by employees who remain to operate critical plant operations before they evacuate
- Procedures to account for all employees after emergency evacuation has been completed
- Rescue and medical duties for those employees performing rescue and medical duties
- Fire and emergency reporting procedures
- Alarm and communication system
- Personnel to contact for information on plan contents
- Response procedure for ammonia release
- Training requirements

#### ***Personal Protective Equipment Program***

- Hazard analysis and prescription of PPE
- Personal protective devices
- Head protection
- Eye and face protection
- Body protection
- Hand protection
- Foot protection
- Skin protection
- Sanitation
- Safety belts and life lines for fall protection

- Protection for electric shock
- Medical services and first aid/bloodborne pathogens
- Respiratory protective equipment
- Hearing protection
- Training

#### *Plant Operation Safety Program*

#### **Motor Vehicle and Heavy Equipment Safety Program**

- Operation and maintenance of vehicles
- Inspection
- Personal Protective Equipment
- Training

#### **Forklift Operation Program**

- Trained and certified operators
- Fueling operations
- Safe operating parameters
- Training

#### **Excavation/Trenching Program**

- Shoring, sloping, and benching requirements
- Cal-OSHA permit requirements
- Inspection
- Air monitoring
- Access and egress

#### **Fall Protection Program**

- Evaluation of fall hazards
- Protection devices
- Training

#### **Scaffolding/Ladder Safety Program**

- Construction and inspection of equipment
- Proper use
- Training

#### **Articulating Boom Platforms Program**

- Inspection of equipment
- Load ratings
- Safe operating parameters
- Operator training

#### **Crane and Material Handling Program**

- Certified and licensed operators
- Inspection of equipment
- Load ratings
- Safe operating parameters
- Training

### **Hot Work Safety Program**

- Welding and cutting procedures
- Fire watch
- Hot work permit
- Personal Protective Equipment
- Training

### **Workplace Ergonomics Program**

- Identification of personnel at risk
- Evaluation of personnel
- Workplace and job activity modifications
- Training

### **Employee Exposure Monitoring Program**

- Exposure evaluation
- Monitoring requirements
- Reporting of results
- Medical surveillance
- Training

### **Electrical Safety Program**

- Grounding procedure
- LO/TO procedures
- Overhead and underground utilities
- Utility clearance
- Training

### **Permit-Required Confined Space Entry Program**

- Air monitoring and ventilation requirements
- Rescue procedures
- LO/TO and blocking, blinding, and blanking requirements
- Permit completion
- Training

### **Hand and Portable Power Tool Safety Program**

- Guarding and proper operation
- Training

### **Housekeeping and Material Handling and Storage Program**

- Storage requirements
- Walkways and work surfaces
- Equipment handling requirements
- Training

### **Hearing Conservation Program**

- Identifying high-noise environments
- Exposure monitoring
- Medical surveillance requirements
- Hearing protective devices

- Training

**Back Injury Prevention Program**

- Proper lifting and material handling procedures
- Training

**Hazard Communication Program**

- Labeling requirements
- Storage and handling
- MSDS
- Chemical inventory
- Training

**Respiratory Protection Program**

- Selection and use
- Storage
- Fit testing
- Medical requirements
- Inspection and repair
- Training

**Heat and Cold Stress Monitoring and Control Program**

- Monitoring requirements
- Prevention and control

**Pressure Vessel and Pipeline Safety Program**

- Line-breaking policy
- Equipment inspection and maintenance
- Blocking, bleeding, and blanking
- Communication
- Training

**Safe Driving Program**

- Inspection and maintenance
- Training

**8.7.4.4 Safety Training Programs**

To ensure that employees recognize and understand how to protect themselves from potential hazards during this project, comprehensive training programs for construction and operation will be implemented as indicated in Tables 8.7-7 and 8.7-8. Each of the safety procedures developed to control and mitigate potential site hazards will require some form of training. Training will be delivered in various ways, depending on the requirements of Cal-OSHA standards, the complexity of the topic, the characteristics of the workforce, and the degree of risk associated with each of the identified hazards.

Tables 8.7-7 and 8.7-8 summarize the safety training programs that will be provided to construction and operations personnel, respectively.

**TABLE 8.7-7**  
**Construction Training Program**

<b>Training Course</b>	<b>Target Employees</b>
Injury and Illness Prevention Training	All
Emergency Action Program/Plan	All
Personal Protective Equipment Training	All
Motor Vehicle and Heavy Equipment Safety Training	Employees working on, near, or with heavy equipment or vehicles
Forklift Operation Training	Employees operating forklifts
Excavation/Trenching Safety Training	Employees involved with trenching or excavation
Fall Protection Training	Employees working at heights greater than 6 feet or required to use fall protection
Scaffolding/Ladder Safety Training	Employees required to erect or use scaffolding
Crane Safety Training	Employees supervising or performing crane operations
Fire Protection and Prevention Training	Employees responsible for the handling and storage of flammable or combustible liquids or gases
Hazard Communication Training	Employees handling or working with hazardous materials
Hazardous Waste	Employees handling or excavating hazardous waste
Hot Work Safety Training	Employees performing hot work
Fire Prevention and Protection Training	
Electrical Safety Training	Employees performing LO/TO or working on systems that require LO/TO activities
Electrical Safety Training	Employees required to work on electrical systems and equipment, or use electrical equipment and cords
Permit-Required Confined-Space Entry Training	Employees required to supervise or perform confined-space entry activities
Hand and Portable Power Tool Safety Training	Employees that will be operating hand and portable power tools
Heat Stress and Cold Stress Safety Training	Employees that are exposed to temperature extremes
Hearing Conservation Training	All
Back Injury Prevention Training	All
Safe Driving Training	Employees supervising or driving motor vehicles
Pressure Vessel and Pipeline Safety Training	Employees supervising or working on pressurized systems or equipment
Respiratory Protection Training	All employees required to wear respiratory protection
Fire Protection and Prevention Training	All

TABLE 8.7-8  
Operations Training Program

Training Course	Target Employees
Injury and Illness Prevention Training	All
Emergency Action Plan	All
Personal Protective Equipment Training	All
Excavation/Trenching Safety Training	Employees involved with trenching or excavation
Scaffolding/Ladder Safety Training	Employees required to erect or use scaffolding
Fall Protection Training	Employees required to use fall protection
Forklift Operator Training	Employees operating forklifts
Crane Safety Training	Employees supervising or performing crane operations
Workplace Ergonomics	Employees performing repetitive activities
Fire Protection and Prevention Training	Employees responsible for the handling and storage of flammable or combustible liquids or gasses
Hot Work Safety Training	Employees performing hot work
Electrical Safety Training	Employees performing LO/TO
Electrical Safety	Employees required to work on electrical systems and equipment
Permit-required Confined-space Entry	Employees required to supervise or perform confined-space entry
Hand and Portable Power Tool Safety Training	Employees that will be operating hand and portable power tools
Heat Stress and Cold Stress Safety Training	Employees exposed to temperature extremes
Hearing Conservation Training	All
Back Injury Prevention Training	All
Safe Driving Training	Employees supervising or driving motor vehicles
Hazard Communication Training	Employees handling or working around hazardous materials
Pressure Vessel and Pipeline Safety Training	Employees supervising or working on pressurized systems or equipment
Respiratory Protection Program	All employees required to wear respiratory protection
Fire Protection and Prevention Training	All

#### 8.7.4.5 Fire Protection

There are nine fire stations in the City of Hayward. The station nearest the project site is Fire Station #6, located at 1401 West Winton Ave., approximately 1 mile from the project site and provides first response for fire, hazardous materials incidents, and paramedic services. The station has an anticipated response time of 3 to 4 minutes (Burke, 2006).

## 8.7.5 Involved Agencies and Agency Contacts

Several agencies are involved to ensure protection of worker health and safety. Agency contacts relative to worker health and safety and fire are shown in Table 8.7-9.

TABLE 8.7-9  
Agency Contacts

Agency	Contact Name	Address and Telephone
Cal-OSHA District Office Consultation Service	Jay Sekhon Area Manager	1515 Clay St., Suite 1103 Oakland, CA 94612 510.622.2891
Pressure Vessel Unit District Office, Division of Occupational Safety and Health	John Sergeant Sr. Pressure Vessel Engineer	Elihu Harris State Building 1515 Clay Street, Suite 901 Oakland, CA 94612 510.622-3071 510.622.3063 (fax)
City of Hayward Fire Department.	Larry Arfsten Fire Chief	777 B Street Hayward, CA 94541 510.583.4945
Alameda County Environmental Health	Arnold Perkins Public Health Department Director	Alameda County Public Health Department 1000 Broadway Suite 500 Oakland, CA 94607 Phone: 510 267.8000 Fax: 510 267-3212

## 8.7.6 Permits Required and Permit Schedule

Table 8.7-10 lists applicable permits related to the protection of worker health and safety for Eastshore certification. The activities covered and application requirements to obtain each permit are provided.

All permits noted in Table 8.7-10 may be obtained from any Cal-OSHA district or field office as needed. Notification requirements are listed as 24 hours because the permits may be required at several points in the construction of the plant or during operations; no specific permitting schedule is provided.

TABLE 8.7-10  
Health and Safety Permits

Permit or Approval	Schedule	Applicability	Contact
Trenching and excavation permit	Submit completed permit application to any Cal-OSHA district or field office prior to commencing construction	Trenches and excavations of more than 5 feet that personnel are required to enter, or Construction of buildings, structures, scaffolding, or falsework more than 3 stories high, or Demolition of any building or structure or dismantling of scaffolding or falsework more than 3 stories high	Any Cal-OSHA district or field office
Construction Demolition	Submit completed permit application to any Cal-OSHA district or field office prior to commencing construction	Construction of demolition of buildings, structures 3 feet or higher	Any Cal-OSHA district or field office

TABLE 8.7-10  
Health and Safety Permits

Permit or Approval	Schedule	Applicability	Contact
Scaffolding	Submit completed permit application to any Cal-OSHA district or field office prior to commencing construction	Scaffolding 36 feet or higher, erection or dismantling	Any Cal-OSHA district or field office
Permit to erect a fixed tower crane	Submit completed permit application to any Cal-OSHA district or field office at least 24 hours prior to initiation of activity	Required to erect, climb, or dismantle fixed tower cranes Completion of erection of tower crane and commencement of operation, or Climbing of the tower crane, or Dismantling of the tower crane	Any Cal-OSHA district or field office
Pressure vessel, unfired or fired	Submit completed permit application to Cal-OSHA Pressure Vessel Unit	Pressure vessels covered by the Unfired and Fired Pressure Vessel Safety Orders require a permit to operate.	Cal-OSHA pressure vessel unit

### 8.7.7 References

Burke, J. 2006. Comments from John Burke, Fire Chief, City of Hayward. July 13.