Exhibit 6-1: Tables 6.2-13 through 6.2-15

Table 6.2-13 – Summary of Maximum Hourly Operational Emissions (Rev. 8/21/08)

POLLUTANT	NOx	CO	VOC	$PM_{10/2.5}$	SOx
Turbines (lb/hr)	30.73	30.28	5.25	6.14	1.77
Black-Start Engine (lb/hr)	1.39	1.85	0.31	0.04	0.008
Fire-Pump Engine (lb/hr)	1.58	0.31	0.0003	0.04	0.001
Chiller Cooling Tower (lb/hr)	-	-	-	0.2	-
Water Trucks (lb/hr)	0.64	0.14	0.03	0.07	0.002
Maximum Facility Hourly (lb/hr)	**35.7**	**33.05**	**5.60**	**6.49**	**1.78**

Table 6.2-14 – Summary of Maximum Daily Operational Emissions (Rev. 8/21/08)

POLLUTANT	NOx	CO	VOC	$PM_{10/2.5}$	SOx
Turbines (lb/day)	282.5	365.3	70.86	132.8	47.2
Black-Start Engine (lb/day)	1.39	1.85	0.31	0.04	0.008
Fire-Pump Engine (lb/day)	1.58	0.31	0.0003	0.04	0.001
Chiller Cooling Tower (lb/day)	-	-	-	4.69	-
Water Trucks (lb/day)	15.30	3.31	0.76	1.75	0.05
Maximum Facility Daily (lb/day)	**333.71**	**382.26**	**71.93**	**139.3**	**47.26**

Table 6.2-15 – Summary of Annual Operational Emissions (Rev 8/21/08)

POLLUTANT	NOx	CO	VOC	$PM_{10/2.5}$	SOx
Turbines: Maximum (lb/yr)	35,413	45,630	8,905	17,550	6,336
Turbines: Expected (lb/yr)	11,448	14,725	2,862	5,508	1,974
Black-Start Engine (lb/yr)	19.39	25.9	4.27	0.56	0.12
Fire-Pump Engine (lb/yr)	81.94	15.92	0.01	1.94	0.05
Chiller Cooling Tower (lb/yr)	-	-	-	625	-
Water Trucks Maximum (lb/yr)	2,040	441	101	233	6.32
Water Trucks Expected (lb/yr)	638	138	31	73	1.97
Maximum Facility Annual (lb/yr)	41,942	47,641	9,010	18,411	6,342
Maximum Facility Annual (tpy)	**20.97**	**23.82**	**4.51**	**9.21**	**3.17**
Average Facility Annual (tpy)	**6.77**	**7.86**	**1.45**	**3.10**	**0.99**

Exhibit 6-2: Tables 6.2-19 through 6.2-20

Table 6.2-19 - PSD Trigger Levels
(Revised 8/21/08)

AIR CONTAMINANT	PSD TRIGGER LEVELS (TON/YR)	PROJECT (TON/YR)
Particulate Matter (PM_{10})	250	9.24
Oxides of Nitrogen (NO_X)	250	20.97
Volatile Organic Compounds (VOC)	250	4.85
Oxides of Sulfur (SO_X)	250	3.17
Carbon Monoxide (CO)	250	23.82

Table 6.2-20 - Major Stationary Source Thresholds
(Revised 8/21/08)

AIR CONTAMINANT	THRESHOLDS (TON/YR)	PROJECT (TON/YR)
Particulate Matter (PM_{10})	100	9.24
Oxides of Nitrogen (NO_X)	50	20.97
Volatile Organic Compounds (VOC)	50	4.85
Oxides of Sulfur (SO_X)	100	3.17
Carbon Monoxide (CO)	100	23.82
Lead (Pb)	100	0

Exhibit 6-3: Table 6.2C-12

Table 6.2C-12 - Turbine Emission Estimates During Operational Phase

Turbine Emissions Factors (100% Load)

Base Load Emissions Per Turbine			NOx	CO	VOC	PM10	SO_2
Steady State Uncontrolled (lb/hr)			43.00	18.37	1.25	2.70	1.00
Steady State Controlled (lb/hr)			4.30	6.12	1.25	2.70	1.00
Start/Stop Emissions Per Turbine		Minutes	NOx	CO	VOC	PM10	SO_2
Startup Emissions (lb/event)		10	3.00	5.60	1.10	0.67	0.14
Warm-up Emissions (lb/event)		30	10.93	7.50	1.11	1.50	0.41
Shutdown Emissions (lb/event)		8	2.20	3.70	0.60	0.53	0.11
Startup Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Startup		0.167	3.00	5.60	1.10	0.67	0.14
Warm-up		0.500	10.93	7.50	1.11	1.50	0.41
Steady State Controlled		0.333	1.43	2.04	0.42	0.90	0.33
Total Hourly Emission / Turbine		1.000	15.36	15.14	2.63	3.07	0.88
Shutdown Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Steady State Controlled		0.867	3.73	5.31	1.08	2.34	0.87
Shutdown		0.133	2.20	3.70	0.60	0.53	0.11
Total Hourly Emission / Turbine		1.000	5.93	9.01	1.68	2.87	0.98

Facility Turbine Emissions (2 Turbines)

Maximum Hourly Emissions	T1	T2	Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	1	1	0.333	6.00	11.20	2.20	1.34	0.28
Warm-up Event	1	1	1.000	21.86	15.00	2.22	3.00	0.82
Steady State	1	1	0.667	2.87	4.08	0.83	1.80	0.67
Total Maximum Hourly (lb/hr)			**2.00**	**30.73**	**30.28**	**5.25**	**6.14**	**1.77**
Maximum Eight Hours Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	11.20	48.16	68.58	14.00	30.24	11.21
Total Maximum Eight Hours (lb)			**16.00**	**144.94**	**169.38**	**30.86**	**46.44**	**15.17**
Maximum Daily Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	43.20	185.76	264.53	54.00	116.64	43.24
Total Maximum Daily (lb/day)			**48.00**	**282.54**	**365.33**	**70.86**	**132.84**	**47.20**
Maximum Annual Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	250	250	83.33	1,500	2,800	550	335	70
Warm-up Event	250	250	250.00	5,465	3,750	555	750	205
Shutdown Event	250	250	66.67	1,100	1,850	300	265	55
Steady State Uncontrolled	20	20	40	1,720	735	50	108	40
Steady State Controlled	2980	2980	5,960	25,628	36,495	7,450	16,092	5,966
Total Maximium Annual Daily (lb/yr)			**6,400**	**35,413**	**45,630**	**8,905**	**17,550**	**6,336**
			Tons	**17.71**	**22.81**	**4.45**	**8.78**	**3.17**
Annual Average Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	100	100	33.33	600	1,120	220	134	28
Warm-up Event	100	100	100.00	2,186	1,500	222	300	82
Shutdown Event	100	100	26.67	440	740	120	106	22
Steady State Uncontrolled	4	4	8	344	147	10	22	8
Steady State Controlled	916	916	1,832	7,878	11,218	2,290	4,946	1,834
Total Maximium Annual Daily (lb/yr)			**2,000**	**11,448**	**14,725**	**2,862**	**5,508**	**1,974**
			Tons	**5.72**	**7.36**	**1.43**	**2.75**	**0.99**

Notes:
1. Uncontrolled emission data based on updated GE performance data provided 9/26/2007
2. Controlled emissions are based on targetted BACT thresholds of 2.5 ppm NOx, 6 ppm CO.
3. Oxidation catalyst presumed to have the same oxidation potential for CO and VOC.
4. Calculations are based on annual average ambient temperature of 70.5 °F
5. Maximum one hour emissions based on simultaneous startup of both turbines
6. Startup events are 10 minutes (0.167 hour) each
7. Warm-up events are 30 minutes (0.500 hour) each
8. Shutdown events are 8 minutes (0.130 hour) each
9. Startup and shutdown emissions are based on GE data at ISO conditions
10. Warm-up emissions are based on linear emission reduction ramp

Turbine Emissions Factors (75% Load)

Base Load Emissions Per Turbine			NOx	CO	VOC	PM10	SO_2
Steady State Uncontrolled (lb/hr)			34.00	12.96	0.99	2.32	0.80
Steady State Controlled (lb/hr)			3.40	4.32	0.99	2.32	0.80
Start/Stop Emissions Per Turbine		Minutes	NOx	CO	VOC	PM10	SO_2
Startup Emissions (lb/event)		10	3.00	5.60	1.10	0.67	0.14
Warm-up Emissions (lb/event)		30	10.93	7.50	1.11	1.50	0.41
Shutdown Emissions (lb/event)		8	2.20	3.70	0.60	0.53	0.11
Startup Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Startup		0.167	3.00	5.60	1.10	0.67	0.14
Warm-up		0.500	10.93	7.50	1.11	1.50	0.41
Steady State Controlled		0.333	1.13	1.44	0.33	0.77	0.27
Total Hourly Emission / Turbine		1.000	15.06	14.54	2.54	2.94	0.82
Shutdown Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Steady State Controlled		0.867	2.95	3.74	0.86	2.01	0.69
Shutdown		0.133	2.20	3.70	0.60	0.53	0.11
Total Hourly Emission / Turbine		1.000	5.15	7.44	1.46	2.54	0.80

Facility Turbine Emissions (2 Turbines)

Maximum Hourly Emissions	T1	T2	Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	1	1	0.333	6.00	11.20	2.20	1.34	0.28
Warm-up Event	1	1	1.000	21.86	15.00	2.22	3.00	0.82
Steady State	1	1	0.667	2.27	2.88	0.66	1.55	0.53
Total Maximum Hourly (lb/hr)			**2.00**	**30.13**	**29.08**	**5.08**	**5.89**	**1.63**
Maximum Eight Hours Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	11.20	38.08	48.38	11.09	26.02	8.91
Total Maximum Eight Hours (lb)			**16.00**	**134.86**	**149.18**	**27.95**	**42.22**	**12.87**
Maximum Daily Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	43.20	146.88	186.62	42.77	100.36	34.35
Total Maximum Daily (lb/day)			**48.00**	**243.66**	**287.42**	**59.63**	**116.56**	**38.31**
Maximum Annual Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	250	250	83.33	1,500	2,800	550	335	70
Warm-up Event	250	250	250.00	5,465	3,750	555	750	205
Shutdown Event	250	250	66.67	1,100	1,850	300	265	55
Steady State Uncontrolled	20	20	40	1,360	518	40	93	32
Steady State Controlled	2980	2980	5,960	20,264	25,747	5,900	13,846	4,739
Total Maximium Annual Daily (lb/yr)			**6,400**	**29,689**	**34,666**	**7,345**	**15,289**	**5,101**
			Tons	**14.84**	**17.33**	**3.67**	**7.64**	**2.55**

Notes:
1. VOC emission factor based on the higher of estimated emission and the guaranteed levels.
2. PM10 emissions for partial load is adjusted by exhaust flowrate.
3. SO2 emissions calculated using projected fuel consumption.

Turbine Emissions Factors (50% Load)

Base Load Emissions Per Turbine			NOx	CO	VOC	PM10	SO_2
Steady State Uncontrolled (lb/hr)			26.00	9.70	0.75	1.94	0.60
Steady State Controlled (lb/hr)			2.60	3.23	0.75	1.94	0.60
Start/Stop Emissions Per Turbine		Minutes	NOx	CO	VOC	PM10	SO_2
Startup Emissions (lb/event)		10	3.00	5.60	1.10	0.67	0.14
Warm-up Emissions (lb/event)		30	10.93	7.50	1.11	1.50	0.41
Shutdown Emissions (lb/event)		8	2.20	3.70	0.60	0.53	0.11
Startup Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Startup		0.167	3.00	5.60	1.10	0.67	0.14
Warm-up		0.500	10.93	7.50	1.11	1.50	0.41
Steady State Controlled		0.333	0.87	1.08	0.25	0.65	0.20
Total Hourly Emission / Turbine		1.000	14.80	14.18	2.46	2.82	0.75
Shutdown Emissions / Hour / Turbine		Hour	NOx	CO	VOC	PM10	SO_2
Steady State Controlled		0.867	2.25	2.80	0.65	1.68	0.52
Shutdown		0.133	2.20	3.70	0.60	0.53	0.11
Total Hourly Emission / Turbine		1.000	4.45	6.50	1.25	2.21	0.63

Facility Turbine Emissions (2 Turbines)

Maximum Hourly Emissions	T1	T2	Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	1	1	0.333	6.00	11.20	2.20	1.34	0.28
Warm-up Event	1	1	1.000	21.86	15.00	2.22	3.00	0.82
Steady State	1	1	0.667	1.73	2.16	0.50	1.29	0.40
Total Maximum Hourly (lb/hr)			**2.00**	**29.59**	**28.36**	**4.92**	**5.63**	**1.50**
Maximum Eight Hours Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	11.20	29.12	36.21	8.40	21.68	6.67
Total Maximum Eight Hours (lb)			**16.00**	**125.90**	**137.01**	**25.26**	**37.88**	**10.63**
Maximum Daily Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	3	3	1.00	18.00	33.60	6.60	4.02	0.84
Warm-up Event	3	3	3.00	65.58	45.00	6.66	9.00	2.46
Shutdown Event	3	3	0.80	13.20	22.20	3.60	3.18	0.66
Steady State Controlled	1	1	43.20	112.32	139.68	32.40	83.64	25.74
Total Maximum Daily (lb/day)			**48.00**	**209.10**	**240.48**	**49.26**	**99.84**	**29.70**
Maximum Annual Emissions			Hours	NOx	CO	VOC	PM10	SO_2
Startup Event	250	250	83.33	1,500	2,800	550	335	70
Warm-up Event	250	250	250.00	5,465	3,750	555	750	205
Shutdown Event	250	250	66.67	1,100	1,850	300	265	55
Steady State Uncontrolled	20	20	40	1,040	388	30	77	24
Steady State Controlled	2980	2980	5,960	15,496	19,271	4,470	11,539	3,551
Total Maximium Annual Daily (lb/yr)			**6,400**	**24,601**	**28,059**	**5,905**	**12,966**	**3,905**
			Tons	**12.30**	**14.03**	**2.95**	**6.48**	**1.95**