

**PALOMAR ENERGY PROJECT (01-AFC-24)  
CEC STAFF DATA REQUEST NUMBER 19**

**Technical Area: Air Quality**

**Response Date: April 8, 2002**

**REQUEST:**

Please verify that no diesel-powered generators or fire-water pump engine would be included with the Palomar Energy Project and that no auxiliary boiler would be included.

---

**RESPONSE:**

No diesel-powered generator, fire-water pump engine, or auxiliary boiler will be utilized at the Palomar Energy Project.

---