

**PALOMAR ENERGY PROJECT (01-AFC-24)
CEC STAFF DATA REQUEST NUMBER 112**

Technical Area: Visual Resources

Response Date: April 8, 2002

REQUEST:

Please identify the relative humidities, in percent, assumed for each of the ambient temperatures (20°F, 62°F and 110°F) given in Table 5.10-7 of the AFC Data Adequacy Supplement (pg. 5.10-29)

RESPONSE:

Average relative humidity values for the three ambient temperatures (20°F, 62°F, and 110°F) were not used. Rather, explicit measured values for each hour in the 3-year data set were input to the CSVP model on an hourly basis.
