

**PALOMAR ENERGY PROJECT (01-AFC-24)
CEC STAFF DATA REQUEST NUMBER 74**

Technical Area: Visual Resources

Response Date: April 8, 2002

REQUEST:

If the upgrade is necessary for the proposed project, please explain whether or not any aboveground facilities would be required for the gas pipeline including pump stations and/or valves. If so, please identify their locations and describe the facility characteristics including dimensions.

RESPONSE:

The gas pipeline upgrade will require no aboveground facilities.