

**PALOMAR ENERGY PROJECT (01-AFC-24)  
CEC STAFF DATA REQUEST NUMBER 88**

**Technical Area: Visual Resources**

**Response Date: April 8, 2002**

**REQUEST:**

Please specify the heights of the existing lattice towers.

---

**RESPONSE:**

The heights of the existing 138 kV tower structures are approximately 100 feet. The existing 230 kV towers are approximately 120 feet tall.

---