

**PALOMAR ENERGY PROJECT (01-AFC-24)
CEC STAFF DATA REQUEST NUMBER 90**

Technical Area: Visual Resources

Response Date: April 8, 2002

REQUEST:

Please specify the heights of the proposed tubular structures.

RESPONSE:

Although engineering studies to determine final tubular tower heights have not yet been completed by SDG&E, it currently is expected that the new 230 kV tubular poles will be approximately the same height as the existing 230 kV towers, which are approximately 120 feet tall. This is the same height used to depict the tubular towers in the visual simulations.
