

**PALOMAR ENERGY PROJECT (01-AFC-24)
CEC STAFF DATA REQUEST NUMBER 91**

Technical Area: Visual Resources

Response Date: April 8, 2002

REQUEST:

Please describe the rebuild scenario in detail including the following information: (a) number of poles, (b) pole construction material (wood or steel), (c) pole color (if other than wood), and (d) pole locations.

RESPONSE:

Palomar plans to underground the 69 kV lines rather than rebuilding aboveground poles.