

Bill Powers, P.E.  
Powers Engineering  
4452 Park Blvd., Suite 209  
San Diego, CA 92116  
(619) 295-2072

STATE OF CALIFORNIA  
State Energy Resources  
Conservation and Development Commission

In the matter of: )  
)  
)  
Palomar Energy, LLC )  
Application for Certification of )  
Palomar Energy Power Plant )  
)

DOCKET NO: **01-AFC-24**

DATA REQUEST  
of **Bill Powers, P.E.**  
SET **One two (RM)**

TO: **Stephen Baum, CEO of Sempra Energy, and his Attorney.**

**Bill Powers, P.E.** requests that you answer the following data request within **10** days. All the information sought is relevant to the proceeding and is in the control of the applicant and not readily available from other sources. In answering this data request, you are required to furnish full and complete answers.

- 1. Describe in detail the concentration (in maximum, average, and minimum ppm or mg/l) of total organic compounds (TOC) and volatile organic compounds (VOC) in the HARRF reclaimed water to be used by the Palomar Energy Project. A careful review of all of the pollutants listed in 22 CCR Table 64431-A of &6431, 40 CFR 131.36, and 22 CCR Table 64444-A of &64444 indicates that TOC and VOC are not included, only individual compounds. Accurate information on the VOC concentration will be necessary to calculate a comprehensive VOC emission rate for the Palomar Energy Project cooling towers. TOC data will be used to corroborate the VOC concentration data.***

**September 13, 2002**

Date

\_\_\_\_\_  
Signature

Check box if continuation pages are attached.