

CALIFORNIA ENERGY COMMISSION

16 NINTH STREET
SACRAMENTO, CA 95814-5512



January 31, 2002

Fred Salzmann
Project Manager
PASTORIA ENERGY FACILITY
P.O. Box 866
Lebec, CA 93243

Subject: Pastoria Energy Facility (99-AFC-7C)
Approval of Petition to Modify Transmission Towers

Dear Mr. Salzmann:

In accordance with the provisions of Title 20, California Code of Regulations, section 1769(a), California Energy Commission (Energy Commission) staff reviewed your petition dated November 28, 2001 requesting to increase the transmission tower height from 120 to 128 feet and to eliminate three transmission towers. Staff determined that the petition met the criteria of section 1769(a)(2), and mailed the enclosed "Notice of Insignificant Project Change" to the Energy Commission's post-certification project mailing list on January 16, 2002.

The Energy Commission did not receive any public comments regarding this requested project change within the 14-day public review period as specified in section 1769(a)(2). Therefore, your requested modification to the transmission towers is approved.

If you have any questions, please call me at (916) 654-3864, or e-mail me at ntronaas@energy.state.ca.us.

Sincerely,

Nancy Tronaas
Compliance Project Manager

Enclosure

cc: Raymond Rodriguez, PEF/Calpine
Greg Fenton, Kern County Engineering and Survey Services Department