The Pegasus Project Hazardous Air Pollutants Emissions And Health Risk Analysis for Turbine 3 (CTG3)

Natural Gas High Heat Value (HHV) =	1,050.0	Btu/scf
Annual Turbine Capacity (HHV) @ 66 °F & 100% Load* =	450.0	MMBtu/Hr
Max Turbine Heat Input (HHV) @ 24 °F & 100% Load** =	467.5	MMBtu/Hr

Annual Fuel Rate =	0.429 MMscf/hour	Max Fuel Rate =	0.445 MMscf/hr

Maximum Impacts from 1 gram per second ISCT3 Air Dispersion Modeling & Location of Impacts				
Averaging Time	Max Impact	Unit	UTM Coordinates	
1-hour Maximum Impact =	3.341	$(\mu g/m^3)/(g/s)$	437,812	3,763,778
Annual Maximum Impact =	0.1684080	$(\mu g/m^3)/(g/s)$	439,612	3,761,078

Hazardous Air Pollutants Emission Factors & Plant Sources Emission Rates				Risk Assessment Health Values					Hazard Indices & Cancer Risk			Hazard Indices & Cancer Risks Adjusted for Multipathway		
HAP	CATEF Emission Factor*** (lbs/MMcf)	CTG 3 Max. Emissions (g/s)	CTG 3 Avg. Annual Emissions (g/s)	Acute RELs $(\mu g/m^3)$	Chronic RELs $(\mu g/m^3)$	Chronic MPAF	Cancer Potency $(\mu g/m^3)^{-1}$	MICR MPAF	Acute Hazard Index	Chronic Hazard Index	Inhalation Cancer Risks Per Million	Acute Hazard Index	Chronic Hazard Index	Max Individual Cancer Risks Per Million
Acetaldedyde	6.86E-02	3.85E-03	3.71E-03		9.0E+00	1.0	2.7E-06	1.0		6.9E-05	1.7E-03		6.9E-05	1.7E-03
Acrolein	2.73E-02	1.53E-03	1.48E-03	1.9E-01	2.0E-02	1.0			2.7E-02	1.2E-02		2.7E-02	1.2E-02	
Ammonia [1]	7.14E+00	4.01E-01	3.86E-01	3.2E+03	2.0E+02	1.0			4.2E-04	3.3E-04		4.2E-04	3.3E-04	
Benzene	1.36E-02	7.63E-04	7.35E-04	1.3E+03	6.0E+01	1.0	2.9E-05	1.0	2.0E-06	2.1E-06	3.6E-03	2.0E-06	2.1E-06	3.6E-03
Benzo(a)anthracene	2.26E-05	1.27E-06	1.22E-06				1.1E-04	12.7			2.3E-05			2.9E-04
Benzo(a)pyrene	1.39E-05	7.79E-07	7.51E-07				1.1E-03	12.7			1.4E-04			1.8E-03
Benzo(b)fluoranthene	1.13E-05	6.34E-07	6.11E-07				1.1E-04	12.7			1.1E-05			1.4E-04
Benzo(k)fluoranthene	1.10E-05	6.17E-07	5.95E-07				1.1E-04	12.7			1.1E-05			1.4E-04
1,3-Butadiene	1.27E-04	7.12E-06	6.86E-06				1.7E-04	1.0			2.0E-04			2.0E-04
Chrysene	2.52E-05	1.41E-06	1.36E-06				1.1E-05	12.7			2.5E-06			3.2E-05
Dibenz(a.h)anthracene	2.35E-05	1.32E-06	1.27E-06				1.2E-03	12.7			2.6E-04			3.3E-03
Formaldehyde	1.10E-01	6.17E-03	5.95E-03	9.4E+01	3.0E+00	1.0	6.0E-06	1.0	2.2E-04	3.3E-04	6.0E-03	2.2E-04	3.3E-04	6.0E-03
Indeno(1,2,3-cd)pyrene	2.35E-05	1.32E-06	1.27E-06				1.1E-04	12.7			2.4E-05			3.0E-04
Naphthalene	1.66E-03	9.31E-05	8.97E-05		9.0E+00	1.0				1.7E-06			1.7E-06	
Propylene Oxide	4.78E-02	2.68E-03	2.58E-03	3.1E+03	3.0E+01	1.0	3.7E-06	1.0	2.9E-06	1.5E-05	1.6E-03	2.9E-06	1.5E-05	1.6E-03
Toluene	7.10E-02	3.98E-03	3.84E-03	3.7E+04	3.0E+02	1.0			3.6E-07	2.2E-06		3.6E-07	2.2E-06	
Xylene (Total)	2.61E-02	1.46E-03	1.41E-03	2.2E+04	7.0E+02	1.0			2.2E-07	3.4E-07		2.2E-07	3.4E-07	
		4.21E-01	4.06E-01						2.76E-02	1.32E-02	1.36E-02	0.02756	0.01317	0.01902

* With inlet air chiller on

**Heat Input for the short term case is for 24 degrees, 100% load, inlet air chiller off, and water injection off.

*** Mean California Air Toxic Emission Factors (CATEF), Version 1.2 are used.

[1] Ammonia Emissions are based on 5 ppmdv maximum ammonia slip @ 15% Oxygen