

## CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET  
SACRAMENTO, CA 95814-5512



**NOTICE OF RECEIPT OF THE  
EMERGENCY PERMITTING PROPOSAL  
FOR THE RAMCO CHULA VISTA PEAKER GENERATING STATION PROJECT  
EMERGENCY PERMITTING PROPOSAL (01-EP-3)**

On March 15, 2001, RAMCO, Inc., (RAMCO) filed an emergency permitting application for the Chula Vista Peaker Generating Station project (Chula Vista). RAMCO supplemented their application on May 11 and on May 21, 2001. The Energy Commission staff has reviewed the application and determined it is complete. This project is being reviewed under Public Resources Code section 25705, which grants the Energy Commission emergency permitting authority, and Executive Order D-26-01, issued February 8, 2001, and Executive Order D-28-01 issued March 7, 2001. **In Executive Orders D-26-01 and D-28-01 the Governor ordered the Energy Commission and other relevant state and local agencies to expedite review of proposed thermal power plants for construction and operation on an emergency basis by September 30, 2001.** Staff expects the Energy Commission to make a final decision on this project within three weeks. The application is available at [www.energy.ca.gov/sitingcases/peakers](http://www.energy.ca.gov/sitingcases/peakers).

Staff has begun an expedited 'fatal-flaw' analysis of the project. A hearing will be held in the City of Chula Vista on May 29, 2001. In order for the project, if approved, to be on line by September 30, the Commission plans to complete the expedited review of this project approximately three weeks from determining the application is complete.

This project is being considered outside of the Energy Commission's normal power plant siting process. Under Public Resources Code section 25705, if the legislature or the Governor declares a state of energy emergency, the Commission has emergency authority to order the construction and use of generating facilities under terms and conditions it specifies to protect the public interest. This authority can be invoked only if the Legislature or Governor declares a state of emergency and the Commission determines that all reasonable conservation, allocation, and service restriction measures may not alleviate an energy supply emergency. The Governor declared a state of emergency on January 17, 2001. On February 8 and March 7, the Governor issued several executive orders and declared that all reasonable conservation, allocation, and service restriction measures may not alleviate an energy supply emergency.

In Executive Orders D-26-01 and D-28-01, the Governor ordered the Energy Commission to expedite the processing of applications for peaking and renewable power plants that can be on line by September 30. The Governor also declared that these projects are emergency projects under Public Resources Code section 21080(b)(4), and are thereby exempt from the requirements of the California Environmental Quality Act (CEQA). A summary of the emergency permitting process, including the proposed schedule, and a checklist showing the information required in an application, can be found on the web at:

[www.energy.ca.gov/sitingcases/peakers/documents/index.html](http://www.energy.ca.gov/sitingcases/peakers/documents/index.html). A copy of this summary is attached to this notice.

### **PROJECT DESCRIPTION**

The Chula Vista project is a 62.4 megawatt (MW) simple-cycle natural gas-fired power plant to be located at the existing Chula Vista Generating Station in the City of Chula Vista, San Diego County, California. The project will consist of one 62.4 MW natural gas-fired simple-cycle peaking turbine and associated equipment located adjacent to the existing 44 MW generation facility. The project will require no new linear facilities and will interconnect to San Diego Gas & Electric's (SDG&E) electricity transmission system through the existing facility's interconnection to SDG&E located on the site. Natural gas will be supplied through an on-site connection to the existing SDG&E natural gas system.

At startup, emissions of NO<sub>x</sub> will be 25 ppm. RAMCO will be required to control NO<sub>x</sub> emissions to 5 ppm, by the installation of selective catalytic reduction (SCR) equipment, not later than June 1, 2002.

Project construction is scheduled to begin on June 15, 2001, and will take approximately two to three months. RAMCO will begin commercial operation by September 30, 2001.

### **PUBLIC PARTICIPATION**

Staff has begun an expedited 'fatal-flaw' analysis of the project. A hearing will be held in the City of Chula Vista on May 29, 2001. This hearing will provide the public as well as local, state and federal agencies the opportunity to ask questions about, and provide input on, the proposed project. A notice for this hearing will be mailed, but anyone interested in attending is encouraged to check the Energy Commission's Internet page at [www.energy.ca.gov/sitingcases/peakers](http://www.energy.ca.gov/sitingcases/peakers). This web site will include information on the status of the project, copies of notices and other relevant documents, and instructions for signing up for the project's email list-server. If you have questions or would like additional information on how to participate in the Energy Commission's review of the project, please contact Bob Eller, Siting Project Manager, at (916) 651-8835, or by email at [beller@energy.state.ca.us](mailto:beller@energy.state.ca.us).

If you want information on how you can participate in the Energy Commission's review of the project, please contact Ms. Roberta Mendonca, the Energy Commission's Public Adviser, by email at [pao@energy.state.ca.us](mailto:pao@energy.state.ca.us). For information regarding sites in Northern California, call toll free (877) 602-4747, and for sites in Southern California, call toll free (800) 273-4459. If you require special accommodations to attend a workshop, please call Robert Sifuentes at (916) 654-5004, at least five days before a workshop. Technical or project schedule questions should be directed to Bob Eller, Siting Project Manager, in the Systems Assessment and Facilities Siting Division, at (916) 651-8835, or by email at [beller@energy.state.ca.us](mailto:beller@energy.state.ca.us). The status of the project,

copies of notices and other relevant documents are also available on the Energy Commission's Internet web page at [www.energy.ca.gov/sitingcases](http://www.energy.ca.gov/sitingcases). News media inquiries should be directed to Assistant Director, Claudia Chandler, at (916) 654-4989.

This notice of receipt has been mailed to property owners located within 500 feet of to the project site and any of the project-related facilities. By being on the mailing list, you will receive notices of all project-related activities and notices when documents related to the project's evaluation are available for review. If you want your name removed from the mailing list, please contact Mary Dyas, Siting Project Assistant, at (916) 651-8891 or by email at [mdyas@energy.state.ca.us](mailto:mdyas@energy.state.ca.us).

### **AVAILABILITY OF THE APPLICATION**

Copies of the application are available for public inspection at the following libraries:

Chula Vista Public Library  
365 F Street  
Chula Vista, CA 91910-2697

South Chula Vista Library  
389 Orange Avenue  
Chula Vista, CA 91911

Otay Mesa Branch  
3003 Coronado Avenue  
San Diego, CA 92154

Copies are also available at the Energy Commission's Library in Sacramento, the California State Library in Sacramento, and at public libraries in Los Angeles, San Francisco, San Diego, Fresno, and Eureka. In addition, copies are being distributed to those public agencies that would normally have jurisdiction except for the Energy Commission's exclusive authority to certify sites and related facilities.

DATE: \_\_\_\_\_

\_\_\_\_\_  
ROBERT L. THERKELSEN, Deputy Director  
Systems Assessment & Facilities Siting

Enclosure  
Mailed to property owner list