Category C - Phase II of GWF Tracy

a) A three-phase fault with the 6-cycle normal clearing time on the
2) Tesla 115 kV Bus 2

Plot 1	Project Terminal Voltages and Angles
Plot 2	Project Power and Speed
Plot 3	Selected Bus Voltages Adjacent to Fault
Plot 4	Selected Bus Frequencies Adjacent to Fault

GENERAL ELECTRIC COMPANY

1

Mon Aug 27 09:44:00 2001

C:\GWF\ph2\CatC\A\A_2_Tesla2.chf

C:\GWF\04hs-115-3b-dyd.sav



0.01667 Time, sec. 21.0000

0.2000	o	vt	39008	GWF	TCY2	13.80	1	1.2000
-100.0	+	ang	39008	GWF	TCY2	13.80	1	100.00
0.2000	*	vt	39009	GWF	TCY3	13.80	1	1.2000
-100.0	#	ang	39009	GWF	TCY3	13.80	1	100.00
0.2000	x	vt	39007	GWF	TCY1	13.80	1	1.2000
-100.0	$	ang	39007	GWF	TCY1	13.80	1	100.00

GWF Tracy Peaking Plant Project (Phase 2 - 258 MW)
2004 Summer Peak Base Case, Stability Study
Phase 2 w/ GWF CT 1 & 2 and ST each @ 86.0 MW
3 phase 6 cycle fault at the Tesla 115 kV bus followed loss of
Tesla 115 kV Bus 2.

GENERAL ELECTRIC COMPANY	2 Sun Aug 26 23:52:32 2001	C:\GWF\ph2\CatC\A\A_2_Tesla2.chf C:\GWF\04hs-115-3b-dyd.sav



0.0000	o	pg	39008	GWF	TCY2	13.80	1	226.20
0.9900	+	spd	39008	GWF	TCY2	13.80	1	1.0100
0.0000	*	pg	39009	GWF	TCY3	13.80	1	226.20
0.9900	#	spd	39009	GWF	TCY3	13.80	1	1.0100
0.0000	x	pg	39007	GWF	TCY1	13.80	1	226.20
0.9900	$	spd	39007	GWF	TCY1	13.80	1	1.0100

GWF Tracy Peaking Plant Project (Phase 2 - 258 MW)
2004 Summer Peak Base Case, Stability Study
Phase 2 w/ GWF CT 1 & 2 and ST each @ 86.0 MW
3 phase 6 cycle fault at the Tesla 115 kV bus followed loss of
Tesla 115 kV Bus 2.



GWF Tracy Peaking Plant Project (Phase 2 - 258 MW)
2004 Summer Peak Base Case, Stability Study
Phase 2 w/ GWF CT 1 & 2 and ST each @ 86.0 MW
3 phase 6 cycle fault at the Tesla 115 kV bus followed loss of
Tesla 115 kV Bus 2.



0.7000	o	vbus	30625	TESLA D	230.00	1	1.1000
0.7000	+	vbul	33506	STANISLS	115.00	1	1.1000
0.7000	*	vbul	33514	MANTECA	115.00	1	1.1000
0.7000	#	vbus	33528	KASSON	115.00	1	1.1000
0.7000	x	vbus	33540	TESLA	115.00	1	1.1000
0.7000	$	vbul	33548	TRACY	115.00	1	1.1000

GWF Tracy Peaking Plant Project (Phase 2 - 258 MW)
2004 Summer Peak Base Case, Stability Study
Phase 2 w/ GWF CT 1 & 2 and ST each @ 86.0 MW
3 phase 6 cycle fault at the Tesla 115 kV bus followed loss of
Tesla 115 kV Bus 2.