

DELEGATE CBO INSPECTION RECORD

Today's Date 7-9-2012

Description of Inspection; Structure GSU #2 Tall Wall Area: Powerblock #2

Inspection is needed on rebar before pour on the GSU #2 Tall Wall. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-9-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-10-2012 A.M./P.M. 2:00 PM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar, water stop, clearance approved—Ok to install forms

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-10-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7-9-2012

Description of Inspection; Structure GSU #5 Short Wall & Pad Area: Powerblock #5

Inspection is needed on rebar before pour on the GSU #5 Short Wall and Pad. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-9-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-10-2012 A.M./P.M. 1:30 PM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Pending RFI for embeds clearnace

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-10-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7-9-2012

Description of Inspection; Structure GSU #5 Short Wall & Pad Area: Powerblock #5

Inspection is needed on rebar before pour on the GSU #5 Short Wall and Pad. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-9-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-10-2012 A.M./P.M. 1:30 PM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Pending RFI for embeds clearnace

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-10-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date _____

Description of Inspection; Structure _____ Area: South Road

PDR in the South Road, South of Finger 3. 4" PDR0858, 0868, 0823, 0866, 0804, 0871; 6" PDR 0858, 0880

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 07/09/12 A.M./P.M. 1:30 pm Contact: Shrenik S.

Overtime Requested: YES/NO_X SIGN: _____ Cell/Tel. Number: _____

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Piping, slope, and cathodic protection approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-10-12

TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7-6-12

Description of Inspection;

Area: Admin Bld Mechanical Room

Head pressure test in mechanical Room DWV piping

The Work described above conforms to the final approved plans.

Superintendent Signature: Mike Huffhines Date: 7-6-12
Kiewit Building Group

Inspection Schedule: One day advance notice required:

Request Date: 7-9-12 @ 10am Contact: Mike Huffhines

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 913-238-2166

Inspection Results: PASS: X

REPAIR REQUIRED: _____

Inspector's Comments:

- 1. Rgh. plumbing Ok (approved as marked on plans)**
- 2. Drywall in hallway approved**
- 3. Insulation approved**

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-11-12

DELEGATE CBO INSPECTION RECORD

Today's Date 7/11/2012

Description of Inspection; Structure: Air Compressor Slab Area: Air Compressor Area

Inspection of rebar in the air compressor foundation.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/11/2012 A.M./**P.M.** 1:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X_____ REPAIR REQUIRED:_____

Inspector's Comments:

Forms and rebar approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas **Date:** 7-11-12

__ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7-10-2012

Description of Inspection; Structure GSU #5 Short Wall Area: Powerblock #5

Inspection is needed on rebar before pour on the GSU #5 Short Wall. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-10-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-11-2012 A.M./P.M. 1:00 PM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-11-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/12/12

Description of Inspection; Structure : Switchyard Unit 4 Piers Area: _____

Rebar & Concrete Pour for 734-01, 734-09, 734-10, 734-11, 734-11, 734-06, 734-14 drilled piers

The Work described above conforms to the final approved plans.

Superintendent Signature: B.P.A. Date: 7/12/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/11/12 A.M. P.M.- 10:30 Contact: Brandon Parker

Overtime Requested: NO X SIGN: B.P.A. Cell/Tel. Number: 707-753-3163

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Cages and piers are approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-12-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/12/2012

Description of Inspection; Structure: Catch Basin #1 Lid Area: Cooling Tower

Inspection of rebar and embed on catch basin #1 top.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/12/2012 A.M./**P.M.** 1:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X___ REPAIR REQUIRED:_____

Inspector's Comments:

Forms and rebar approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: __Harvey Thomas__ Date: __7-13-12_____
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date: 7-12-12

Description of Inspection;

Area: Admin Bldg

Rough Plumbing (all areas on admin side)

The Work described above conforms to the final approved plans.

Superintendent Signature: John Zegarski Date: 7-13-12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-13-12 (1400.) Contact: Harvey

Overtime Requested: YES/NO X: Cell/Tel. Number: 661-609-1928

Inspection Results: PASS: X

REPAIR REQUIRED: _____

Inspector's Comments:

Rgh plmb and pipe insulation approved except as shown on attached plans.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-13-12
TRB + Associates

WALNUT CREEK ENERGY PARK

California Energy Commission/TRB+ Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/13/12

Description of Inspection; Structure _____ Area: West End
Head test SDR drain line by West End
4" SDR 812, 8" SDR 811

The Work described above conforms to the final approved plans.

Superintendent Signature: Shrenik Savani Date: 7/13/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required;

Request Date: 7/13/12 (4.00PM.) Contact: Shrenik Savani

Overtime Requested: YES SIGN: Shrenik Cell/Tel. Number: _____

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Approved per attached plans

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: M. Thomas Date: 7/13/12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/12/2012

Description of Inspection; Structure: UAT Pedestals (5 East) Area: UAT/5KV

Inspection of rebar and anchor bolts of the five UAT Pedestals to the East

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/13/2012 A.M./**P.M.** 1:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X_____ REPAIR REQUIRED:_____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-13-12
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/14/12

Description of Inspection; Structure Ductbank Area: Unit 5 Tempering air/Ammonia

Initial through Final Inspection for electrical ductbank Unit 5 Tempering air/Ammonia.

Conduits: 5058,E5016,E5007,E5015,E5113,E5009,E5155,E5156,E5074,E5075,E5060,E5014,E5086,E5087

Please See Drawing ED-262 Attached.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/14/12 A.M./P.M. 11:00 am Contact: Nicholas Ries

Overtime Requested: x YES/NO _____ SIGN: Nicholas Ries Cell/Tel. Number: (651)245-7579

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Approved per attached plans

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-14-12
TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7-12-2012

Description of Inspection; Structure GSU #3 Pad Area: Powerblock #3

Inspection is needed on rebar before pour on the GSU #3 Pad. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-12-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-14-2012 A.M./P.M. 10:30 AM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: YES SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-14-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/17/12

Description of Inspection; Structure Ductbank Area: Unit 1 Tempering Air Skid

Initial through Final Inspection for electrical ductbank conduit at Unit 1 Tempering Air Skid.

Conduits E1094,E1092,E1060,E1014

Drawings ED-323. See attached.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/17/12 A.M./P.M. 12:00 pm Contact: Nicholas Ries

Overtime Requested: YES/NO SIGN: Nicholas Ries Cell/Tel. Number: (651)245-7579

Inspection Results: PASS: REPAIR REQUIRED:

Inspector's Comments:

Approved per plans

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-17-12
 TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/17/12

Description of Inspection; Structure : Switchyard Unit 5 Piers Area: _____

Rebar & Concrete Pour for 736-25, 736-26, 736-27, 736-07, 736-08 drilled piers

The Work described above conforms to the final approved plans.

Superintendent Signature: BJP Date: 7/17/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/17/12 A.M. P.M.- 8:00 Contact: Brandon Parker

Overtime Requested: NO X SIGN: BJP Cell/Tel. Number: 707-753-3163

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar @ cages and clearances for coverage approved.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-17-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7-13-2012

Description of Inspection; Structure GSU #3 Short Wall Area: Powerblock #3

Inspection is needed on rebar before pour on the GSU #3 Short Wall. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-13-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-16-2012 A.M./P.M. 1:00 PM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-17-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/18/12

Description of Inspection; Structure : Switchyard Unit 5 Piers Area: _____

Rebar & Concrete Pour for 736-11, 736-12, 736-15, 736-16 drilled piers and 736-028

The Work described above conforms to the final approved plans.

Superintendent Signature: BJP Date: 7/18/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/18/12 A.M. P.M.- 10:00 Contact: Brandon Parker

Overtime Requested: NO X SIGN: BJP Cell/Tel. Number: 707-753-3163

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-18-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date: 7-19-12

Description of Inspection;

Area: Admin Bldg

Final Rough Plumbing (all areas on admin side)

The Work described above conforms to the final approved plans.

Superintendent Signature: John Zegarski Date: 7-19-12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-19-12 (1400.) Contact: Harvey

Overtime Requested: YES/NO X: Cell/Tel. Number: 661-609-1928

Inspection Results: PASS: X

REPAIR REQUIRED: _____

Inspector's Comments:

Final rgh plmb approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-19-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date _____

Description of Inspection; Structure _____ Area: South of Unit 4

PDR in the South Road Unit 4 (YP-250, 260) 6" PDR0880; 4" PDR0867, 0882, 0824, 0880, 0803

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 07/18/12 _____ A.M./P.M. 11:00 AM _____ Contact: Shrenik S. _____

Overtime Requested: YES/NO X SIGN: _____ Cell/Tel. Number: _____

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

**Approved per attached plan
Cathodic ok**

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas_ Date: 7-19-12 _____
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/12/2012

Description of Inspection; Structure: Waste Water Sample Sump Area: Cooling Tower/Waste Water Tank

Inspection of rebar for waste water sample sump bottom slab.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/12/2012 A.M./**P.M.** 1:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X___ REPAIR REQUIRED:_____

Inspector's Comments:

Rebar, water stop and clearances approved—Ok to pour bottom portion.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-19-12
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/20/12

Description of Inspection; Structure : Switchyard Unit 5 Piers Area: _____

Rebar & Concrete Pour for 735-09, 735-06, 735-14, 735-10, 735-11 drilled piers

The Work described above conforms to the final approved plans.

Superintendent Signature: BJP Date: 7/20/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/20/12 A.M. P.M.- 9:00 Contact: Brandon Parker

Overtime Requested: NO X SIGN: BJP Cell/Tel. Number: 707-753-3163

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-20-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/23/12

Description of Inspection; Structure : Switchyard Unit 5 Piers Area: _____

Rebar & Concrete Pour for 735-05, 735-13, 735-12, 735-15, 735-16, 735-08, 736-23

The Work described above conforms to the final approved plans.

Superintendent Signature: *B.P.A.* Date: 7/23/12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/23/12 **A.M./**P.M.- 9:00 Contact: Brandon Parker

Overtime Requested: NO X SIGN: *B.P.A.* Cell/Tel. Number: 707-753-3163

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar and clearance approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-23-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7-18-2012

Description of Inspection; Structure GSU #5 Tall Wall Area: Powerblock #5

Inspection is needed on rebar before pour on the GSU #5 Tall Wall. Please see drawings
2010-031-SF-027, 028

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-18-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-19-2012 A.M./P.M. 10:00 AM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: YES SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Rebar, water stop and clearances are approved.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-23-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7-23-2012

Description of Inspection; Structure CEMS #1 Area: Powerblock #1

Inspection is needed on rebar before pour on the CEMS #1 SOG. Please see drawings

2010-031-SF-015

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-23-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-24-2012 A.M./P.M. 10:00 AM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-24-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/23/2012

Description of Inspection; Structure: Cooling Tower MCC Pad Area: Cooling Tower

Inspection of all rebar prior to pouring MCC pad.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/24/2012 **A.M./P.M.** 9:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X___ REPAIR REQUIRED:_____

Inspector's Comments:

Forms, rebar and clearances approved.

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: __Harvey Thomas__ Date: __7-24-12__
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/23/2012

Description of Inspection; Structure: Waste Water Sample Sump Walls Area: Waste Water Tank

Inspection of all rebar, waterstop, and formwork prior to closing the walls.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7/23/2012 A.M./**P.M.** 1:00 Contact: William Nutting

Overtime Requested: ___ YES/**NO** ___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-24-12
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7-26-2012

Description of Inspection; Structure CEMS #4 Area: Powerblock #4

Inspection is needed on rebar before pour on the CEMS #4 SOG. Please see drawings

2010-031-SF-015

The Work described above conforms to the final approved plans.

Superintendent Signature: BEAU BURNS Date: 7-26-2012
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 7-27-2012 A.M./P.M. 9:00 AM Contact: BEAU BURNS / CHASE MASHBURN

Overtime Requested: NO SIGN: _____ Cell/Tel. Number: 949-351-3639

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-27-12
TRB + Associates

DELEGATE CBO INSPECTION RECORD

Today's Date 7/26/2012

Description of Inspection; Structure: Closed Cooling Water Head Tank Area: Gas Compressor

Inspection of all rebar prior to pouring the slab on grade. Drawing 2010-SF-031-048.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/26/2012 A.M./**P.M.** 12:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X___ REPAIR REQUIRED:_____

Inspector's Comments:

Forms, rebar and clearances approved—Deputy insp to check bolt placement

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: __Harvey Thomas__ Date: __7-27-12__
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 7/27/2012

Description of Inspection; Structure: Closed Cooling Water Heat Exchanger Area: West Side

Inspection of all rebar prior to pouring the slab on grade. Drawing 2010-SF-031-044.

The Work described above conforms to the final approved plans.

Superintendent Signature: _____ Date: _____
Kiewit Power Constructors

Inspection Schedule: *One day advance notice required:*

Request Date: 7/28/2012 **A.M./P.M.** 8:00 Contact: William Nutting

Overtime Requested:___ YES/**NO**___ SIGN: _____ Cell/Tel. Number: 913-602-4982

Inspection Results: PASS:___X___ REPAIR REQUIRED:_____

Inspector's Comments:

Forms, rebar and clearances approved

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-30-12
_ TRB + Associates

Harvey Thomas—(661) 609-1928

DELEGATE CBO INSPECTION RECORD

Today's Date 6-30-12

Description of Inspection; Structure 5kV Aux Transformer Conduit Area: BOP

The embedded conduit coming out from the 5kV building into the transformer pads to the South are ready for concrete pour. The list of conduit that will be poured are:

D0608, D0609, D0610, D0611, D0612, D0613, D0614, D0615, D0616, D0617

Please see attached drawing (2010-031-ED-270) for location of concrete placement.

The Work described above conforms to the final approved plans.

Superintendent Signature: Phil Work Date: 6-30-12
Kiewit Power Constructors

Inspection Schedule: One day advance notice required:

Request Date: 6-30-12 A.M./P.M. 2 P.M. Contact: Matt Vessell

Overtime Requested: YES/NO SIGN: _____ Cell/Tel. Number: (626) 626-8737

Inspection Results: PASS: X REPAIR REQUIRED: _____

Inspector's Comments:

Approved per attached plan

NOTE: *Corrections must be performed, inspected and approved prior to continuing work in affected area.*

Inspector of Record: Harvey Thomas Date: 7-30-12
TRB + Associates

Attachment C-6 – Non-Conformance Report Log

