

February 24, 2009  
 SPA 09-005

Mary Dyas  
 Compliance Project Manager  
 California Energy Commission  
 Siting, Transmission & Environmental Protection Division  
 1516 Ninth Street  
 Sacramento, CA 95814

**Re: Sacramento Power Authority (SPA) – Docket No. 93-AFC-3C  
 Errata to Petition to Amend Conditions of Certification**

Dear Ms. Dyas:


Please accept the following errata to the petition to amend the Conditions of Certification (COCs) for the Sacramento Power Authority (SPA) at Campbell Cogeneration Project, 93-AFC-3C, filed with the Commission on February 9, 2009. The correction occurs in Table 9 of the January 27, 2009 SPA application for Authority to Construct to the Sacramento Metropolitan Air Quality Management District, which is included as one of the petition attachments.

| <b>Table 9<br/>                     Maximum Ambient Impacts, (µg/m<sup>3</sup>)</b> |                |   |  |                                   |                                     |                                       |
|---|----------------|---|--|-----------------------------------|-------------------------------------|---------------------------------------|
| Pollutant   | Averaging Time | SPA Project Impact (µg/m <sup>3</sup> ) | Background Conc. <sup>a</sup> (µg/m <sup>3</sup> ) | Total Impact (µg/m <sup>3</sup> ) | State Standard (µg/m <sup>3</sup> ) | Federal Standard (µg/m <sup>3</sup> ) |
| NO <sub>2</sub>   | 1-hour         | 182                                     | 147  | 329                               | 339                                 | –                                     |
| CO  | 1-hour         | 3,637                                   | 5,470  | 9,107                             | 23,000                              | 40,000                                |
| CO  | 8-hour         | 1,775                                   | 4,620 4,889  | 7,876 6,664                       | 10,000                              | 10,000                                |

This erratum corrects a transcription error in the Table 9 values for the 8-hour CO background concentration and total impact. As indicated in Table 9, this correction results in lower listed total impacts for the CO emissions from the project's commissioning activities.

If there are any questions, please contact me at (916) 732-6246.

Sincerely,

A handwritten signature in cursive script that reads "Stuart Husband".

Stuart Husband  
Regulatory Compliance Coordinator

Enclosure

Cc: Jeff Adkins, Sierra Research  
Ross Gould, SMUD  
Kurt Hook, WGPO  
Lourdes Jimenez-Price, SMUD  
SPA Files 1600.01  
Corporate Files