

Farber

**VERTICAL FENESTRATION ADDITIONS TO EXISTING CONDITIONED SPACE:** In warmer climate zones, require tinted or shaded glass for glass additions that meet the new '98 allowance for small glass additions that do not require compliance calculations. (specific SHGC and shading requirements would be set by the Standards).