

be certified not to be less than the values listed below. Note that the minimum efficiency for this equipment changes on January 23, 2006.

**Table 4-4 – Minimum Cooling Efficiencies for Central Air Conditioners and Heat Pumps**

Source: California Appliance Efficiency Regulations

Appliance	Type	SEER	
		Prior to 1/23/06	On and After 1/23/06
Central Air Conditioners	Split System	10.0	13.0
	Single Package	9.7	13.0
Central Air Source Heat Pumps	Split System	10.0	13.0
	Single Package	9.7	13.0

**Other Air Conditioners and Heat Pumps**

Appliance Efficiency Regulations

The current Appliance Efficiency Regulations for larger central air conditioners and heat pumps, and for all room air conditioners and room air conditioner heat pumps shall be certified by the manufacturer to not to be less than the values listed in Table 4-5 and 4-6.

**Table 4-5 – Minimum Cooling Efficiency for Larger Central Air Conditioners and Heat Pumps**

Source: California Appliance Efficiency Regulations

Equipment Type	Size Category	EER
Central Air Conditioners	65,000 Btu/h up to 135,000 Btu/h	8.9
Central Air Source Heat Pumps	65,000 Btu/h up to 135,000 Btu/h	8.9
Central Water Source Heat Pumps	Up to 135,000 Btu/h	12.0