

CERTIFICATE of INSTALLATION
Two Interlocked Lighting Systems

(Page 1 of 2)

NRCI-ILT-04-E

PROJECT NAME:	DATE:	_____ Building Permit _____ Checked by/Date Enforcement Agency Use
PROJECT ADDRESS:		

GENERAL INFORMATION

DATE OF BUILDING PERMIT	PERMIT #			
BUILDING TYPE	<input type="checkbox"/> Nonresidential	<input type="checkbox"/> High-Rise Residential	<input type="checkbox"/> Hotel/Motel Guest Room	
PHASE OF CONSTRUCTION	<input type="checkbox"/> New Construction	<input type="checkbox"/> Addition	<input type="checkbox"/> Alteration	<input type="checkbox"/> Unconditioned
<i>If more than one person has responsibility for building construction, each person shall prepare and sign an Installation Certificate document applicable to the portion of construction for which they are responsible; alternatively, the person with chief responsibility for construction shall prepare and sign the Installation Certificate document(s) for the entire construction.</i>				

DECLARATION STATEMENT

- I certify under penalty of perjury, under the laws of the State of California, the information provided on this form is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for construction, or an authorized representative of the person responsible for construction (responsible person).
- I certify that the installed features, materials, components, or manufactured devices identified on this certificate (the installation) conforms to all applicable codes and regulations, and the installation is consistent with the plans and specifications approved by the enforcement agency.
- I reviewed a copy of the Certificate of Compliance approved by the enforcement agency that identifies the specific requirements for the installation. I certify that the requirements detailed on the Certificate of Compliance that apply to the installation have been met.
- I will ensure that a completed, signed copy of this Installation Certificate shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Installation Certificate is required to be included with the documentation the builder provides to the building owner at occupancy.

Company Name:		
Responsible Person's Name:	Responsible Person's Signature:	
Lic.#	Date Signed:	Position With Company:

SCOPE OF RESPONSIBILITY

<i>Enter the date of approval by enforcement agency of the Certificate of Compliance that provides the specifications for the energy efficiency measures for the scope of responsibility for this Installation Certificate:</i>	Date:
---	-------

Two Interlocked Lighting Systems

§130.4(b) - Before Two Interlocked Lighting Systems will be permitted for compliance with Section 140.6 of Part 6 of Title 24, the person who is eligible under Division 3 of the Business and Professions Code to accept responsibility for the construction or installation of features, materials, components, or manufactured devices shall sign and submit this Installation Certificate.

If any of the following requirements fail the installation test, all of the planned permanent and planned portable lighting in the room shall be included in determining the installed lighting power.

Check all that apply:

- The function area qualifies to install two interlocked lighting systems because it is only one of the following types:
 - Auditorium room
 - Convention center room
 - Conference room
 - Multipurpose room
 - Theater room
 - There are no more than two interlocked lighting systems serving the space.
 - The two lighting systems are interlocked with a non-programmable double throw switch to prevent simultaneous operation.
-
- For compliance with Part 6 a Nonprogrammable Double-Throw Switch is an electrical switch commonly called a "single pole double throw" or "three-way" switch that is wired as a selector switch allowing one of two loads to be enabled. It can be a line voltage switch or a low voltage switch selecting between two relays. It cannot be overridden or changed in any manner that would permit both loads to operate simultaneously.