

**ELEVATOR LIGHTING AND VENTILATION CONTROLS**

CEC-NRCC-PRC-12-E (Revised MM/YY)  
 CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE	NRCC-PRC-12-E
<u>Elevator Lighting and Ventilation Controls</u>	(Page 1 of 2)
Project Name:	Date Prepared:

<b>A. General Information</b>
Phase of Construction: <input type="checkbox"/> New Construction <input type="checkbox"/> Addition <input type="checkbox"/> Alteration

<b>B. Mandatory Requirements</b>						
MANDATORY MEASURES	T-24 Sections	Indicate page reference for information on the plans or specification, or list information below				
<u>Light Power Density for the luminaires inside the elevator cab shall be no greater than 0.6 watts per square foot.</u>	§120.6(f)1					
<u>Elevator cab ventilation fans for cabs without space conditioning shall not exceed 0.33 watts per CFM as measured at maximum speed.</u>	§120.6(f)2					
<u>Elevator equipped with automatic shutoff controls?</u>	§120.6(f)3 & 4	<input type="checkbox"/> Yes / <input type="checkbox"/> No				

**ELEVATOR LIGHTING AND VENTILATION CONTROLS**

CEC-NRCC-PRC-12-E (Revised MM/YY)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-12-E

Elevator Lighting and Ventilation Controls

(Page 2 of 2)

Project Name:

Date Prepared:

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name:

Documentation Author Signature:

Company:

Signature Date:

Address:

CEA/ HERS Certification Identification (if applicable):

City/State/Zip:

Phone:

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name:

Responsible Designer Signature:

Company :

Date Signed:

Address:

License:

City/State/Zip:

Phone:

### **NRCC-PRC-12-E User Instructions**

This is the primary form for elevator lighting and ventilation controls, which provides compliance information for the use of the enforcement agency's field inspectors. This form must be included on the plans. A copy of this form should also be submitted to the enforcement agency along with the rest of the compliance submittal at the time of building permit application.

#### **Project Description**

PROJECT NAME is the title of the project, as shown on the plans and known to the enforcement agency.

DATE is the last revision date of the plans. If the plans are revised after this date, it may be necessary to re-submit the compliance documentation to reflect the altered design. Note that it is the enforcement agency's discretion whether to require new compliance documentation or not.

#### **Section A. General Information**

PHASE OF CONSTRUCTION indicates the status of the building project described in the compliance documents. Refer to Nonresidential Compliance Manual Section 1.7 for detailed discussion of the various choices.

1. NEW CONSTRUCTION should be checked for all new buildings, newly conditioned space or for new construction in existing buildings (tenant improvements, see Section 1.7.11 and 1.7.12) that are submitted for envelope compliance.
2. ADDITION should be checked for an addition which is not treated as a stand-alone building, but which uses option 2 described in Section 1.7.14. Tenant improvements that increase conditioned floor area and volume are additions.
3. ALTERATION should be checked for alterations to an existing building mechanical systems (see Section 1.7.13). Tenant improvements are usually alterations.

#### **Section B. Mandatory Measures**

The mandatory measures must be incorporated into the construction documents. Left column list the measures and the section numbers in the Building Efficiency Standards where the requirements for those measures are specified. The columns labeled *Indicate Page Reference on Plans or Schedule* are for designating the specific sheet on the plans or specification section(s) where the measures used to comply with the Standards are documented. In each column, the documentation author shall identify where each of the required measures are specified on the plans or in the project specifications. Where a measure is not applicable to the specific system, the letters "NA" (for not applicable) are placed in the cell. Groups of similar systems can be entered in a single column where appropriate.

#### **Documentation Author's Declaration Statement**

The CERTIFICATE OF COMPLIANCE is signed by both the Documentation Author and the Principal Designer who is responsible for preparation of the plans of building. This latter person is also responsible for the energy compliance documentation, even if the actual work is delegated to a different person acting as Documentation Author. It is necessary that the compliance documentation be consistent with the plans.

DOCUMENTATION AUTHOR is the person who prepared the energy compliance documentation and who signs the Declaration Statement. The person's telephone number is given to facilitate response to any questions that arise. A Documentation Author may have additional certifications such as a Certified Energy Analyst or a Home Energy Rating System certification number. Enter number in the CEA# or HERS# box.

#### **Declaration Statement of Principle Designer**

The Declaration Statement is signed by the person responsible for preparation of the plans for the building and the documentation author. This principal designer is also responsible for the energy compliance documentation, even if the actual work is delegated to someone else (the Documentation Author as described above). It is necessary that the compliance documentation be consistent with the plans. The Business and Professions Code governs who is qualified to prepare plans and therefore to sign this statement. See Section 2.2.2 Permit Application for applicable text from the Business and Professions Code.