



Fuji Printing Ink MFG. Co., Ltd. (Itami City)

Slate Roof: 875 sqm Application Date: 7/10~7/20, 2004

Air Temperature below the ceiling was reduced by 9.6 °C after the application when the outside temperature was constant at 36.0 °C.

【Measuring Points】

In the air below the ceiling



Date	7/10	7/11	7/12	7/13	7/14	7/15	7/16	7/17	7/18	7/19	7/20	7/21	7/22	7/23	7/24
Weather	☔/☀	☀/☔	☁	☀	☀	☀	☀	☀/☁	☁	☁	☁/☀	☀	☀	☀	☀
Max. Outside Temp.	33.9	30.4	30.5	36.0	37.8	38.2	37.3	35.2	33.4	34.4	36.0	35.0	37.1	37.9	32.8
Max. Below the Ceiling	40.4	43.1	33.3	43.4	45.5	41.3	35.4	34.5	33.3	34.4	33.8	35.2	35.6	36.5	32.8