

**CALIFORNIA
ENERGY
COMMISSION**

NILAND GAS TURBINE PLANT

**Small Power Plant Exemption (06-SPPE-1)
Imperial County**



**COMMISSION DECISION
MITIGATED NEGATIVE DECLARATION &
FINAL INITIAL STUDY**

**OCTOBER 2006
(06-SPPE-1)
CEC-800-2006-008-CMF**



NILAND GAS TURBINE PLANT

Small Power Plant Exemption (06-SPPE-1)
Imperial County



CALIFORNIA
ENERGY
COMMISSION

COMMISSION DECISION
MITIGATED NEGATIVE DECLARATION &
FINAL INITIAL STUDY

OCTOBER 2006
(06-SPPE-1)
CEC-800-2006-008-CMF



CALIFORNIA ENERGY COMMISSION

1516 9th Street
Sacramento, CA 95814

<http://www.energy.ca.gov/sitingcases/niland/index.html>



JACKALYNE PFANNENSTIEL
Chair

JAMES D. BOYD
Vice Chair

ARTHUR H. ROSENFELD, Ph. D.
Commissioner

JOHN L. GEESMAN
Commissioner

JEFFREY D. BYRON
Commissioner

STANLEY VALKOSKY
Chief Hearing Adviser

GARRET SHEAN
Hearing Officer

TABLE OF CONTENTS

DECISION	Page 3
PROJECT DESCRIPTION	3
FINDINGS	5
FINAL INITIAL STUDY	
Executive Summary.....	i
Proposed Mitigated Negative Declaration	v
Introduction.....	1
Project Description.....	2
Air Quality	3
Biological Resources	4
Cultural Resources	5
Energy Resources	6
Geology, Mineral Resources & Paleontology	7
Hazardous Materials Management.....	8
Land Use, Recreation & Agricultural Resources	9
Noise & Vibration.....	10
Public Health.....	11
Socioeconomics	12
Soil & Water Resources	13
Traffic & Transportation.....	14
Transmission Line Safety & Nuisance.....	15
Transmission System Engineering.....	16
Visual Resources.....	17
Waste Management	18
General Conditions of Compliance.....	19

This page intentionally blank.



**CALIFORNIA
ENERGY
COMMISSION**

1516 Ninth Street
Sacramento, CA 95814
800-822-6228
www.energy.ca.gov

COMMISSION DECISION

NILAND GAS TURBINE PLANT
SMALL POWER PLANT EXEMPTION
DOCKET NO. 06-SPPE-1

The California Energy Commission is the State agency granted exclusive authority to review and license proposals to construct and operate large electric power plants, including the authority to exempt proposals under 100 MW from our certification review. Proposals granted an exemption are subject to local permitting processes. On March 13, 2006, the Imperial Irrigation District (IID) filed an application for a Small Power Plant Exemption (SPPE).

The Energy Commission grants a Small Power Plant Exemption to the Imperial Irrigation District for its 93 MW Niland Gas Turbine Plant Project in Niland, California, with the following features and highlighted measures to mitigate potential environmental and community impacts and comply with applicable laws, ordinances, regulations and standards (LORS):

**PROJECT
DESCRIPTION:**

The IID proposes to build and operate a nominal 93 megawatt (MW) simple-cycle power plant on a 22-acre site northeast of Niland, California. The proposed site is owned by IID and is adjacent to IID's existing Niland Substation. The project would supply the internal power generation needs of the IID service territory during periods of peak electrical demand.

The plant would consist of two General Electric LM6000 PD SPRINT NxGen combustion turbine generators (CTG) equipped with inlet air chiller coils, selective catalytic reduction (SCR) for NOx control, zero liquid discharge (ZLD) wastewater treatment system, water storage and treatment systems, gas compressor equipment, and electrical transmission and interconnection system with associated auxiliary systems and equipment.

Water for injection to augment power generation is to be supplied by Golden State Water Company's existing pipeline crossing IID's property. Natural gas will be supplied by the existing Southern California Gas Company's pipeline adjacent to the site. The project will interconnect directly to the 92-kilovolt bus at the adjacent Niland Substation.

**LOCAL
ECONOMIC
BENEFITS:**

Construction of the project, to be completed in May 2008, will require nine months with an average of 40 commuting workers, and a peak of 60, from Imperial and surrounding counties. Project cost is estimated at \$69.4 million, with a construction payroll of \$10.4 million. The value of construction costs within Imperial County is estimated at \$1.3 million. Construction sales taxes amount to \$4.2 million. Annual operation payroll would be \$200,000, with approximately \$188,000 of annual purchases in Imperial County. Local merchants and restaurants in Niland will benefit from sales to construction workers.

NOISE:

The three closest sensitive residential noise receptors are located 1,600 feet east of the project; and the J & H Trailer Park is located 2,600 feet west of the project. Based upon Energy Commission practice of determining noise impact using the quietest four consecutive hours of the night, the project could create significant adverse noise impacts in this fairly quiet rural setting if not mitigated. Nighttime noise survey measurements were affected by nearby vehicular and rail traffic, railroad crossing bells, air conditioners running all night during the hot summertime, and crickets and frogs. As a peaker, the project is intended to operate mostly during the hot months (May through October), including overnight as necessary to meet air conditioning load.

For this project, the most stringent noise limitation is the Imperial County General Plan, which establishes a limit of 45 dBA (Leq) measured at the property line of the receptor during nighttime hours. With the noise mitigation IID will apply to the project, the predicted maximum nighttime noise from the project operating during hot summer months will comply with the General Plan limit, since household air conditioners as well as frogs and crickets will be contributing to the ambient nighttime noise levels. To assure compliance with the General Plan and no significant impact on nighttime residential noise receptors after the project begins operation, the Commission requires 'before and after' noise surveys and establishing a public noise complaint resolution process. (Conditions: **NOISE 2 & 3**)

DISCUSSION:

No areas have been identified in the Environmental Checklist of the Final Initial Study as having the potential for unmitigated significant environmental impacts. A highlight of the environmental analysis and mitigation follows:

- ✓ To mitigate potential noise impacts, particularly nighttime noise, the project will meet Imperial County's General Plan noise limit by on-site mitigation to reduce receptor noise to not more than 45 dBA.


**FINDINGS &
ORDERS:**

Based upon the entirety of the uncontested record in this proceeding, including the Small Power Plant Exemption Application, Applicant's Data Responses, the Energy Commission Staff's Draft and Final Initial Study and Proposed Mitigated Negative Declaration, and comments by agencies and others, the Commission makes the following findings:

1. With the mitigation measures and Conditions of Exemption of the Final Initial Study, incorporated by reference, and compliance therewith verified by a reporting and monitoring program, the project will cause no unmitigated significant environmental impacts or adverse impact to energy resources.
2. The project is granted a Small Power Plant Exemption under Public Resources Code section 25541.
3. The Proposed Mitigated Negative Declaration and Final Initial Study were prepared in compliance with the California Environmental Quality Act and all applicable State and Commission Guidelines.

Dated: October 11, 2006


**ENERGY RESOURCES
CONSERVATION AND DEVELOPMENT
COMMISSION**



JACKALYNE PFANNENSTIEL
Chairman

(absent)


JAMES D. BOYD
Vice Chair



ARTHUR H. ROSENFELD
Commissioner

(absent)

JOHN L. GEESMAN
Commissioner



JEFFREY D. BYRON
Commissioner