



SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS

CERTIFICATE OF VERIFICATION

Note: This table completed by HERS Registry.

Table with 2 columns and 3 rows: Project Name, Dwelling Address, City and Zip Code; Enforcement Agency, Permit Number, Permit Application Date.

A. System Information

HERS Rater to field-verify all system information, discrepancies to be noted by overwriting entry.

Table with 3 columns and 18 rows containing system information fields like Space Conditioning System Identification, Condenser details, Refrigerant Type, and Verification Method.

MCH-25d - Refrigerant Charge Verification - Fault Indicator Display (FID)



B. Fault Indicator Display Verification Applicability

01	Measured Condenser Air Entering Dry-bulb Temperature (T _{condenser, db}) (°F)	
02	Outdoor Temperature Qualification Status	
03	Self Diagnostic Reporting (SDR)	
04	Fault Indicator Display Verification Applicability	

C. Measurement Access Hole (MAH) Verification

HERS Raters are required to visually field verify MAH. Procedures for installing MAH are specified in Reference Residential Appendix RA3.2.2.3.

01	Method Used to Demonstrate Compliance with the Measurement Access Hole (MAH) Requirement	
----	--	--

D. Minimum System Airflow Rate Verification

Procedures for verifying minimum system airflow are specified in Reference Residential Appendix RA3.3.3.

01	02	03
Indoor Unit Name or Description of Area Served	Minimum Required System Airflow Rate (cfm)	System Airflow Rate Verification Status
04	Compliance Statement:	
Notes:		

E. Fault Indicator Display Installation Verification

Procedures for the Fault Indicator Display Verification are detailed in RA3.4.2.

01	FID Manufacturer Name/Make	
02	FID Model Number	
03	Display Module is Mounted Adjacent to the System Thermostat	
04	The manufacturer has certified to the Energy Commission that the FID model meets the requirements of Reference Joint Appendix JA6 (Make and model found on CEC list of approved FID devices).	
05	The system has operated for at least 15 minutes and the FID reports that the system is operating within acceptable parameters.	
06	Compliance Statement:	



SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS

F. Determination of HERS Verification Compliance

All applicable sections of this document shall indicate compliance with the specified verification protocol requirements in order for this Certificate of Verification as a whole to be determined to be in compliance.

01	
----	--

For information and data collection only. Not valid until registered with a HERS provider



SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

1. I certify that this Certificate of Verification documentation is accurate and complete.

Table with 2 columns: Documentation Author Name, Documentation Author Signature, Company, Date Signed, Address, CEA/HERS Certification Information, City/State/Zip, Phone.

RESPONSIBLE PERSON'S DECLARATION STATEMENT

- 2. I certify the following under penalty of perjury, under the laws of the State of California:
1. The information provided on this Certificate of Verification is true and correct.
2. I am the certified HERS Rater who performed the verification identified and reported on this Certificate of Verification (responsible rater).
3. The installed features, materials, components, manufactured devices, or system performance diagnostic results that require HERS verification identified on this Certificate of Verification comply with the applicable requirements in Reference Appendices RA2, RA3, and the requirements specified on the Certificate of Compliance for the building approved by the enforcement agency.
4. The information reported on applicable sections of the Certificate(s) of Installation (LMCI) signed and submitted by the person(s) responsible for the construction or installation conforms to the requirements specified on the Certificate(s) of Compliance (LMCC) approved by the enforcement agency.
5. I understand that a registered copy of this Certificate of Verification shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to ensure this requirement is accomplished.
6. I understand that a registered copy of this Certificate of Verification is required to be included with the documentation the builder provides to the building

BUILDER OR INSTALLER INFORMATION AS SHOWN ON THE CERTIFICATE OF INSTALLATION

Table with 2 columns: Company Name (Installing Subcontractor, General Contractor, or Builder/Owner), Responsible Builder or Installer Name, CSLB License.

HERS PROVIDER DATA REGISTRY INFORMATION

Table with 2 columns: Sample Group Number (if applicable), Dwelling Test Status in Sample Group (if applicable).

HERS RATER INFORMATION

Table with 2 columns: HERS Rater Company Name, Responsible Rater Name, Responsible Rater Signature, Responsible Rater Certification Number w/ this HERS Provider, Date Signed.

For assistance or questions regarding the Energy Standards, contact the Energy Hotline at: 1-800-772-3300

CERTIFICATE OF VERIFICATION – USER INSTRUCTIONS	LMCV-MCH-25-H
Refrigerant Charge Verification	(Page 1 of 4)

LMCV-MCH-25d-H User Instructions

Section A. System Information

1. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
2. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
3. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
4. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
5. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
6. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
7. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail. Choose the type of refrigerant used by the system being verified. R-22 and R-410A are the most common, but other types may occasionally be encountered.
8. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If “Other” is chosen in A07, then installer will indicate the type of refrigerant being used. If R-22 or R-410A is being used (regardless of trade name, Puron, Genetron, etc.) it should be indicated in A07, not here. This row is only for refrigerants other than R-22 and R-410a. Documentation of other refrigerants should be requested. If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
9. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). If applicable, a liquid line filter drier shall be installed according to the manufacturer’s specifications.
10. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). These are defined in detail the Residential Compliance Manual. If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail. Indicate whether the HVAC system is Completely New, Replacement or an Alteration.
11. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). Installer is to select the appropriate choice regarding whether this system has a Fault Indicator Display (FID). Qualifying FID’s may exempt a system from HERS refrigerant charge verification. FID’s are described in Joint Appendix JA6.1. Qualifying FID’s must appear on a list of approved devices kept by the Commission. If installed system does not match the description here, it fails. Note: Installation of a FID does not exempt the installer from proper refrigerant charge verification. It may only exempt the need for third party refrigerant charge verification. Third party verification of the FID is required. Other requirements may also be triggered.
12. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). Most ducted split systems and package systems are of the type that minimum airflow can be verified using an approved measurement procedure. Examples of systems that do not meet this description are ductless systems. Selecting “No” here may subject the project to additional scrutiny by enforcement personnel.
13. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). Most ducted split systems and package systems are of the type that approved refrigerant charge verification procedures

CERTIFICATE OF VERIFICATION – USER INSTRUCTIONS	LMCV-MCH-25-H
Refrigerant Charge Verification	(Page 2 of 4)

detailed in Residential Appendix RA3.2.2 or RA1 can be used (i.e., Standard Charge Verification or Winter Setup Verification procedures). Examples of systems that may not meet this description are “mini splits” or variable refrigerant flow systems that may only be charged using weigh-in procedures. Selecting “No” here may subject the project to additional scrutiny.

14. HERS rater to input date of their refrigerant charge verification.
15. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). The installer is to have selected the refrigerant charge verification method used from the choices provided:
 - Superheat (outdoor temperature must be $\geq 55^{\circ}\text{F}$); this verification method can only be used when the outdoor temperature is at or above 55°F . It is only used on systems with fixed orifice refrigerant metering devices (non-variable metering devices). This method is detailed in Reference Appendix RA3.2.2.6.1. Systems verified using this method may be eligible for HERS verification compliance using Group Sampling. Choosing this option will generate a LMCI-MCH-25a.
 - Subcooling (outdoor temperature must be $\geq 55^{\circ}\text{F}$); this verification method can only be used when the outdoor temperature is at or above 55°F . It is only used on systems with variable metering devices (TXV or EXV). This method is detailed in Reference Appendix RA3.2.2.6.2. Systems verified using this method may be eligible for HERS verification compliance using Group Sampling. Choosing this option will generate a LMCI-MCH-25b.
 - Weigh-in; this verification method can be used by the installer at any outdoor temperature allowed by the equipment manufacturer. This method is detailed in Reference Appendix RA3.2.3. Systems verified using this method are NOT eligible for HERS verification compliance using Group Sampling. Choosing this option will generate a LMCI-MCH-25c.
 - Winter Setup (applicable when outdoor temperature is $< 55^{\circ}\text{F}$); the Winter Setup verification method is a special version of the Subcooling method. It can be used when the outdoor temperature is between 37°F and 55°F . It can only be used on equipment where the manufacturer has specifically approved it for the equipment being tested. The Winter Setup procedure is details in Residential Appendix RA1.2. Choosing this option will generate a LMCI-MCH-25e.
 - New Package Unit Factory Charge; the installer should choose this option when a new package unit is being installed that has an AHRI rating. This helps ensure that the unit was properly charged at the factory. HERS verification of refrigerant charge may not be required in this case. Choosing this option will generate a LMCI-MCH-25f.
16. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). The installer (or rater) is to have identified who performed the verification that is documented on the Certificate of Installation. Note that HERS verification compliance by Group Sampling requires that the installer perform their own refrigerant charge verification as part of the installation of the equipment prior to the system being put into a sample group for possible selection by a HERS rater for verification. If Group Sampling is not intended, the HERS Rater may perform the refrigerant charge verification on behalf of the Installing Contractor (applies to any method but Weigh-In) and the Rater will enter same results on both the LMCI and LMCV.
17. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). The Group Sampling status is automatically displayed based on the input results of A15 and A16 on the LMCI. Group Sampling procedures are detailed in Residential Appendix RA2.3.
18. Specify the refrigerant charge verification used by the HERS rater. Choices vary depending on what method was specified in A11, A12, and A15.

CERTIFICATE OF VERIFICATION – USER INSTRUCTIONS	LMCV-MCH-25-H
Refrigerant Charge Verification	(Page 3 of 4)

Section B. Fault Indicator Display Verification Applicability

1. Measure and record the condenser entering dry bulb air temperature (outdoor air at condenser).
2. This box is filled automatically. If the outdoor temperature is less than 55°F, the FID must be equipped with self diagnostic reporting capabilities for it to operate correctly when it is below 55°F.
3. Rater to verify whether or not FID is equipped with SDR capability. This can be determined by checking model number against CEC list of approved FIDs.
4. This box is filled automatically. The outdoor temperature must be above 55°F or the FID must be equipped with SDR capability for FID verification to proceed.

Section C. Measurement Access Hole (MAH) Verification

1. This information is automatically pulled from the Certificate of Installation (LMCI-MCH-25). Installer is to have indicated the method used to demonstrate compliance with the MAH requirement by selecting the appropriate method from the drop down list. Procedures for installing MAH's are detailed in RA3.2.2.3. Selecting that the MAH cannot be installed consistent with Figure 3.2-1 may result in additional scrutiny by enforcement personnel.) If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.

Section D. Minimum System Airflow Rate Verification

1. This information is automatically calculated based on the information given in A10. This is the target minimum system airflow required for the system being verified.
2. This information is automatically calculated based on either the LMCV-MCH-23, or LMCV-MCH-28, which documents the rater's measured airflow of the system being verified. If the measured airflow is not adequate it will not comply with the airflow requirements and refrigerant charge verification cannot be performed.

Section E. Verification of Fault Indicator Display

1. Information retrieved from LMCI-MCH-25. Rater to confirm that entry matches name shown on the list of approved devices kept by the Commission. If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
2. Information retrieved from LMCI-MCH-25. Rater to confirm that entry matches model number shown on the list of approved devices kept by the Commission. If installed system does not match this entry, it can be overwritten by rater but it will be flagged as a possible fail.
3. The rater must confirm that the FID display module is mounted adjacent to thermostat that controls the system being verified. This requirement is detailed in Residential Appendix RA3.4.2.
4. The rater must confirm that the installed FID is approved and appears the list of approved devices kept by the Commission. This requirement is detailed in Residential Appendix RA3.4.2.
5. The rater must confirm that the system has operated for at least 15 minutes and that they system is operating within acceptable parameters as specified by the FID and equipment manufacturers. This requirement is detailed in Residential Appendix RA3.4.2.

Section F. Determination of HERS Verification Compliance

1. This field is filled out automatically. Compliance requires that all individual criteria pass.

CERTIFICATE OF VERIFICATION – USER INSTRUCTIONS	LMCV-MCH-25-H
Refrigerant Charge Verification	(Page 4 of 4)

Documentation Declaration Statements

1. The person who prepared the LMCV will sign and complete the fields for their name, company (if applicable), address, phone number, certification information (if applicable), date and signature.
2. The person who is assuming responsibility for the project being built to comply with Title 24, Part 6, will complete the fields (if applicable) for their company, responsible builder or installer name, CSLB license number, sample group number, dwelling test status in sample group, HERS Rater company name, HERS Rater name, HERS Rater signature, HERS Rater certification number and date signed.

For information and data collection only. Not valid until registered with a HERS provider