

INSTALLER and INSPECTOR QUICK-REFERENCE: 2022 NRCA-PRC-06-F Air-Cooled Condenser Fan Motor Variable Speed Controls	
Purpose and Scope of the Test	
This test ensures that the condenser fan speed is continuously variable, that the condenser fans are controlled in unison, the minimum condensing temperature control setpoint is 70°F or lower, and that the condensing temperature of the condenser is reset in response to ambient dry-bulb temperature, per the Energy Code.	
Test trigger	
<p>Newly Constructed Buildings: Applies to functional testing and verification of fan motor variable speed control for air-cooled condensers. Condenser fan motor controls are required on any new air-cooled condensers installed on new refrigeration systems.</p> <p><i>Exceptions:</i></p> <ul style="list-style-type: none"> • <i>Systems for which more than 20 percent of the total design load is for quick chilling, freezing, or process refrigeration.</i> 	
Relevant Energy Code References and Required Compliance Documents	
Title 24, Part 6 of the California Building Code, Building Energy Efficiency Standards (Energy Code) sections 120.6(a)4, 120.6(a)7, 170.2(c)4F; NA7.10.3.2; NRCC-PRC-E Table F.	
Who Can Perform the Test	
There are no restrictions. The test is typically performed by the startup technician responsible for programming the setpoints in the control system.	
Required Tools	
<p>Performance of this test will require measuring the ambient dry-bulb temperature, and condenser operating pressure. The instrumentation needed to perform the test may include, but is not limited to:</p> <ul style="list-style-type: none"> • A temperature sensor calibrated to +/- 0.7°F between -30°F and 200°F. • A pressure sensor shall be calibrated to +/- 2.5 psi between 0 and 500 psig. 	
Estimated Time to Complete Test	
<p>Construction Inspection: 1 hours (for one condenser)</p> <p>Functional testing: 3 hours (for one condenser)</p>	
Potential Issues and Cautions	
Coordinate test procedures with the refrigeration or controls contractor, or the facility supervisor since they may be needed to assist with the manipulation of the control system.	

**INSTALLER and INSPECTOR QUICK-REFERENCE:
2022 NRCA-PRC-06-F
Air-Cooled Condenser Fan Motor Variable Speed Controls**

Potential Issues and Cautions (cont.)

To ensure proper overall system operation, make sure that the system pressure is not held at excessively low or high values for an extended period of time when varying the saturated condensing temperature (SCT) control setpoint. Avoid abrupt changes in pressure. Coordinate with facility operator or refrigeration contractor.

Inspection Enforcement

- The minimum saturated condensing temperature (SCT) control setpoint is at or below 70°F.
- The SCT value used by the control system is the temperature equivalent reading of the condenser pressure sensor.
- All drain leg pressure regulator valves (if used) are set below the minimum condensing temperature/pressure setpoint, and all receiver pressurization valves, such as the outlet pressure regulator (OPR), are set lower than the drain leg pressure regulator valve setting. This ensures that the pressure regulator valve and receiver pressurization valve settings do not force the actual condensing temperature to be higher than the minimum condensing temperature setpoint. (Note: These regulators are only used on small systems and rarely with evaporative condensers.)
- All pressure and temperature sensors have been calibrated and read accurately.
- Temperature sensors are mounted in a location away from direct sunlight.
- All sensor readings used by the condenser controller convert or calculate to the correct conversion units at the controller (e.g., saturated pressure reading is correctly converted to appropriate saturated temperature).
- All condenser motors are operational and rotate in the correct direction.
- All condenser fan speed controls are operational and connected to condenser fan motors, to operate fans serving a common condenser loop in unison.
- All speed controls are in "auto" mode.
- Records showing calibration was performed, what offsets or control system calibration values were used, and documentation of the instrumentation used for calibration.

Acceptance Criteria

- The target condensing temperature is reset in response to ambient dry-bulb temperature, by using a temperature difference (TD) between the condensing temperature and the ambient dry-bulb temperature.
- The condenser fan speed is continuously variable, and the condenser fans are controlled in unison – varying the speed of all fans serving a common condenser loop at the same time.