



California Energy Commission

Title: Data Center Load Forecasts, 2024 - 2040

Presenter: Jenny Chen, Taylor Harms, Energy Assessment Division

Date: 10/21/2024



Agenda

1. Data received and methodology
2. Forecasts for two scenarios



Definitions

- **Annual Load Factor**
 - Total consumption (kWh) throughout the year \div (peak load * 8760 hours)
- **Average Demand / Load**
 - Load averaged over 8760 hours of the year
- **Installed Capacity/Nameplate Capacity**
 - Full load of the facility
- **Method of Service (MOS) Study**
 - Type of service that utilities provide to new and existing customers requesting to connect load at 66 kV or higher. It addresses all technical requirements of the customer facility.
- **Peak Demand / Load**
 - Highest level of power consumption experienced by the system during a specific timeframe (“max demand”)
- **Power Usage Effectiveness (PUE)**
 - Ratio of total facility source energy (including IT source energy such as servers) to IT source energy. The closer the PUE is to 1.0, the more efficient the server facility.
 - (e.g.,) PUE of 1.25 means that the facility must draw 5 MW of electricity for each 4 MW of power consumed by servers.
- **Utilization Factor (UF)**
 - Percentage of installed or nameplate capacity at which data center operates, based on historical AMI data



Assumptions

Scenario 1:


- Includes all projected data-center projects and known loads.
- For both scenarios 1 and 2, apply ramp rate of 149% annually, until estimated peak load of projected facility is reached.

Scenario 2:

- All reported projects and known loads are accounted for, **except:**
 1. 50% of PG&E projected incremental capacity over 2025 – 2037,
 2. Pre-MOS projects in SCE territory,
 3. One project application in City of San Jose.




Peak Demand – Scenarios 1 and 2



Source: CEC Staff (with data inputs from PG&E, Palo Alto, SVP, San Jose, SCE)



Consumption – Scenarios 1 and 2



Source: CEC Staff (with data inputs from PG&E, Palo Alto, SVP, San Jose, SCE)



Data Received & Methodology



Data Received and Methods

Estimated Peak Load, using Assumptions from Existing Data Centers

SCE	<ul style="list-style-type: none">• Peak demand of planned data centers to be served at the distribution-level from 2024 - 2028,• Installed capacity of planned data centers at the sub-transmission level
PG&E	<ul style="list-style-type: none">• Projections of incremental installed capacity from 2025 – 2037, based on customer-provided ramping schedule
City of San Jose	<ul style="list-style-type: none">• Received start dates and total capacity for potential data center projects.

Utility-provided Data

SVP	<ul style="list-style-type: none">• Annual peak demand for SVP system under 1-in-2 weather scenario.• Broke out peak demand for data centers.
City of Palo Alto	<ul style="list-style-type: none">• Annual peak demand for City of Palo Alto system under 1-in-2 weather scenario.• Broke out peak demand for data centers.



Estimating Peak Load of Data Centers

Based on historical load of 60+ data centers in SVP territory:

1. Demand of either new or existing project requests assumed to be 5.0 MW in Year 0,
2. Year-0 demand ramped up year over year (YoY) 149% from Year 0 – 5; 113% from Year 6 – 10.
3. Peak load of data center: ~67% of nameplate capacity
4. Efficient data centers have relatively similar total facility source energy to IT source energy
 - Power Usage Effectiveness (PUE) ~1.2


Example:

Data Center Peak Load Estimate (MW) = IT load or installed capacity (MW) * UF of 67% * PUE

Source: Silicon Valley Power (SVP). Data Center Load Estimation Data & Methods. SVP Engineering Division. Sep 11, 2024.




Peak Data Center Demand (Scenario 1):



Source: CEC staff (with data inputs from PG&E, Palo Alto, SVP, San Jose, SCE)




Annual Consumption (Scenario 1):



Source: CEC staff (with data inputs from PG&E, Palo Alto, SVP, San Jose, SCE)




Peak Data Center Demand (Scenario 2):



All reported projects and known loads are accounted for, **except**: (1) 50% of PG&E projected incremental capacity over 2025 – 2037, (2) pre-MOS projects in SCE territory, (3) one reported project in City of San Jose.



Annual Consumption (Scenario 2):



All reported projects and known loads are accounted for, **except**: (1) 50% of PG&E projected incremental capacity over 2025 – 2037, (2) pre-MOS projects in SCE territory, (3) one reported project in City of San Jose.

Source: CEC staff (with data inputs from PG&E, Palo Alto, SVP, San Jose, SCE)



Sources for Benchmarking

- “US data center demand is forecast to grow by some **10 percent** a year until 2030.”
 - **Source:** [McKinsey & Co. *Investing in the rising data center economy*. Exhibit 1. Jan 17, 2023.](#)
- “PG&E currently has ~2,300 MW of applications for data center capacity (as of Oct 2024).”
 - **Source:** [Nelli, Daniel, et al. “Forecasting Electric System Impacts of New Large Loads: Challenges and Opportunities.” Slide 2 \(Key Messages\). May 16, 2024.](#)
- Range of projections for new US data center load growth: **approximately 9 – 16%**
 - **Source:** [Energy + Environmental Economics \(E3\). Figure ES-2. “Load Growth is Here to Stay, but Are Data Centers?” Page 2. July 2024.](#)



Estimating Average Load Data Centers

Based on historical load of 60+ data centers in SVP territory:

1. Demand of either new or existing project requests assumed to be 5.0 MW in Year 0,
2. Year-0 demand ramped up year over year (YoY) 149% from Year 0 – 5; 113% from Year 6 – 10.
3. Peak load of DC: ~67% of nameplate capacity
4. Efficient data centers have relatively similar total facility source energy to IT source energy
 - Power Usage Effectiveness (PUE) ~1.2
5. Multiply estimated peak demand by load factor (LF) of 79% to derive average load.

Example:

Data Center Average Load Estimate (MW) = IT Load (MW) * UF of 67% * PUE * Annual LF

Source: Silicon Valley Power (SVP). Data Center Load Estimation Data & Methods. SVP Engineering Division. Sep 11, 2024.



Questions for Stakeholder Feedback

- Power Usage Effectiveness (PUE): Currently using 1.2. Should it be higher for planned data centers in SCE territory? If so, how much higher?
- How likely are projections to be realized, given current and future rate environments?
- Are there other utilities with growing data-center load that should be considered?
- Which scenario is more reflective of future data center load? Please provide your justifications.



Q and A