

**CERTIFICATE OF COMPLIANCE**

This form is used to document any process systems that are within the scope of the permit application and are demonstrating compliance with mandatory requirements in §120.6/ §160.7, or prescriptive requirements in §140.9. This compliance document is used for newly constructed, addition and alteration projects.

Project Name:	Enforcement Agency:
Dwelling Address:	Permit Number:
City and Zip Code:	Date Permit Issued:

A. GENERAL INFORMATION

01	Project Location (city)		04	Total Conditioned Floor Area	
02	Climate Zone		05	Total-Unconditioned Floor Area	
03	Occupancy Types Within Project:		06	# of Stories (Habitable Above Grade)	
☐	Office	☐	Retail	☐	Warehouse
☐	Hotel/ Motel	☐	School or Classroom	☐	Healthcare facility
☐	High-Rise Residential	☐	Relocatable Public School	☐	All Other Occupancy Types
☐	Auditorium	☐	Library	☐	Restaurant
☐	Convention Center	☐	Medical Office Bldg/ Clinic	☐	Theater
☐	Commercial Industrial	☐	Data Center	☐	Gymnasium
				☐	Grocery
				☐	Financial Institution
				☐	Unleased Tenant Space
				☐	Parking Garage
				☐	Religious Facility
				☐	Support Area

Alert! Healthcare Facilities do not have to meet the elevator, commercial kitchen, or lab exhaust requirements under Title 24, Part 6 and therefore are not documented on the NRCC-PRC-E. The corresponding tables (K, N, O) say "This section does not apply" when healthcare facility has been chosen as an occupancy within Table A. Systems serving these spaces shall meet the requirements of the Appliance Efficiency Regulations for walk-in coolers or freezers contained in the Appliance Efficiency Regulations (California Code of Regulations, Title 20, Sections 1601 through 1608).

**B. PROJECT SCOPE**

This table includes process systems that are within the scope of the permit application and are demonstrating compliance with mandatory requirements in §120.6/§160.7 or prescriptive requirements in §140.9.

My project consists of (check all that apply):

01		02	
☐	Refrigerated Spaces <3,000 ft ² Total (no Title 24, Pt 6 requirements)	☐	Escalator & Moving Walkway Speed Controls (mandatory §120.6(g))
☐	Refrigerated Spaces ≥3,000 ft ² Total (mandatory §120.6(a))	☐	Controlled Environment Horticulture (mandatory §120.6(h)) ¹
☐	Food/Beverage Stores > 8,000ft ² cfa (mandatory §120.6(b))	☐	New Steam Traps (mandatory §120.6(i))
☐	Enclosed Parking Garage Exhaust ≥ 10,000 cfm (mandatory §120.6(c))	☐	Computer Rooms (mandatory §120.6(j) & prescriptive §140.9(a)) ¹
☐	Newly Installed Process Boilers (mandatory §120.6(d))	☐	Commercial Kitchen Ventilation/Exhaust (prescriptive §140.9(b)) ¹
☐	Compressed Air Systems Combined HP ≥ 25 (mandatory §120.6(e))	☐	Laboratory Exhaust/Factory Exhaust & Fume Hood (prescriptive §140.9(c)) ¹
☐	Elevator Lighting & Ventilation Controls (mandatory §120.6(f)/§160.7)		

¹ FOOTNOTE: These building features can comply using the performance method. If using the performance method for these features, compliance should be demonstrated on the NRCC-PRF-E compliance document.

Alert! Refrigerated Warehouses and refrigerated spaces that are less than 3,000 square feet do not have requirements under Title 24, Part 6 and therefore are not documented on the NRCC-PRC-E. Systems serving these spaces shall meet the requirements of the Appliance Efficiency Regulations for walk-in coolers or freezers contained in the Appliance Efficiency Regulations (California Code of Regulations, Title 20, Sections 1601 through 1608).

**C. COMPLIANCE RESULTS**

Results in this table are automatically calculated from data input and calculations in Tables F through R.

Note: If any cell on this table says "COMPLIES with Exceptional Conditions" refer to Table D. Exceptional Conditions for guidance or see the applicable Table referenced below.

01	02	03	04	05	06	07	08	09	10	11	12	13
Refrigerated Warehouse/ Space §120.6(a)	Commercial Refrigeration §120.6(b)	Parking Garage Exhaust §120.6 (c)	Process Boilers §120.6(d)	Compressed Air Systems §120.6(e)	Elevators §120.6(f)/ §160.7	Escalators & Moving Walkways §120.6 (g)	Computer Rooms §140.9 (a)	Commercial Kitchens §140.9(b)	Laboratory/ Factory Exhaust §140.9(c)	Controlled Environment Horticulture §120.6(h)	Steam Traps §120.6(i)	Compliance Results
(See Table F)	(See Table G)	(See Table H)	(See Table I)	(See Table J)	(See Table K)	(See Table L)	(See Table M)	(See Table N)	(See Table O)	(See Table P)	(See Table Q)	
☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ COMPLIES ☐ COMPLIES WITH EXCEPTIONAL CONDITIONS" ☐ DOES NOT COMPLY

D. EXCEPTIONAL CONDITIONS

This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

--

E. ADDITIONAL REMARKS

This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

--

**F. REFRIGERATED WAREHOUSES/SPACES**

This table includes all refrigerated warehouses > 3,000ft² and refrigerated spaces with a sum total of > 3,000 ft² served by the same refrigeration system. The inputs within Table F are used to demonstrate compliance with the requirements of §120.6(a) and §120.3.

Warehouse Exterior Surface Insulation

01	☐	Exterior surfaces of refrigerated warehouses/spaces are specified to be insulated at least to the R-values in TABLE 120.6-A-1 (see below) per §120.6:	
TABLE 120.6-A REFRIGERATED WAREHOUSE/SPACE INSULATION			
Space	Surface		Minimum R-Value
Freezers	Roof/ Ceiling		40
	Wall		36
	Floor		35
	Floor with all heating from productive refrigeration capacity ¹		20
Coolers	Roof/ Ceiling		28
	Wall		28

Under slab Heating

01	02
Room ID/ Description	Compliance Method §120.6(a)2

Fan Powered Evaporators

01	02	03	04	05	06	07	08
Name or Item Tag	Fan Motor Efficiency §120.6(a)3A			Fan Controls §120.6(a)3B & §120.6(a)3C		Evaporator Efficiency §120.6(a)3D & §120.6(a)3E	
	HP	Phase	Type or Efficiency	Evaporator Fans Served By	Compliance Method	Compliance Method	Applied Static Pressure Drop

**Condensers**

01	Indicate condenser types included in the project: ¹	☐ Air-Cooled (new only)	☐ Evaporative-cooled (new only)	☐ Water-cooled (new only)	☐ Adiabatic (new only)	☐ Altered/replacement or existing condensers only

¹ FOOTNOTE: Altered/replacement or existing condensers do not have Title 24, Part 6 requirements.

Air-Cooled Condensers

02	03	04	05	06	07	08	09	10	11
Name or Item Tag	Condenser Location	Variable Speed Control §120.6(a)4D	Temp Setpoint Controls §120.6(a)4E	Design Condensing Temperatures §120.6(a)4B	Condenser Efficiency §120.6(a)4G			Fin Density §120.6(a)4H	Complies?
					Refrigerant Type	Minimum Efficiency Required (Btuh/W)	Efficiency per Design (Btuh/W)		

Water-Cooled and Evaporative-Cooled Condensers

02	03	04	05	06	07	08	09	10
Name or Item Tag	Condenser Location	Variable Speed Control §120.6(a)4D	Temp Setpoint Controls §120.6(a)4E	Design Condensing Temperatures §120.6(a)4A	Condenser Efficiency §120.6(a)4G			Complies?
					THR Capacity	Minimum Efficiency Required (Btuh/W)	Efficiency per Design (Btuh/W)	

Adiabatic Condensers

02	03	04	05	06	07	08	09
Name or Item Tag	Variable Speed Control §120.6(a)4D	Temp Setpoint Controls §120.6(a)4E	Design Condensing Temperatures §120.6(a)4C	Condenser Efficiency §120.6(a)4G			Complies?
				Refrigerant Type	Minimum Efficiency Required (Btuh/W)	Efficiency per Design (Btuh/W)	

**Compressors**

01	Indicate compressor types included in the project: ¹	☐ Compressor (new only)	☐ Altered or existing compressors only
02	03	04	05
Name or Item Tag	Design Condensing Temp §120.6(a)5A&B	Variable Speed Control §120.6(a)5C	Variable Volume Ratio §120.6(a)5D

¹ FOOTNOTE: Altered/replacement or existing compressors do not have Title 24, Part 6 requirements.

Infiltration Barriers and Automatic Door Closers

01	02	03
Room ID/ Description	Infiltration Compliance Method §120.6(a)6	Door Closure Compliance Method §120.6(a)9

Transcritical CO₂ Fan-powered Gas Coolers

01	Indicate gas cooler types included in the project: ¹	☐ Air-cooled (new only)	☐ Adiabatic (new only)	☐ Altered/replacement or existing gas coolers only	☐ No Transcritical CO ₂ refrigeration/ no fan-powered gas coolers
----	---	--	---	---	---

¹ FOOTNOTE: Altered/replacement or existing gas-coolers do not have Title 24, Part 6 requirements.

Alert! Air-cooled gas coolers are prohibited in climate zones 9-15 per §120.6(a)8A.

02	03	04	05	06	07	08	09
Name or Item Tag	Design Leaving Gas Temperature §120.6(a)8B&C	Variable Speed Control §120.6(a)8D	Gas Cooler Pressure Controls §120.6(a)8E&F	Design Condensing Temperatures §120.6(a)8G	Condenser Efficiency §120.6(a)8H		Complies?
					Minimum Efficiency Required (Btuh/W)	Efficiency per Design (Btuh/W)	

**Mandatory Pipe Insulation All Occupancies - §120.3**

System Name:		User Input	
	Yes	Not Applicable	Requirement
01	☐	☐	For systems serving nonresidential spaces, pipe insulation for the following applications is specified to comply with Table 120.3-A1 or or Table 120.3-A2 (see below) per §120.3: - Recirculating system piping, including supply and return piping of the water heater - The first 8 ft of hot and cold outlet piping, including between storage tank and heat trap, for a nonrecirculating storage system - Pipes that are externally heated
02	☐	☐	Per §120.3(b), pipe and appurtenance insulation shall be protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind. Protection shall include: - Insulation exposed to weather shall be installed with a cover suitable for outdoor service - Pipe insulation buried below grade must be installed in a water proof and non-crushable casing or sleeve. - Pipe insulation covering chilled water piping and refrigerant suction piping located outside the conditioned space shall include, or be protected by, a Class I or Class II vapor retarder. All penetrations and joints shall be sealed.

G. COMMERCIAL REFRIGERATION

This table includes all refrigeration equipment being utilized for refrigerated display cases or walk in coolers/freezers, located in a retail food/beverage store with 8,000 ft or more of conditioned floor area. The inputs within Table G are used to demonstrate compliance with the requirements of §120.6(b) and §120.3.

01	Indicate components of the refrigeration system included in the project:	☐ Condensers	☐ Compressors	☐ Refrigerated Display Cases	☐ Heat Recovery	☐ Transcritical CO2 Fan-powered Gas Coolers	☐ Pipe Insulation
----	--	--	---	--	---	---	---

**Condensers Serving Refrigeration System**

01	☐	The project includes replacement condensers that meet the following conditions: - attached compressor system Total Heat of Rejection does not increase and; - less than 25 percent of both the attached compressors and the attached display cases are new.						
02	☐	All equipment, appliances and components serving the refrigeration system have been certified by the Energy Commission as compliant with Title 20 and listed in the Modernized Appliance Efficiency Database System. ¹						
03	04	05	06	07	08	09	10	11
Name or Item Tag	Condenser Type	Variable Speed Control §120.6(b)1A	Temp Setpoint Controls §120.6(b)1B, C, D, F	Condenser Specific Efficiency §120.6(b)1G			Fin Density §120.6(b)1H	Complies?
				Specific Efficiency Compliance Method	Minimum Specific Efficiency Required (Btuh/W)	Specific Efficiency per Design (Btuh/W)		

¹ FOOTNOTE: Compliant equipment may be found in the Modernized Appliance Efficiency Database System (MAEDbS) on the Energy Commission website:

Compressors and Condensing Units Serving Refrigeration System

01	☐	All compressors being used for the refrigeration system are being reused.			
02		03		04	05
Name or Item Tag		Saturation suction temperature control (SST) §120.6(b)2A		Liquid Subcooling Compliance Method §120.6(b)2B	Transcritical CO ₂ Min Condensing Temp §120.6(b)2C

**Refrigerated Display Cases**

01	Design includes lighting controls for refrigerated display cases including illuminated glass doors of walk-in coolers/freezers per §120.6(b)3. Select method(s) being utilized below:	
02	☐	Timeclock: Turn off lighting power automatically during non-business hours
03	☐	Motion Sensor: Reduce lighting power by at least 50% within 30 minutes after the nearby area is vacated

Heat Recovery of Refrigeration System

01	☐	All HVAC/ refrigeration systems are being reused.
02		
Compliance Method ¹ §120.6(b)4		

¹ FOOTNOTE: Authority Having Jurisdiction may ask for calculations to confirm compliance.

Transcritical CO₂ Fan-powered Gas Coolers

01	Indicate gas cooler types included in the project: ¹	☐ Air-cooled (new only)	☐ Adiabatic (new only)	☐ Altered/replacement or existing gas coolers only	☐ No Transcritical CO ₂ refrigeration/ no fan-powered gas coolers
----	---	--	---	---	---

¹ FOOTNOTE: Altered/replacement or existing gas-coolers do not have Title 24, Part 6 requirements.

Alert! Air-cooled gas coolers are prohibited in climate zones 10-15 per §120.6(b)5A.

02	03	04	05	06	07	08	09
Name or Item Tag	Design Leaving Gas Temperature §120.6(b)5B&C	Variable Speed Control §120.6(b)5D	Gas Cooler Pressure Controls §120.6(b)5E&F	Design Condensing Temperatures §120.6(b)5G	Condenser Efficiency §120.6(b)5H		Complies?
					Minimum Efficiency Required (Btuh/W)	Efficiency per Design (Btuh/W)	

**Mandatory Pipe Insulation All Occupancies - §120.3**

System Name:		User Input	
	Yes	Not Applicable	Requirement
01	☐	☐	For systems serving nonresidential spaces, pipe insulation for the following applications is specified to comply with Table 120.3-A1 or or Table 120.3-A2 (see below) per §120.3: - Recirculating system piping, including supply and return piping of the water heater - The first 8 ft of hot and cold outlet piping, including between storage tank and heat trap, for a nonrecirculating storage system - Pipes that are externally heated
02	☐	☐	Per §120.3(b), pipe and appurtenance insulation shall be protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind. Protection shall include: - Insulation exposed to weather shall be installed with a cover suitable for outdoor service - Pipe insulation buried below grade must be installed in a water proof and non-crushable casing or sleeve. - Pipe insulation covering chilled water piping and refrigerant suction piping located outside the conditioned space shall include, or be protected by, a Class I or Class II vapor retarder. All penetrations and joints shall be sealed.

**H. ENCLOSED PARKING GARAGE EXHAUST**

This table includes all newly installed mechanical ventilation systems which serve parking garages and have a design exhaust rate greater than or equal to 10,000 cfm. The inputs of Table H are used to demonstrate compliance with the requirements of §120.6(c).

	Yes	Exceptions				
01	☐	Garage is expected to have vehicles with non-gasoline combustion engines for > 20% of the parked vehicles per Exception 1 to §120.6(c)				
02	☐	Project scope includes an addition or alteration to an existing garage where < 10,000 cfm of new exhaust capacity is being added Exception 2 to §120.6(c)				
	Yes	Requirements				
03	☐	Exhaust fan control modulates airflow rates $\leq$ 50% design capacity when contaminant levels are maintained per §120.6(c)1				
04	☐	Fan control or device allows fan motor demand $\leq$ 30% design wattages at 50% of design airflow per §120.6(c)2				
05	☐	Design includes monitoring CO with a sensor density $\geq$ 1 per 5,000 ft ² per §120.6(c)3				
06	☐	CO sensors are located in the highest expected concentration locations, with at least two per proximity zone per §120.6(c)3				
07	☐	Design CO sensor setpoint $\leq$ 25 ppm per §120.6(c)4				
08	☐	Occupied garage design maintains negative pressurization per §120.6(c)6				
09	☐	Designed occupied total ventilation rate $\geq$ 0.15 CFM/ ft ² §120.6(c)5				
		10	11	12	13	14
		Fan Name	Parking Garage Area (ft ²)	Ventilation Fan Rate (CFM)	Minimum Ventilation Rate Required (CFM)	Compliant?
15	Indicate where in the construction documents these requirements can be verified					

**I. PROCESS BOILER**

This table includes all process boilers within the scope of the permit application to demonstrate compliance with the requirements of §120.6(d).

01	02	03	04	05
Name or Item Tag	Rated Input Capacity per Boiler (Btu/h)	Combustion Air Shutoff §120.6(d)1	Fan Controls §120.6(d)2	Stack Design and Controls §120.6(d)3

J. COMPRESSED AIR SYSTEMS

This table includes all new or altered compressed air systems with a combined HP of 25 or greater. The inputs within Table J are used to demonstrate compliance with the requirements of §120.6(e).

01	02	03	04	05	06
System Name/ Description	Trim Compressor Compliance Method §120.6(e)1	Controls §120.6(e)2	Monitoring §120.6(e)3	Compressed Air Piping > 50 Adjoining ft in Length §120.6(e)5	
				Service Line Size ¹	Section Average Velocity or Total Pressure Drop

**K. ELEVATOR LIGHTING AND VENTILATION**

This table includes all elevator lighting and ventilation systems within the scope of the permit application to show compliance with the requirements of §120.6(f)/ §160.7.

01	02	03	04	05	06	07	08	
Lighting §120.6(f)1 & §120.6(f)3 / §160.7								
Elevator Name or Item Tag	Elevator Area (ft2)	Fixture Name or Item Tag	Watts per Fixture	Number of Fixtures	Power per Design (W)	Maximum Power Allowed ¹ (W)	Controls	
		Total Design Watts						
09	10	11	12	13	14	15		
Name or Item Tag	Conditioned Cab?	Ventilation §120.6(f)2 & §120.6(f)3/ §160.7						
		Fan Power (Watts)	Design Airflow (CFM)	Design Watts per CFM	Maximum Watts per CFM Allowed	Controls		
16	Indicate where in the construction documents these requirements can be verified							

¹ FOOTNOTE: 0.6 watts per ft2 allowed per §120.6(f)1. Interior signal lighting and display lighting not included in power density calculation.

L. ESCALATORS AND MOVING WALKWAYS SPEED CONTROLS

This table includes all escalators and moving walkway controls necessary to demonstrate compliance with the requirements of §120.6(g).

01
Compliance Method §120.6(g)

**M. COMPUTER ROOM SYSTEM SUMMARY**

This table contains all computer room systems to demonstrate compliance with mandatory requirements of §120.6(j) and the prescriptive requirements of §140.9(a). Prescriptive requirements only apply to computer rooms with a power density greater than 20 W/ft².

Computer Room HVAC

01	02	03	04	05	06	07	08	09
Computer Room Name/ ID	Economizer Compliance Method §140.9(a)1	Reheat §120.6(j)1	Humidification §120.6(j)2	Fan Power §140.9(a)2			Fan Controls §120.6(j)3	Air Containment §140.9(a)3
				Sensible Cooling Capacity ¹ (kBtuh)	Total Fan System Power per Design (Watts)	Maximum Fan System Power Allowed (Watts)		

¹ FOOTNOTE: Refers to net sensible cooling capacity at design conditions.

Computer Room Uninterruptible Power Supply (UPS)

01	02	03	04	05	06
Computer Room Name/ ID	Alternating Current Output UPS Compliance Method §140.9(a)4	Type of UPS	UPS Rated Output Power (W)	Minimum Efficiency Required Table 140.9-B	Design Efficiency Specified

**N. COMMERCIAL KITCHEN EXHAUST AND VENTILATION**

This table contains all new or replacement hoods being installed within the scope of the permit application. The inputs within Table N are used to demonstrate compliance within §140.9(b).

Kitchen Ventilation §140.9(b)2

01	☐	Existing kitchen hoods not being replaced as part of an addition or alteration (do not need to meet requirements)
Requirements		
02	Replacement Air to Hood Compliance Method §140.9(b)1A	
03	Mechanically cooled or heated makeup air delivered to any space with a kitchen hood is designed per 140.9(b)2A to not exceed the greater of:	
04	Location that is supplying transfer air:	
05	The kitchen /dining facility has a total Type I and Type II kitchen hood exhaust airflow rate > 5000 cfm and is designed to have one of the following per 140.9(b)2B:	

Kitchen Exhaust: Airflow Rate §140.9(b)1B

01	Kitchen Name or Tag		Compliance Method per §140.9(b)1B			
02	03	04	05	06	07	08
Name or Item Tag	Hood Type ¹	Hood Style	Hood Length (ft)	Equipment Duty	Design Hood Exhaust Rate (CFM)	Max Hood Exhaust Rate Allowed (CFM)

¹ FOOTNOTE: Type II hoods do not have a max hood exhaust air rate per Part 6 §140.9(b)1B.

**Electric Ready Commercial Kitchens §120.6(k)**

This table includes electrical system requirements that must be met when using gas or propane in newly constructed commercial kitchens to demonstrate compliance with §120.6(k).

01	Newly constructed commercial kitchen:	☐ Uses gas or propane fuel.	☐ All-electric kitchen.	☐ Is within a healthcare facility.

Mandatory requirements for commercial kitchens

	Yes	Requirement
02	☐	Includes a dedicated branch circuit wiring and outlet accessible to cookline appliances and meets the following requirements: a) The branch circuit conductors shall be rated at 50 amps minimum. b) The electrical service panel shall have a minimum capacity of 800 connected amps.
03	☐	The electrical service panel shall be sized to accommodate an additional either 208v or 240v 50-amp breaker.

O. LABORATORY AND FACTORY EXHAUST AND FUME HOODS

This table includes all laboratory and factory exhaust and fume hoods within the scope of the permit application. The inputs within Table O are used to demonstrate compliance with the requirements within §140.9(c).

01	02	03	04	05	06	07
Zone/System or Item Tag	Airflow Reduction Compliance Method §140.9(c)1	Transfer Air Compliance Method §140.9(c)2	Exhaust Fan System Power Compliance Method §140.9(c)3	Hood Sash Closure Compliance Method §140.9(c)4	Reheat Limitation Compliance Method §140.9(c)5	Exhaust Air Heat Recovery Compliance Method §140.9(c)6

**FAN SYSTEMS**

This table is used to demonstrate compliance with prescriptive requirements found in §140.4(c), §140.4(e) §140.4(m), §170.2(c)3 & §170.2(c)4A for fan systems. Fan systems serving only process loads are exempt from these requirements and do not need to be included in Table H.

System Name:		Quantity	Fan System Status:	System Zoning		Fan System Airflow(cfm)		Site Elevation			
01	02	03	04		05	06	07	08	09	10	11
Fan Name or Item Tag	Fan Type	Qty	Components		Airflow Through Component (%)	Water Gauge (w.g)	Component Allowance	Fan Allowance (watt/cfm) ³	Design Electrical Input Power Method	Motor Nameplate Horsepower	Design Electrical Input Power (kW)
(fan 1)	dropdown		Dropdown (component 1)				component 1 allowance	Fan Allowance	Dropdown	Dropdown	
			(component2)				component 2 allowance				
(fan 2)	dropdown		Dropdown (component 1)				component 1 allowance	Fan Allowance	Dropdown	Dropdown	
			(component2)				component 2 allowance				

Exhaust Systems 140.9(c)3D

This table includes all laboratory and factory exhaust and fume hoods within the scope of the permit application. The inputs within Table O are used to demonstrate compliance with the requirements within §140.9(c)3D.

01	02	03	04	05	06
Exhaust System Name or Item Tag	Sum of occupied minimum circulation rates for spaces served	Minimum Acceptable Exhaust Airflow Rate	Exhaust Fan System Airflow (cfm)	Design Exhaust Fan System Power (watts)	Variable Speed Controls per 140.9(c)3D

**P. CONTROLLED ENVIRONMENT HORTICULTURE**

This table documents compliance with mandatory controlled environment horticulture requirements of §120.6(h).

Space Conditioning for Plant Production §120.6(h)1 and 4.

01	02	03
System Name/ Description	Dehumidification System for Indoor Grow CEH Compliance Method §120.6(h)1	HVAC System Compliance Method §120.6(h)4

Lighting and Electrical Systems §120.6(h)2 and 5

01	02	03	04	05	06
System Name/ Description	Indoor or Greenhouse Space	Photosynthetic Photon Efficacy (PPE) §120.6(h)5A	Lighting Controls §120.6(h)5B&C		Electrical System Monitoring Capability §120.6(h)2
			Timeswitch	Multilevel	

Greenhouse Envelopes

This table documents mandatory requirements for envelope assemblies in conditioned greenhouses. Envelope assemblies in Indoor Grow Facilities should be documented on the NRCC-ENV for prescriptive compliance or NRCC-PRF for performance compliance.

01	02	03	04
Tag/Plan Detail ID	Assembly Type	Non-Opaque Envelope Compliance Method §120.6(h)4B	Opaque Envelope Compliance Method §120.6(h)4A

**Q. STEAM TRAPS IN INDUSTRIAL FACILITIES**

This table documents compliance with mandatory steam trap requirements of §120.6(i). Steam traps with operating pressure greater than 15 psig and a total combined connected boiler input rating greater than 5 Million Btu/hr shall meet the requirements. Steam trap replacements or steam traps added to support replacement process equipment do not have requirements under Title 24, Part 6 and are not included in the table below.

01	02	03
Fault Detection Diagnostics Monitoring		Strainer Installation
Update Interval	Alarm Display	

S. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections have been made based on information provided in this document. If any selections have been changed by the permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and can be found online.

YES	NO	Form/Title	Field Inspector	
			Pass	Fail
☐	☐	NRCI-PRC-E Covered Process	☐	☐

**T. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE**

Selections have been made based on information provided in this document. If any selections have been changed by the permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP). For more information visit:

<http://www.energy.ca.gov/title24/attcp/providers.html>.

YES	NO	Form/Title	Field Inspector	
			Pass	Fail
☐	☐	NRCA-PRC-01-F Compressed Air Systems	☐	☐
☐	☐	NRCA-PRC-02-F Kitchen Exhaust	☐	☐
☐	☐	NRCA-PRC-03-F Garage Exhaust	☐	☐
☐	☐	NRCA-PRC-04-F Refrigerated Warehouses - Evaporator Fan Motor Controls	☐	☐
☐	☐	NRCA-PRC-05-F Refrigerated Warehouses - Evaporative Condenser Controls	☐	☐
☐	☐	NRCA-PRC-06-F-Refrigerated Warehouses - Air Cooled Condenser Controls	☐	☐
☐	☐	NRCA-PRC-16-F-Refrigerated Warehouses - Adiabatic Condenser Controls	☐	☐
☐	☐	NRCA-PRC-07-F-Refrigerated Warehouses - Variable Speed Compressor	☐	☐
☐	☐	NRCA-PRC-08-F Refrigerated Warehouses - Electric Resistance Underslab Heating System	☐	☐
☐	☐	NRCA-PRC-12-F Elevator Lighting & Ventilation Controls	☐	☐
☐	☐	NRCA-PRC-13-F Escalators & Moving Walkways Speed Controls	☐	☐
☐	☐	NRCA-PRC-14-F Lab Exhaust Ventilation Systems	☐	☐
☐	☐	NRCA-PRC-15-F Fume Hood Automatic Sash Closure Systems	☐	☐
☐	☐	NRCA-PRC-17-F Transcritical CO ₂ Refrigeration Systems	☐	☐
☐	☐	NRCA-PRC-18-F Steam Traps	☐	☐

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/AEA/ECC Certification Identification (if applicable):
City/State/Zip:	Phone:

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I understand that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building and shall be made available to the enforcement agency for all applicable inspections. I will take the necessary steps to fulfill this requirement.
6. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy. I will take the necessary steps to fulfill this requirement.

Responsible Designer Name:	Responsible Designer Signature:
Company :	Date Signed:
Responsible Person Scope:	
Address:	License:
City/State/Zip:	Phone:

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 1 of 9)

A. General Information

1. Enter the City the project is located in.
2. Climate Zone: Select from dropdown.
3. Select the applicable Occupancy Types within the Project.
4. Enter the Total Conditioned Floor Area.
5. Enter the Total Unconditioned Floor Area.
6. Enter the Number of Stories Above Grade.

B. Project Scope

- 1-2. Select the process systems that are included in the project.

C. Compliance Results

1. Results in this table are automatically calculated from data input and calculations in Tables F through R.

D. Exceptional Conditions

1. This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. Additional Remarks

1. Enter any notes or comments for the AHJ.

F. Refrigerated Warehouses/Spaces

Warehouse Exterior Surface Insulation

1. Check if the exterior surfaces of refrigerated warehouses/spaces are insulated at least to the R-values in TABLE 120.6-A.

Underslab Heating

1. Enter the Room ID/Description.
2. Compliance Method: Select from dropdown.

Fan Powered Evaporators

1. Enter the Name or Item Tag.
2. Fan Motor Efficiency HP: Select from dropdown.
3. Fan Motor Efficiency Phase: Select from dropdown.
4. Fan Motor Efficiency Type or Efficiency: Select from dropdown.
5. Evaporator Fans Served By: Select from dropdown.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 2 of 9)

6. Compliance Method: Select from dropdown.

Condensers

1. Select the condenser types included in the project.

Air-Cooled Condensers

2. Enter the Name or Item Tag.
3. Condenser Location: Select from dropdown.
4. Variable Speed Control: Select from dropdown.
5. Temp Setpoint Controls: Select from dropdown.
6. Design Condensing Temperatures: Select from dropdown.
7. Refrigerant Type: Select from dropdown.
8. This field is filled out automatically.
9. Enter the Efficiency per Design.
10. Fin Density: Select from dropdown.
11. This field is filled out automatically.

Water-Cooled and Evaporative-Cooled Condensers

2. Enter the Name or Item Tag.
3. Condenser Location: Select from dropdown.
4. Variable Speed Control: Select from dropdown.
5. Temp Setpoint Controls: Select from dropdown.
6. Design Condensing Temperatures: Select from dropdown.
7. THR Capacity: Select from dropdown.
8. This field is filled out automatically.
9. Enter the Efficiency per Design.
10. This field is filled out automatically.

Adiabatic Condensers

2. Enter the Name or Item Tag.
3. Variable Speed Control: Select from dropdown.
4. Temp Setpoint Controls: Select from dropdown.
5. Design Condensing Temperatures: Select from dropdown.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 3 of 9)

6. Refrigerant Type: Select from dropdown.
7. This field is filled out automatically.
8. Enter the Efficiency per Design.
9. This field is filled out automatically.

Compressors

1. Select the compressor types included in the project.
2. Enter the Name or Item Tag.
3. Design Condensing Temperatures: Select from dropdown.
4. Variable Speed Control: Select from dropdown.
5. Variable Volume Ratio: Select from dropdown.

Infiltration Barriers and Automatic Door Closers

1. Enter the Room ID/Description.
2. Infiltration Compliance Method: Select from dropdown.
3. Door Closure Compliance method: Select from dropdown.

Transcritical CO2 Fan-powered Gas Coolers

1. Select the gas cooler types included in the project.
2. Enter the Name or Item Tag.
3. Design Leaving Gas Temperature: Select from dropdown.
4. Variable Speed Control: Select from dropdown.
5. Gas Cooler Pressure Controls: Select from dropdown.
6. Design Condensing Temperatures: Select from dropdown.
7. This field is filled out automatically.
8. Enter the Efficiency per Design.
9. This field is filled out automatically.

G. Commercial Refrigeration

1. Select the components of the refrigeration system included in the project.

Condensers Serving Refrigeration System

- 1-2. Check to verify your project meets the requirements
3. Enter the name or Item Tag.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 4 of 9)

4. Condenser Type: Select from dropdown.
5. Variable Speed Control: Select from dropdown.
6. Temp Setpoint Controls: Select from dropdown.
7. Specific Efficiency Compliance Method: Select from dropdown.
8. This field is filled out automatically.
9. Enter the Specific Efficiency per Design.
10. Enter the Fin Density.
11. This field is filled out automatically.

Compressors and Condensing Units Serving Refrigeration System

1. Check if all compressors being used for the refrigeration system are being reused.
2. Enter the Name or Item Tag.
3. Saturation Suction Temperature Control: Select from dropdown.
4. Liquid Subcooling Compliance Method: Select from dropdown.
5. Transcritical CO2 Min Condensing Temp: Select from dropdown.

Refrigerated Display Cases

1. Static text.
2. Check if timeclock is being utilized.
3. Check if motion sensor is being utilized.

Heat Recovery of Refrigeration System

1. Check if all HVAC/refrigeration systems are being reused.
2. Compliance Method: Select from dropdown.

Transcritical CO2 Fan-powered Gas Coolers

1. Select the gas cooler types included in the project.
2. Enter the Name or Item Tag.
3. Design Leaving Gas Temperature: Select from dropdown.
4. Variable Speed Control: Select from dropdown.
5. Gas Cooler Pressure Controls: Select from dropdown.
6. Design Condensing Temperatures: Select from dropdown.
7. This field is filled out automatically.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 5 of 9)

8. Enter the Efficiency per Design.
9. This field is filled out automatically.

H. Enclosed Parking Garage Exhaust

- 1-9. Check Yes to verify your project meets the requirements.
10. Enter the Fan Name.
11. Enter the parking Garage Area.
12. Enter the Ventilation Fan Rate.
13. This field is filled out automatically.
14. This field is filled out automatically.

I. Process Boiler

1. Enter the Name or Item Tag.
2. Rated Input Capacity per Boiler: Select from dropdown.
3. Combustion Air Shutoff: Select from dropdown.
4. Fan Controls: Select from dropdown.
5. Stack Design and Controls: Select from dropdown.

J. Compressed Air Systems

1. Enter the System Name/Description.
2. Trim Compressor Compliance Method: Select from dropdown.
3. Controls: Select from dropdown.
4. Monitoring: Select from dropdown.
5. Service Line Size: Select from dropdown.
6. Section Average Velocity: Select from dropdown.
7. Total Pressure Drop: Select from dropdown.

K. Elevator Lighting and Ventilation

1. Enter the Elevator Name or Item Tag.
2. Enter the Elevator Area.
3. Enter the Fixture Name or Item Tag.
4. Enter the Watts per Fixture.
5. Enter the Number of Fixtures.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 6 of 9)

6. This field is filled out automatically.
7. This field is filled out automatically.
8. Controls: Select from dropdown.
9. This field is filled out automatically.
10. Conditioned Cab?: Select from dropdown.
11. Enter the Fan Power.
12. Enter the Design Airflow.
13. This field is filled out automatically.
14. This field is filled out automatically.
15. Controls: Select from dropdown.

L. Escalators and Moving Walkways Speed Controls

1. Compliance Method: Select from dropdown.

M. Computer Room System Summary

Computer Room HVAC

1. Enter the Computer Room Name/ID.
2. Economizer Compliance Method: Select from dropdown.
3. Reheat: Select from dropdown.
4. Humidification: Select from dropdown.
5. Enter the Sensible Cooling Capacity.
6. Enter the Total Fan System Power per Design.
7. This field is filled out automatically.
8. Fan Controls: Select from dropdown.
9. Air Containment: Select from dropdown.

Computer Room Uninterruptible Power Supply (UPS)

1. This field is filled out automatically.
2. Alternating Current Output UPS Compliance Method: Select from dropdown.
3. Type of UPS: Select from dropdown.
4. Enter the UPS Rated Output Power.
5. This field is filled out automatically.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 7 of 9)

6. Enter the Design Efficiency Specified.

N. Commercial Kitchen Exhaust and Ventilation

Kitchen Ventilation

1. Check if the existing kitchen hoods are not being replaced as part of an addition or alteration.
2. Replacement Air to Hood Compliance Method: Select from dropdown.
3. Mechanically cooled or heated makeup air delivered to any space with a kitchen hood is designed: Select from dropdown.
4. Enter the Location that is Supplying Transfer Air.
5. The kitchen /dining facility has a total Type I and Type II kitchen hood exhaust airflow rate > 5000 cfm and is designed to have one of the following: Select from dropdown.

Kitchen Exhaust: Airflow Rate

1. Enter the Kitchen Name or Tag.
Compliance Method: Select from dropdown.
2. Enter the Name or Item Tag.
3. Hood Type: Select from dropdown.
4. Hood Style: Select from dropdown.
5. Enter the Hood Length.
6. Equipment Duty: Select from dropdown.
7. Enter the Design Hood Exhaust Rate.
8. This field is filled out automatically.

O. Laboratory and Factory Exhaust and Fume Hoods

1. Enter the Zone/System or Item Tag.
2. Airflow Reduction Compliance Method: Select from dropdown.
3. Transfer Air Compliance Method: Select from dropdown.
4. Fan Power Compliance Method: Select from dropdown.
5. Hood Sash Closure Compliance Method: Select from dropdown.

P. Controlled Environment Horticulture

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 8 of 9)

Space Conditioning for Plant Production

1. Enter the Space Name/Description.
2. Dehumidification System for Indoor Grow CEH Compliance Method: Select from dropdown.
3. HVAC System Compliance Method: Select from dropdown.

Lighting and Electrical Systems

1. Enter the System Name/Description.
2. Indoor or Greenhouse Space: Select from dropdown.
3. Photosynthetic Photon Efficacy (PPE): Select from dropdown.
4. Timeswitch Controls: Select from dropdown.
5. Multilevel Controls: Select from dropdown.
6. Electrical System Monitoring Capability: Select from dropdown.

Opaque and Non-Opaque Envelopes

1. Enter the Tag/Plan Detail ID.
2. Assembly Type: Select from dropdown.
3. Non-Opaque Envelope Compliance Method: Select from dropdown.
4. Opaque Envelope Compliance Method: Select from dropdown.

Q. Steam Traps in Industrial Facilities

1. Update Interval: Select from dropdown.
2. Alarm Display: Select from dropdown.
3. Strainer Installation: Select from dropdown.

S. Declaration of Required Certificates of Installation

1. Selections have been automatically made based on information provided in this document. If any selections have been changed by the permit applicant, an explanation should be included in Table E. Additional Remarks.

T. Declaration of Required Certificates of Acceptance

1. Selections have been automatically made based on information provided in this document. If any selections have been changed by the permit applicant, an explanation should be included in Table E. Additional Remarks.

CERTIFICATE OF COMPLIANCE – USER INSTRUCTIONS	NRCC-PRC-E
Process Systems	(Page 9 of 9)

Documentation Declaration Statements

1. The person who prepared the NRCC will sign and complete the fields for their name, company (if applicable), address, phone number, certification information (if applicable), date and signature.
2. The person who is assuming responsibility for the project being built to comply with Title 24, Part 6, will complete the fields for their name, company (if applicable), address, phone number, license number (if applicable), date and signature.