



**CALIFORNIA  
ENERGY COMMISSION**



California Energy Commission  
Clean Transportation Program

## **FINAL PROJECT REPORT**

# **Las Gallinas Valley Sanitary District Natural Gas Fueling Infrastructure Installation Project**

**Prepared for: California Energy Commission**

**Prepared by: Las Gallinas Valley Sanitary District**



**Gavin Newsom, Governor**

**July 2019 | CEC-600-2019-034**

# California Energy Commission

Jessica Bernardini P.E.

Steve Whitman

**Primary Author(s)**

Las Gallinas valley Sanitary District

300 Smith Ranch Road

San Rafael, CA 94903

(415) 472-1033

**Agreement Number: ARV-15-038**

Eric VanWinkle

**Commission Agreement Manager**

Elizabeth John

**Office Manager**

**ADVANCED FUELS AND VEHICLE TECHNOLOGIES OFFICE**

Kevin Barker

**Deputy Director**

**FUELS AND TRANSPORTATION**

Drew Bohan

**Executive Director**

## **DISCLAIMER**

This report was prepared as the result of work sponsored by the California Energy Commission (CEC). It does not necessarily represent the views of the CEC, its employees, or the State of California. The CEC, the State of California, its employees, contractors, and subcontractors make no warrant, express or implied, and assume no legal liability for the information in this report; nor does any party represent that the use of this information will not infringe upon privately owned rights. This report has not been approved or disapproved by the CEC nor has the CEC passed upon the accuracy or adequacy of the information in this report.

# **ACKNOWLEDGEMENTS**

The Las Gallinas Valley Sanitary District acknowledges the support of the California Energy Commission and the following district employees who were instrumental in implementing the project:

Michael Cortez, P.E. - District Engineer

Greg Pease - Collection System/Safety Manager

Susan M. McGuire - Administrative Services Manager

# PREFACE

Assembly Bill 118 (Núñez, Chapter 750, Statutes of 2007) created the Clean Transportation Program, formerly known as the Alternative and Renewable Fuel and Vehicle Technology Program. The statute authorizes the California Energy Commission (CEC) to develop and deploy alternative and renewable fuels and advanced transportation technologies to help attain the state's climate change policies. Assembly Bill 8 (Perea, Chapter 401, Statutes of 2013) reauthorizes the Clean Transportation Program through January 1, 2024, and specifies that the CEC allocate up to \$20 million per year (or up to 20 percent of each fiscal year's funds) in funding for hydrogen station development until at least 100 stations are operational.

The Clean Transportation Program has an annual budget of about \$100 million and provides financial support for projects that:

- Reduce California's use and dependence on petroleum transportation fuels and increase the use of alternative and renewable fuels and advanced vehicle technologies.
- Produce sustainable alternative and renewable low-carbon fuels in California.
- Expand alternative fueling infrastructure and fueling stations.
- Improve the efficiency, performance and market viability of alternative light-, medium-, and heavy-duty vehicle technologies.
- Retrofit medium- and heavy-duty on-road and nonroad vehicle fleets to alternative technologies or fuel use.
- Expand the alternative fueling infrastructure available to existing fleets, public transit, and transportation corridors.
- Establish workforce-training programs and conduct public outreach on the benefits of alternative transportation fuels and vehicle technologies.

To be eligible for funding under the Clean Transportation Program, a project must be consistent with the CEC's annual Clean Transportation Program Investment Plan Update. The CEC issued PON-14-608 to provide funding for projects that establish or expand infrastructure necessary to store, distribute and dispense compressed natural gas for use in natural gas vehicles. In response to PON-14-608, the recipient submitted an application which was proposed for funding in the CEC's notice of proposed awards August 12, 2015 and the agreement was executed as ARV-15-038 on January 14, 2016.

# ABSTRACT

This final project report documents the planning, fueling station equipment, specifications, and initial throughput from the installation of a new compressed natural gas fueling system at the Las Gallinas Valley Sanitary District made possible through the California Energy Commission grant ARV-15-038. This report also provides analysis of the six months operational data collected at the station.

The project results show that the installation of the compressed natural gas stations provides a critical support to the Las Gallinas Valley Sanitary District's efforts in phasing out diesel operated trucks and providing a steady supply of compressed natural gas as back-up to the Renewable Natural Gas system at the Waste Water Treatment Plant. The project also supports the Las Gallinas Valley Sanitary District's compressed natural gas fleet.

**Keywords:** California Energy Commission, Las Gallinas Valley Sanitary District, Compressed Natural Gas, Renewable Natural Gas, Waste Water Treatment Plant

Please use the following citation for this report:

Bernardini, Jessica, Steve, Whitman. Las Gallinas Valley Sanitary District. 2019. *Las Gallinas Valley Sanitary District Natural Gas Fueling Infrastructure Installation Project*. California Energy Commission. Publication Number: CEC-600-2019-034.



# TABLE OF CONTENTS

	Page
Acknowledgements .....	i
Preface.....	ii
Abstract .....	iii
Table of Contents.....	v
List of Figures .....	v
List of Tables .....	vi
EXECUTIVE SUMMARY .....	1
CHAPTER 1: Project Introduction .....	3
Background .....	3
Project Description .....	3
CHAPTER 2: Installation and Deployment .....	5
CNG Fueling Infrastructure .....	5
Final Inspection and Testing .....	7
CHAPTER 3: Usage and Data Collection.....	8
Emissions Reductions Calculations.....	9
CHAPTER 4: Observations and Challenges .....	11
CHAPTER 5: Conclusions .....	12
GLOSSARY.....	13
Appendix A: Compressor Test Report .....	15
Appendix B: Las Gallinas Diesel Engine Calculations .....	17
Appendix C: Las Gallinas CNG Engine Calculations .....	24

## LIST OF FIGURES

	Page
Figure 1: Project Location.....	3
Figure 2: Funding Acknowledgement.....	4
Figure 3: Aerial View of the new CNG Facility.....	5
Figure 4: CNG Infrastructure Looking South.....	6
Figure 5: CNG Infrastructure Looking North .....	6
Figure 6: Micro Motion Flow Meter .....	7

Figure 7: CNG Truck Fueling at the Facility .....	8
---	---

## LIST OF TABLES

	Page
Table 1: Actual Expenses vs Budget .....	4
Table 2: Monthly Data Collection.....	9
Table 3: Greenhouse Gas Reductions .....	10
Table 4: Emission Factors .....	10



## **EXECUTIVE SUMMARY**

This final report prepared for the California Energy Commission meets all reporting requirements of the Agreement ARV-15-038 with the Las Gallinas Valley Sanitary District. This project installed and operated one fast-fill compressed natural gas station to provide back-up to the Waste Water Treatment Plant time-fill Renewable Natural Gas station. This project will also provide compressed natural gas to compressed natural gas trucks through the PG&E supply lines.




# CHAPTER 1: Project Introduction

---

## Background

The Las Gallinas Valley Sanitary District (the District) was awarded a CEC grant (ARV-15-038) in 2015 to build and operate a natural gas fueling infrastructure at the District's wastewater treatment plant located north of San Rafael, in a semi-rural area next to San Pablo Bay. The closest compressed natural gas (CNG) station is at the Pacific Gas and Electric San Rafael Service Center more than ten miles to the south. Figure 1 shows location of the project and the closest CNG stations which are within 20 miles from the District.

**Figure 1: Project Location**



Source: CNG Now. Last accessed April 2, 2018

## Project Description

The District was the applicant but collaborated with other team members to complete this project. The team includes the owner and operator of the CNG fueling station, the Design Engineer which was Cornerstone Environmental Group, a Tetra Tech Company (Cornerstone). Cornerstone assisted with design, procurement, and engineering during construction of the CNG fast-fill station. Cornerstone developed specifications for the project, created and managed the bid proposal, and provided technical expertise in CNG and CNG facilities. Western Water of Santa Rosa, California won the bid for the procurement and installation of the CNG infrastructure. The District coordinated with PG&E prior to construction to ensure permitting and design requirements were met.

The cost for construction and installation for this CNG station was \$495,550, which is about \$155,820 less than the original total budget amount for the project. The Energy Commission grant of \$250,000 covered part of the total cost. The match funds contributed by partners and

supporters was more than the minimum of 25 percent of the total allowable cost (approximately \$83,300). Table 1 shows the actual expenses compared to the budget.

**Table 1: Actual Expenses vs Budget**

Task	CTP Grant	Match Share	Actual	Budget
Administration	-	\$35,985.43	\$35,985.43	\$108,662.00
Finalize Design, Plans, and Specifications	-	\$5,592.50	\$5,592.50	\$88,710.00
Equipment Procurement and Delivery	\$250,000.00	\$69,000.00	\$319,000.00	\$319,000.00
Construction	-	\$135,000.00	\$135,000.00	\$135,000.00
Operation	-	\$0.00	\$0.00	\$0.00
Data Collection and Analysis	-	\$0.00	\$0.00	\$0.00
<b>TOTAL</b>	<b>\$250,000.00</b>	<b>\$245,550.93</b>	<b>\$495,550.93</b>	<b>\$651,372.00</b>

Source: Las Gallinas Valley Sanitary District

The natural gas fueling infrastructure project is part of a larger, innovative project that will play an important role in the future of wastewater bioenergy systems in California. The larger project is a new approach for wastewater treatment facilities that will provide a cost-effective and efficient technologically advanced strategy for maximizing on-site bioenergy resources. Figure 2 shows the banner at the site acknowledging Energy Commission funding for this project.

**Figure 2: Funding Acknowledgement**




Photo Credit: Las Gallinas Valley Sanitary District

## CHAPTER 2: Installation and Deployment

---

The project team began construction at the Smith Ranch Road in February 2016. Grading was done on the site in preparation for paving and foundation installation prior to the receipt of CNG fueling equipment. Piping from the PG&E meter to the fueling station was installed along with secondary-electrical power from the existing source at the Smith Ranch Pump Station. After significant delays in receipt of equipment, the CNG equipment was received and installed on-site in March 2017. Figure 3 shows the aerial view of the new CNG facility.

**Figure 3: Aerial View of the new CNG Facility**



Photo Credit: Las Gallinas Valley Sanitary District

### **CNG Fueling Infrastructure**

The 15-foot by 7-foot, skid-mounted CNG facility includes a single tower NGD-25 ST Xebec natural gas dryer; a Coltri GL-24-AST000 four-stage reciprocating compressor capable of providing a delivery pressure of 4,000 pounds per square inch gauge at a flow rate of 24 standard cubic feet per minute. Figures 4 and 5 show different views of the CNG infrastructure. The compressor provides filling of the cascade storage tanks. A Greenline GL-



B065 fast-fill control panel with cascade actuator controls filling from the fast-fill cascade tanks. The cascade tanks provide a 120 Gasoline Gallon Equivalent (GGE) Cascade storage capacity with four 30 GGE capacity high pressure cylinders.

**Figure 4: CNG Infrastructure Looking South**



Photo Credit: Las Gallinas Valley Sanitary District

**Figure 5: CNG Infrastructure Looking North**



Photo Credit: Las Gallinas Valley Sanitary District

A standalone GreenLine standard high hose CNG dispenser was installed at the station, with no metering capabilities since currently only the District has access to and utilizes the equipment. Should this change in the future, a metered fill post will be installed. To quantify

the volume of CNG used during filling, a flow meter was installed in the supply pipeline to the CNG station. The flow meter shown in Figure 6 provides the amount of CNG fuel, provided in GGE. The Emerson Micro Motion CNG flow meter provides the volume based on an instantaneous reading of mass of the gas traveling through the meter. The new station can store 120 GGE of CNG at 4,000 psig working pressure, and this provides 40 GGE of useable CNG at fast-fill rate. The system fuels a half-filled tank flusher truck within approximately 20 minutes.

**Figure 6: Micro Motion Flow Meter**



Photo Credit: Las Gallinas Valley Sanitary District

## **Final Inspection and Testing**

The CNG fast-fill station was connected to the PG&E supply in March 2017, and on June 28, 2017, GreenLine, the equipment distributor, inspected the CNG fueling infrastructure and signed off on start-up of the fast-fill CNG station. The test report for the compressor is included in Appendix A.

## CHAPTER 3: Usage and Data Collection

---

Data collection started in August 2017. Prior to the construction of the fast-fill station with this project, the District wastewater treatment plant had a fleet of three diesel-powered Class 6 trucks that are used for operations. The District has now replaced one of the trucks with a CNG-fueled truck. Figure 7 shows a CNG truck fueling at the facility.

**Figure 7: CNG Truck Fueling at the Facility**



Photo Credit: Las Gallinas Valley Sanitary District

Each of the existing trucks has a 50-gallon fuel tank and are each driven approximately 10,000 miles a year. The trucks are in operation about 1,700 hours a year, during which time they are typically not accumulating mileage, but operating in-place while they perform maintenance work on sewer facilities; therefore, the mileage does not adequately reflect their overall fuel usage. The new CNG trucks will be purchased one at a time by the District, as the District becomes familiar with the CNG station and the use of CNG trucks.

The District has been using the fast-fill station consistently for the last six months, August through March 2018 (the CNG truck was not used in September because of maintenance issues despite the CNG fueling station being available for use). While the station was not operational prior to that time, the CNG truck was available for use and the District was fueling at a CNG station inconveniently located further away. Over a six-month period, there were several inoperative days, which included downtime that resulted in reprogramming of the priority panel to increase efficiency in the discharging of the fueling tanks. However, the District does not track the days that the CNG fueling station was inoperative. In March 2018, the CNG truck underwent maintenance and modifications to the truck accessories. The truck operators have mentioned that they are pleased with the CNG truck's capacity and fuel train



operating capabilities. Table 2 Summarizes data collected from August 2017 to February 2018 from the CNG fueling station project.

**Table 2: Monthly Data Collection**

<b>Month</b>	<b>Total Runtime Per Month for CNG Truck (Hours)</b>	<b>Number of Days Vehicle Driven</b>	<b>Approximate gallons of CNG per diesel gallon equivalent (DGE) for the month</b>
August 2017	184	23	266
September 2017	0	0	0
October 2017	176	22	139
November 2017	160	20	170
December 2017	160	20	160
January 2018	184	23	194
February 2018	160	20	136

Source: Las Gallinas Valley Sanitary District

## **Emissions Reductions Calculations**

During the six months of data collection, it is estimated that the CNG truck operated for roughly 1,030 hours and used approximately 1,200 GGE of CNG. Based on this information, it is estimated that the CNG truck will operate for 2,050 hours per year and use a total of approximately 2,400 GGE of CNG. This equates to 1.2 GGE per hour (gal/hr) or 1.05 DGE per hour, based on the conversion of 114,000 British thermal units (BTUs) per gallon of gasoline and 128,400 BTUs per gallon of diesel.

Since the District did not track mileage or fuel consumption for the previous diesel truck, it was assumed for emissions offset purposes that the diesel truck operated approximately the same amount of time, 2,050 hours per year, as estimated for the CNG truck. However, since the miles per gallon (mpg) or gallons per hour (gal/hr) are unknown for the diesel truck, the estimate of 1.2 gal/hr was used (based on 2,500 gallons of diesel consumed per year). The estimate is based on the previously estimated consumption of 2,500 diesel gallons per year over 2,050 hours.

Emissions factors for the fuel utilized was derived from Subpart C of the Environmental Protection Agency Mandatory Reporting Greenhouse Gas Rule for diesel and CNG. The emissions factors for the diesel and CNG engines were derived from the California Air Resource Board Executive Orders U-R-001-0228 and A-021-0646-2.

The District's fleet goal is to eventually convert the two remaining diesel trucks to CNG, and potentially purchase a CNG vehicle for general District use. One CNG truck was used to evaluate the annual GHG reductions presented in Table 3. The CNG truck with 300 horsepower (hp) replaced a 255 hp diesel truck.

**Table 3: Greenhouse Gas Reductions**

Month	DGEs per hour assumed for emissions from CNG Truck (gal/hr)	Particulate Matter (PM) psig displaced by one CNG truck (PM <sub>2.5</sub> & PM <sub>10</sub> ) (lbs/month)	Oxides of Nitrogen (NOx) displaced by one CNG vehicle (lbs/month)	Carbon Dioxide (CO <sub>2</sub> ) displaced by CNG vehicles <sup>1</sup>
August 2017	1.04	14	246	1,596
September 2017	-	-	-	-
October 2017	1.04	14	235	834
November 2017	1.04	12	214	1,020
December 2017	1.04	12	214	960
January 2018	1.04	14	246	1,164
February 2018	1.04	12	214	816

Source: Las Gallinas Valley Sanitary District

Because of the difference in engine sizes, the emissions factors for carbon dioxide (CO<sub>2</sub>), particulate matter (PM) less than or equal to 10 micrometers in diameter (PM<sub>10</sub>), non-methane hydrocarbons (NMHC), and nitrogen dioxide (NO<sub>x</sub>) are presented in Table 4 as lb/hr to normalize the difference in hp output from each engine. The emissions factors provided by the Environmental Protection Agency and CARB executive orders are provided in grams per breaking horse power-hours, and then were normalized to lbs/hr to eliminate the difference in horsepower between the two trucks.

**Table 4: Emission Factors**

Engine Type	CO <sub>2</sub> (kg/MMBTU)	CH <sub>4</sub> (kg/MMBTU)	N <sub>2</sub> O (kg/MMBTU)	CO (lb/hr)	PM <sub>10</sub> (lb/hr)	NMHC (lb/hr)	NO <sub>x</sub> (lb/hr)
Caterpillar C7 Diesel Engine	73.96	3.00E-03	6.00E-04	1.47	0.084	2.77	1.35
Cummins ISL G 300 HP (CNG Engine)	53.02	1.00E-03	1.00E-04	10.25	0.007	0.093	0.013

Source: Las Gallinas Valley Sanitary District

Based on these emissions factors, diesel has a carbon intensity of 21 lbs CO<sub>2</sub>/DGE, or approximately 44,700 lbs of CO<sub>2</sub> per year total. Following conversion from diesel to CNG, CNG has a CO<sub>2</sub> emission factor of 15 lbs CO<sub>2</sub>/DGE, or approximately 31,960 lbs of CO<sub>2</sub> per year. The conversion of one truck from diesel to CNG results in an approximately 30 percent reduction in CO<sub>2</sub> emissions.

This project represents an estimated annual displacement of approximately 2,500 DGE of diesel fuel, approximately 160 pounds of particulate matter, approximately 2,740 pounds of NO<sub>x</sub>, and 12,780 pounds of CO<sub>2</sub>.

---

<sup>1</sup> The CO<sub>2</sub> measured at 21 lbs/DGE for diesel and 15 lbs/DGE for CNG, and the CO<sub>2</sub> emission factors provided in kg/MMBTU were converted based on 128,400 BTU/DGE.

## CHAPTER 4: Observations and Challenges

---

The project is a success and the visibility of a public agency utilizing CNG in the Las Gallinas community provides a positive example of government in action towards a cleaner California. However, the District CNG station is not accessible to the public for several reasons. The small space at the Smith Ranch Road Pump Station makes public accessibility limited and increasing the flow of traffic on the adjacent side street would not be favorable to nearby residents. In addition, while the Smith Ranch Road Pump Station is located within a fence, security of the existing pump station and CNG station is a major consideration.

The PG&E piping connection created a delay in project start-up because the District requested that the Contractor demobilize while the PG&E service upgrade request went through and the waste water treatment plant work was completed. Piping design was refined to accommodate the PG&E space requirements for the new meter.

Civil improvement work such as site grading, retaining wall installation, and concrete pads for equipment foundations also contributed to the delays in completing the project. The District required installation of a retaining wall instead of grading existing ground.

There were significant delays in the fueling station equipment purchase and delivery which ultimately delayed the construction phase by about seven months. Upon delivery and installation, equipment was operational for a day (training) but the site soon realized there was a leak and that the tanks were not providing enough pressure at the dispenser to fill the vehicle. It was also difficult to get the equipment manufacturer, Greenline, on-site to repair and complete the Installation.

## CHAPTER 5: Conclusions

---

This project achieved the District's goals to install a new CNG fueling station to fuel its new CNG truck.

The Energy Commission grant provided the much-needed incentive to support District's efforts to phase out diesel operated trucks and provide a steady supply of CNG as back-up to the Renewable Natural Gas system.

This project is evidence that despite the small scale of the facility, an economical and efficient CNG vehicle program can be achieved for a wastewater treatment facility. The District has several green projects supported by the community, including water reclamation ponds and solar energy production, all within the facility's property. Replacing diesel operated trucks with the cleaner burning CNG not only benefits the District financially in the long run, but allows the District to decrease its air pollution emissions.

The District has every intention of continued operation and utilization of the CNG station for vehicle fueling beyond the terms of the Energy Commission's funding agreement. The District is planning to replace the remainder of its diesel-fueled trucks with CNG-fueled vehicles, which is a significant financial investment.

# GLOSSARY

**ALTERNATIVE AND RENEWABLE FUELS AND VEHICLE TECHNOLOGY PROGRAM (ARFVTP)** – Also known as the Clean Transportation Program, was created by Assembly Bill 118 (Nunez, Chapter 750, Statutes of 2007), the program with an annual budget of about \$100 million supports projects that develop and improve alternative and renewable low-carbon fuels, improve alternative and renewable fuels for existing and developing engine technologies, expand transit and transportation infrastructures, and establishing workforce training programs, conduct public education and promotion, and create technology centers, among other tasks.

**CALIFORNIA AIR RESOURCES BOARD (CARB or ARB)** - The "clean air agency" in the government of California, whose main goals include attaining and maintaining healthy air quality; protecting the public from exposure to toxic air contaminants; and providing innovative approaches for complying with air pollution rules and regulations.

**COMPRESSED NATURAL GAS (CNG)** - Natural gas that has been compressed under high pressure, typically between 2,000 and 3,600 pounds per square inch, held in a container. The gas expands when released for use as a fuel.

**CARBON DIOXIDE (CO<sub>2</sub>)** - A colorless, odorless, non-poisonous gas that is a normal part of the air. Carbon dioxide is exhaled by humans and animals and is absorbed by green growing things and by the sea. CO<sub>2</sub> is the greenhouse gas whose concentration is being most affected directly by human activities. CO<sub>2</sub> also serves as the reference to compare all other greenhouse gases (see carbon dioxide equivalent).

**DIESEL GALLON-EQUIVALENT (DGE)** - is the amount of alternative fuel it takes to equal the energy content of one liquid gallon of diesel gasoline.

**GASOLINE GALLON EQUIVALENT (GGE)** - is the amount of alternative fuel it takes to equal the energy content of one liquid gallon of gasoline. GGE allows consumers to compare the energy content of competing fuels against a commonly known fuel—gasoline. GGE also compares gasoline to fuels sold as a gas (natural gas, propane, and hydrogen) and electricity.<sup>2</sup>

**GREENHOUSE GASES (GHG)** – Any gas that absorbs infra-red radiation in the atmosphere. Greenhouse gases include water vapor, carbon dioxide (CO<sub>2</sub>), methane (CH<sub>4</sub>), nitrous oxide (N<sub>2</sub>O), halogenated fluorocarbons (HCFCs), ozone (O<sub>3</sub>), perfluorinated carbons (PFCs), and hydrofluorocarbons (HFCs).

**HORSEPOWER (HP)** - A unit for measuring the rate of doing work. One horsepower equals about three-fourths of a kilowatt (745.7 watts).

**LAS GALLINAS VALLEY SANITARY DISTRICT (The District)** - Las Gallinas Valley Sanitary District (LGVSD) is located in the Las Gallinas Valley between central San Rafael and Novato.

---

<sup>2</sup> [Gasoline Gallon Equivalent Definition](https://www.definitions.net/) (https://www.definitions.net/).

In 1955, our original wastewater treatment plant was constructed to address health problems associated with failing septic tanks in Santa Venetia.<sup>3</sup>

NOx -- Oxides of nitrogen that are a chief component of air pollution that can be produced by the burning of fossil fuels. Also called nitrogen oxides.

PG&E - The acronym for Pacific Gas and Electric Company an electric and natural gas utility serving the central and northern California region.

POUNDS PER SQUARE INCH GUAGE (PSIG) - The pressure relative to atmosphere.<sup>4</sup>

---

<sup>3</sup> [Las Gallinas Valley Sanitary District Homepage](http://www.lgvsd.org/about-us/) (<http://www.lgvsd.org/about-us/>).

<sup>4</sup> [Pounds per Square Inch Definition](https://www.energy.gov/eere/bioenergy/full-text-glossary) (<https://www.energy.gov/eere/bioenergy/full-text-glossary>).

# APPENDIX A: COMPRESSOR TEST REPORT

CUSTOMER NUMBER: # 11700622

## COMPRESSOR TEST REPORT

CUSTOMER: Las Galinas Sanitary DATE: 06-28-17  
 MODEL: GL-24 S/N: GLFSC0001170 PUMP RPM: 1100  
 UNIT RECEIVED CLEAN: ☐ GRADE OF AESTHETIC APPEARANCE: 1 2 3 4 5 6 7 8 9 10  
 DRIVE TYPE: ELECTRIC ☐ GAS ☐ DIESEL ☐ MAKE: COLTRI MODEL: GL-24 CNG  
 S/N: SC0011633 HP 15 RPM 1100 SHEAVE N/A BELT YES  
 HZ 18.3 FULL LOAD AMPS 48 FLA SERVICE FACTOR VOLTS 230 VAC PHASE 3  
 LUBRICATION: ☒ TYPE SNYN OIL CAPACITY 6 Quarts QTS. LEVEL DECAL ☒  
 OIL PRESSURE 12 PSI OIL TEMPERATURE 108 °F ROTATION: ☒ ROTATION DECAL ☒  
 PRESSURE SWITCH SET @ 4,400 PSI OVER PRESSURE SET @ 4,400 PSI  
 LEAK TESTED @ 5,000 PSI CRANK CASE BLOW BY: .078 LPM  
 FLOW RATE: 3,600 PSI (50% RATED PSI) 24 CFM 4,000 PSI (FULL RATED PSI) 20 CFM  
 VOLTAGE: SHOP ☐ GENERATOR ☐ NO LOAD RUN 230VAC START 49 A/Strt  
 AMPS: RUN (1) 46.3 (2) 45.5 (3) 47.1 @ 4000 PSI (FULL RATED PSI)  
 RUN (1) 40.8 (2) 40.2 (3) 41 @ 2000 PSI (50% RATED PSI)  
 START (1) 47 (2) 47.8 (3) 49 (PEAK-INRUSH)

(50% RATED PSI) STAGE PRESSURE (FULL RATED PSI)		AMBIENT TEMP.	(FULL RATED PSI) TEMPERATURE °F (FULL RATED PSI)	
@	PSI	°F	SUCTION	DISCHARGE
	52	1ST STAGE	210 °F	229 °F
	280	2ND STAGE	165 °F	194 °F
	976	3RD STAGE	182 °F	209 °F
	3200	4TH STAGE	145 °F	176 °F
		5TH STAGE		
CABINET TEMP.		FINAL		

AUTO DRAINS: ☒ 1 2 3  
 TRAP DISCHARGE: CLEAR ☒ SLIGHTLY OILY ☐ VERY OILY ☐ MAYONNAISE ☐  
 TIMED FILL TEST: 4 HOURS AFTER WARM-UP FINAL HOUR METER: 371  
 TIME: 1 : 25 MIN:SEC (0 3,000 PSI FILL TEST) TEST BOTTLE SIZE: 126 SCF  
 CALCULATED FLOW RATE: 22 SCFM ÷ 60 SEC = 10.4 GPH  
 AIR TEST: TEST KIT TYPE N/A S/N N/A  
 4 GAS ANALYZER: O<sub>2</sub> N/A CO N/A CO<sub>2</sub> N/A MOISTURE N/A  
 DECALS APPLIED: S/N PLATE ☒ SAFETY/WARNING ☒ GLF CUS ☐ IER ☐

CRITICAL INFORMATION FILLED OUT BY TECHNIAN

Rev 3.4, 6/28/2017

COMMENTS ON MACHINE AND/OR REASONS FOR TEST FAILURE:

[illegible]

#### AREA FOR DIAGRAMS

MACHINE WILL NEED TO BE SET BACK INTO FAST FILL MODE BY PRESSING THE START BUTTON ON THE HMI SCREEN. THIS PROCESS WILL ONLY NEED TO OCCUR WHEN THE MACHINE IS IN A FAULT AND THE OPERATOR CLEARS THE FAULT. THE START BUTTON FOR THE FAST FILL IS LOCATED ON THE BOTTOM LEFT CORNER OF THE MAIN PAGE.

SECOND ISSUE WAS THE GAS TEMP ERROR - THIS IS WAS ADRESSED BY RE-CALIBRATING THE SETPOINTS TO ACCOMODATE A WIDER TEMPERATURE VARIANCE (220- NOW SET TO 260).

MACHINE HAS A TANK OVERPRESSURE SAFEGUARD IN THE PROGRAM THAT MONITORS THE STORAGE PRESSURE. DUE TO TEMPERATURES WE HAVE ADJUSTED THIS SETPOINT TO 4800PSIG. THE TANKS HAVE MANUAL OVERPRESSURE RELIEFS SET @ 5000PSIG.

GREENLINE MADE ADJUSTMENTS TO THE PRIORITY PANEL ADDING A CHECK VALVE FOR THE DOME LOAD REGULATOR. THIS FIX ACCOMODATED THE NON FULL FILL ISSUE COMPLAINT.

GREENLINE ADDED THE ROOF CANOPY FOR SHADE - LEAK CHECKED THE SYSTEM AND PERFORMED NUMEROUS TRUCK FILLS TO SHAKE THE SYSTEM DOWN.

MACHINE TESTED BY JUSTIN BEERER PASS ☒ FAIL ☐

**CRITICAL INFORMATION IS IN RED MUST BE FILLED OUT BY TECHNICIAN**

GLF Test Form

Rev 3.4, 6/28/2017



# APPENDIX B: LAS GALLINAS DIESEL ENGINE CALCULATIONS

Emissions Summary

Diesel Engine

Las Gallinas

Emission Unit	Description	Maximum Engine Horsepower (hp)	Calculated Emissions									
			Criteria Pollutants						HAP		GHG Emissions	
			CO (lb/hr)	Nox (lb/hr)	PM <sub>10</sub> (lb/hr)	PM <sub>2.5</sub> (lb/hr)	VOC (lb/hr)	SO <sub>2</sub> (lb/hr)	Total (lb/hr)	Maximum Single (lb/hr)	CO <sub>2</sub> (lb/hr)	CO <sub>2e</sub> (lb/hr)
			(tpy)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)
1	Engine	255.0	1.467	1.349	0.084	0.084	2.767	0.003	5.77E-04	1.86E-04	25.638	25.729
			1.502	1.790	0.086	0.086	2.832	0.003	5.90E-04	1.90E-04	26.241	26.333

Note: Fuel type utilized for this engine is diesel number 2.

<u>Equipment Information</u>	<u>Value</u>
Type.....	IC Engine
Manufacturer .....	Caterpillar
Model .....	C7
Power Output Rating (1).....	224 ekW
Mechanical Output Rating (2).....	255 hp
Engine Displacement.....	439.3 in. <sup>3</sup>
RPM (1).....	2,200 rpm
Volumetric Efficiency (3).....	0.9
Fuel Utilized.....	Diesel
 <u>Fuel Information</u>	 <u>Value</u>
Diesel Heating Value [LHV] (4).....	128,748 Btu/gal
Consumption [per hour] (5).....	1.2 gal/hr
Heat Input.....	.16 MMBtu/hr
 <u>Operating Schedule</u>	 <u>Value</u>
Hours Per Year (6).....	2,047 hr/yr
 <u>Exhaust Information</u>	
Temperature (1).....	900 deg F
Exhaust flow (1).....	2,113 cfm

<sup>1</sup> Manufacturer's specifications. Temperature and exhaust flow typical for this type of engine.

<sup>2</sup> Derived from rated power output derived from California Air Resource Board (CARB) Executive Order (EO) U-R-001-0228 Engine Model Summary Template BHP @ RPM.

<sup>3</sup> Typical for naturally aspirated 2 and 4 cycle diesel engines.

<sup>4</sup> Derived from rated power output based on lower heating value for Number 2 diesel fuel of 18,390 Btu/lb and diesel density of 7.001 lb/gal.

<sup>5</sup> Derived from California Air Resource Board (CARB) EO U-R-001-0228 Engine Model Summary Template Fuel Rate at peak horsepower in lbs/hr converted to gal/hr.  
(Diesel gal/hr = 71 / 7.001)

<sup>6</sup> Operations 8 hours a day, Monday through Friday, 7:00 AM to 3:00 PM.

<u>Criteria Pollutants</u>	<u>Value - Emissions</u>
CO (1).....	1.47 lb/hr
NOx (1).....	1.35 lb/hr
PM10 (1).....	0.08 lb/hr
HC (1).....	2.77 lb/hr
SO2 (2).....	1.70E-02 lb/MMBtu

<u>Criteria Pollutants</u>	<u>Value</u>
CO.....	1.4673 lb/hr 1.5018 tons/yr
NOx .....	1.3492 lb/hr 1.3809 tons/yr
PM10.....	0.0838 lb/hr 0.0858 tons/yr
PM2.5.....	0.0838 lb/hr 0.0858 tons/yr
VOC.....	2.7669 lb/hr 2.8319 tons/yr
SO2.....	0.003 lb/hr 0.0027 tons/yr

<sup>1</sup> CO, NOx, and HC (VOC) Per California Air Resources Board (CARB), Executive Order (EO) U-R-001-0228.

NOx value listed as N/A in EO.

<sup>2</sup> SO2 based on Santa Barbara County Air Pollution Control District , Gaseous Fuel SOx Emission Factor, <<http://www.sbcapod.org/eng/tech/sulfur01.htm>>, 15 November 2013.

GHG Emissions for LPG Engine Combustion

Volume of fuel combusted per year Based on facility data	2,500 gallons/yr
Default high heat value of the fuel	1.287E-01 mmBtu/gallon
<b>CO<sub>2</sub> Emissions</b>	
Fuel-specific default CO <sub>2</sub> emission factor (EF) From Table C-1 of subpart C of Mandatory Reporting of GHG Rule	73.96 Kg CO <sub>2</sub> /mmBtu
CO <sub>2</sub> Emissions	24 metric Tons
	26 short tons
Global warming potential for CO <sub>2</sub> (GWP)	1.0
Convert emissions to CO <sub>2</sub> e	23.806 metric tons CO <sub>2</sub> e
	26.241 short tons
<b>CH<sub>4</sub> Emissions</b>	
Fuel-specific default CH <sub>4</sub> emission factor (EF) From Table C-2 of subpart C of Mandatory Reporting of GHG Rule	3.00E-03 Kg CH <sub>4</sub> /mmBtu
CH <sub>4</sub> Emissions	0.0010 metric Tons
	0.0011 short tons
Global warming potential for CH <sub>4</sub> (GWP)	25
Convert emissions to CO <sub>2</sub> e	0.024 metric tons CO <sub>2</sub> e
	0.027 short tons
<b>N<sub>2</sub>O Emissions</b>	
Fuel-specific default N <sub>2</sub> O emission factor (EF) From Table C-2 of subpart C of Mandatory Reporting of GHG Rule	6.00E-04 Kg N <sub>2</sub> O/mmBtu
N <sub>2</sub> O Emissions	0.0002 metric Tons
	0.0002 short tons
Global warming potential for N <sub>2</sub> O (GWP)	310
Convert emissions to CO <sub>2</sub> e	0.060 metric tons CO <sub>2</sub> e
	0.066 short tons
GHG Emissions	23.890 metric Tons of CO <sub>2</sub> e
	26.333 short tons of CO <sub>2</sub> e

Heat Input = .16 MMBtu/hr  
 Mechanical Output = 255 hp

LFG Compound	HAP	VOC	CAS	Emission Factor <sup>1</sup>	Emissions	
				Fuel Input (lb/MMBtu)	(lb/hr)	(tpy)
Benzene	x	x	71-43-2	9.33E-04	1.47E-04	1.50E-04
Toluene (methylbenzene)	x	x	108-88-3	4.09E-04	6.43E-05	6.58E-05
Xylenes (m, o, p)	x	x	1330-20-7	2.85E-04	4.48E-05	4.59E-05
Propylene	--	--	7647-01-0	2.58E-03	4.06E-04	4.15E-04
Formaldehyde	x	x	50-00-0	1.18E-03	1.86E-04	1.90E-04
Acetaldehyde	x	x	75-07-0	7.67E-04	1.21E-04	1.23E-04
Acrolein	x	x	107-02-8	9.25E-05	1.45E-05	1.49E-05
Naphthalene	--	--	2-02-004-01	8.48E-05	1.33E-05	1.36E-05
Total PAH	--	x	--	1.68E-04	2.64E-05	2.70E-05
Total HAP	--	--	--	3.67E-03	5.77E-04	5.90E-04
Maximum Single HAP	--	--	--	1.18E-03	1.86E-04	1.90E-04

<sup>1</sup> AP42 5th Ed., "Compilation of Air Pollutant Emissions Factors, Vol. 1: Gasoline and Diesel Industrial Engines, " Tables 3.4-2, Oct. 1996

Pollutant	Certification Standards <sup>1</sup>			
			Emission Rate	Emission Rate
	(g/Kw-hr)	bhp	(lb/hr)	(g/bhp-hr)
CO	3.5	255	1.467	2.610
PM10	0.2	255	0.084	0.149
NMHC	6.6	255	2.767	4.922
NO <sub>x</sub> <sup>2</sup>	1.8	255	1.349	2.400

<sup>1</sup> CO, PM10, and NMHC Per California Air Resources Board (CARB), Executive Order (EO) U-R-001-0228

<sup>2</sup>NO<sub>x</sub> value not included in EO U-R-001-0228. Value derived from Carl Moyer Program Guidelines Part II of VI, Table 1-3, Nox emissions for Model Year 2004 - 2006.

CO = Carbon Monoxide

Nox = Nitrogen Dioxide

PM10 = Particulate matter less than or equal to 10 micrometers in diameter

NMHC = Non methane hydrocarbons

KW/hr= kilowatts per hour

MW= molecular weight

lb/hr = pounds per hour

deg F to Rankine	459.676
universal gas constant	0.7302 atm-ft <sup>3</sup> /lb-mol-R
million	1.00E+06
# lb per g	2.20E-03
# minutes per hour	60
# lbs per ton	2000
# lbs per kg	2.205
ppm	1.00E-06
MW SO <sub>2</sub> (lb/lb-mol)	64.066
kW to hp	1.341
lb/MMbtu to Btu/hr-hr	7000
engine efficiency	0.9
4 cycle air intake flow constant	3456
deg F to R	460.00
standard temp, R	540.00
liter to cubic inches	61.02
GWP	
CO <sub>2</sub> to CO <sub>2</sub>	1.00
10 <sup>3</sup> gal to gal	0.001
g/bhp-hr to gkW-hr	1.34

## APPENDIX C: LAS GALLINAS CNG ENGINE CALCULATIONS

Emission Unit	Description	Maximum Engine Horsepower (hp)	Calculated Emissions									
			Criteria Pollutants						HAP		GHG Emissions	
			CO (lb/hr) (tpy)	NO <sub>x</sub> (lb/hr) (tpy)	PM <sub>10</sub> (lb/hr) (tpy)	PM <sub>2.5</sub> (lb/hr) (tpy)	VOC (lb/hr) (tpy)	SO <sub>2</sub> (lb/hr) (tpy)	Total (lb/hr) (tpy)	Maximum Single (lb/hr) (tpy)	CO <sub>2</sub> (lb/hr) (tpy)	CO <sub>2e</sub> (lb/hr) (tpy)
1	Engine	300.0	10.251	0.013	0.007	0.007	0.093	0.002	9.03E-03	7.08E-03	13.884	13.898
			10.662	0.014	0.007	0.007	0.096	0.002	9.39E-03	7.37E-03	14.439	14.454



<u>Equipment Information</u>	<u>Value</u>
Type.....	IC Engine
Manufacturer .....	Cummins
Model .....	ISL G 300 HP
Power Output Rating (1).....	224 ekW
Mechanical Output Rating (2).....	300 hp
Engine Displacement.....	543.1 in.^3
RPM (1).....	2,100 rpm
Volumetric Efficiency (3).....	0.9
Fuel Utilized.....	CNG

<u>Fuel Information</u>	<u>Value</u>
Diesel Heating Value [LHV] (3).....	128,748 Btu/gal
Consumption (4,5).....	1.04 gal/hr
Heat Input.....	.13 MMBtu/hr

<u>Operating Schedule</u>	<u>Value</u>
Hours Per Year (5).....	2,080 hr/yr

<u>Exhaust Information</u>	
Temperature (1).....	900 deg F
Exhaust flow (1).....	2,493 cfm

<sup>1</sup> Manufacturer's specifications. Temperature and exhasut flow typical for this type of engine.

<sup>2</sup> Typical for naturally aspirated 2 and 4 cycle diesel engines.

<sup>3</sup> Derived from rated power output based on lower heating value for diesel of 128,748 BTU/gal.

<sup>4</sup> Derived from total usage as reported by site divided by available working hours in August 2017 through February 2018. No fuel was utilized in September 2017, per site.

<sup>5</sup> Operations 8 hours a day, Monday through Friday, 7:00 AM through 3:00 PM.

<u>Criteria Pollutants</u>	<u>Value - Emissions</u>
CO (1).....	10.25 lb/hr
NOx (1).....	0.01 lb/hr
PM10 (1).....	0.01 lb/hr
HC (1).....	0.09 lb/hr
SO2 (2).....	1.70E-02 lb/MMBtu

<u>Criteria Pollutants</u>	<u>Value</u>
CO.....	10.2515 lb/hr 10.6615 tons/yr
NOx .....	0.0132 lb/hr 0.0138 tons/yr
PM10.....	0.0066 lb/hr 0.0069 tons/yr
PM2.5.....	0.0066 lb/hr 0.0069 tons/yr
VOC.....	0.0926 lb/hr 0.0963 tons/yr
SO2.....	0.002 lb/hr 0.0024 tons/yr

<sup>1</sup> CO, NOx, and HC (VOC) Per California Air Resources Board (CARB), Executive Order (EO) A-021-0646-2.

<sup>2</sup> SO2 based on Santa Barbara County Air Pollution Control District , Gaseous Fuel SOx Emission Factor, <<http://www.sbcapcd.org/eng/tech/sulfur01.htm>>, 15 November 2013.

<sup>3</sup> VOC emissions not provided in EO A-021-0646-2.

# GHG Emissions for LPG Engine Combustion

Volume of fuel combusted per year Based on facility data	2,167	gallons/yr
Default high heat value of the fuel	1.140E-01	mmBtu/gallon
<b>CO<sub>2</sub> Emissions</b>		
Fuel-specific default CO <sub>2</sub> emission factor (EF) From Table C-1 of subpart C of Mandatory Reporting of GHG Rule	53.02	Kg CO <sub>2</sub> /mmBtu
CO <sub>2</sub> Emissions	13	metric Tons
	14	short tons
Global warming potential for CO <sub>2</sub> (GWP)	1.0	
Convert emissions to CO <sub>2</sub> e	13.099	metric tons CO <sub>2</sub> e
	14.439	short tons
<b>CH<sub>4</sub> Emissions</b>		
Fuel-specific default CH <sub>4</sub> emission factor (EF) From Table C-2 of subpart C of Mandatory Reporting of GHG Rule	1.00E-03	Kg CH <sub>4</sub> /mmBtu
CH <sub>4</sub> Emissions	0.0002	metric Tons
	0.0003	short tons
Global warming potential for CH <sub>4</sub> (GWP)	25	
Convert emissions to CO <sub>2</sub> e	0.006	metric tons CO <sub>2</sub> e
	0.007	short tons
<b>N<sub>2</sub>O Emissions</b>		
Fuel-specific default N <sub>2</sub> O emission factor (EF) From Table C-2 of subpart C of Mandatory Reporting of GHG Rule	1.00E-04	Kg N <sub>2</sub> O/mmBtu
N <sub>2</sub> O Emissions	0.0000	metric Tons
	0.0000	short tons
Global warming potential for N <sub>2</sub> O (GWP)	310	
Convert emissions to CO <sub>2</sub> e	0.008	metric tons CO <sub>2</sub> e
	0.008	short tons
GHG Emissions	13.113	metric Tons of CO <sub>2</sub> e
	14.454	short tons of CO <sub>2</sub> e

Heat Input = .13 MMBtu/hr  
 Mechanical Output = 300 hp

LFG Compound	HAP	VOC	CAS	Emission Factor <sup>1</sup>	Emissions	
				Fuel Input (lb/MMBtu)	(lb/hr)	(tpy)
Benzene	x	x	71-43-2	4.40E-04	5.90E-05	6.14E-05
Toluene (methylbenzene)	x	x	108-88-3	4.08E-04	5.47E-05	5.69E-05
Xylenes (m, o, p)	x	x	1330-20-7	1.84E-04	2.47E-05	2.57E-05
Formaldehyde	x	x	50-00-0	5.28E-02	7.08E-03	7.37E-03
Acetaldehyde	x	x	75-07-0	8.36E-03	1.12E-03	1.17E-03
Acrolein	x	x	107-02-8	5.14E-03	6.90E-04	7.17E-04
Naphthalene	--	--	2-02-004-01	7.44E-05	9.98E-06	1.04E-05
Total PAH	--	x	--	2.69E-05	3.61E-06	3.75E-06
Total HAP	--	--	--	<b>6.73E-02</b>	9.03E-03	9.39E-03
Maximum Single HAP	--	--	--	<b>5.28E-02</b>	7.08E-03	7.37E-03

<sup>1</sup> AP42 5th Ed., "Compilation of Air Pollutant Emissions Factors, Vol. 1: Natural Gas-fired Reciprocating Engines, " Tables 3.2-2, Oct. 1996.

Pollutant	Certification Standards <sup>1</sup>			
			Emission Rate	Emission Rate
	(g/bhp-hr)	bhp	(lb/hr)	(g/Kw-hr)
CO	15.5	300	10.251	11.558
PM10	0.01	300	0.007	0.007
NMHC	0.14	300	0.093	0.104
NO <sub>x</sub>	0.02	300	0.013	0.015

<sup>1</sup> CO, PM10, NMHC, and NO<sub>x</sub> Per California Air Resources Board (CARB), Executive Order (EO) A-021-0646-2

CO = Carbon Monoxide

No<sub>x</sub> = Nitrogen Dioxide

PM10 = Particulate matter less than or equal to 10 micrometers in diameter

NMHC = Non methane hydrocarbons

KW/hr= kilowatts per hour

MW= molecular weight

lb/hr = pounds per hour

deg F to Rankine	459.676
universal gas constant	0.7302 atm-ft <sup>3</sup> /lb-mol-R
million	1.00E+06
# lb per g	2.20E-03
# minutes per hour	60
# lbs per ton	2000
# lbs per kg	2.205
ppm	1.00E-06
MW SO <sub>2</sub> (lb/lb-mol)	64.066
kW to hp	1.341
lb/MMbtu to Btu/hr-hr	7000
engine efficiency	0.9
4 cycle air intake flow constant	3456
deg F to R	460.00
standard temp, R	540.00
liter to cubic inches	61.02
GWP	
CO <sub>2</sub> to CO <sub>2</sub>	1.00
10 <sup>3</sup> gal to gal	0.001
g/bhp-hr to gkW-hr	1.34