

# 2025 IEPR: Preliminary Data Center Forecast

October 30, 2025



Mathew Cooper

Sector Modeling Unit, Demand Analysis Branch



# Methodology

Methodological framework is similar to 2024 IEPR:

1. Request application data from utilities
2. Apply assumptions to account for:
  - Utilization Factor (67%)\*: Requested capacity vs actual peak
  - Confidence Level: Probability of project completion
  - Ramping: Years to reach full capacity
3. Use existing AMI data to create 8,760 load factor profile

\*Unchanged from CEDU 2024



# Data Request Process

---

- Data request sent to:
  - PG&E, SCE, SVP, Palo Alto, VEA
- Additional conversations held with:
  - SDG&E, Burbank, San Jose
- Next steps:
  - In Nov-Dec, CEC will check if the data center application queue has changed significantly before finalizing the forecast for proposed adoption in January
  - In Q1 2026, CEC will request information to disaggregate data center load impacts to busbar to support the CAISO's transmission planning



# Treatment of VEA data centers

---

- VEA load growth is in Nevada
- Will *not* be included in the statewide annual electricity load
- Will be included in:
  - CAISO hourly load
  - LSE/BA tables



# Group Definition Change


	2024 IEPR	Draft 2025 IEPR
Group 1	Active applications with <u>completed or to-be completed</u> engineering studies	<u>Signed agreement</u> for electric service
Group 2	Active applications <u>prior to initiating</u> engineering studies	<u>Active application</u> for electric service
Group 3	Inquiries	Inquiries

Source: CEC

- 2025 Group 1 projects have more certainty than the 2024 Group 1 projects, since they signed an agreement with the utility
- 2025 Group 2 definition combines what was defined as Group 1 and Group 2 in 2024



# 2025 Capacity Requested




Source: CEC



# PG&E and SCE Capacity Requests: 2024 and 2025


December 2024 compared to summer 2025 data



Source: CEC



# Data Center Sizes



Source: CEC





# Proposed Confidence Levels

## 2024 IEPR

PG&E	Low	Mid	High
Group 1	50%	70%	70%
Group 2	-	-	50%
Group 3	-	-	10%

SCE	Low	Mid	High
T&D planning	100%	100%	100%
Group 1	50%	70%	70%
Group 2	-	50%	50%
Group 3	-	-	10% - 50% per SCE

**Source:** CEC with data inputs from PG&E and SCE

## 2025 IEPR

Assumptions match what was used for PG&E last year, except the red values

All (except SVP)	Low	Mid	High
Group 1	50%	70%	100%
Group 2	-	33%	50%
Group 3	-	-	10%

**Source:** CEC

**Mid:** Baseline & Planning Scenario  
**High:** Local Reliability Scenario



# Ramping Assumptions

	2024 IEPR	Draft 2025 IEPR
Ramping	Year 0-5: 149% Year 6+: 113%	Linear ramp over 7 years


**Source:** CEC with data from SVP

- Ramping applied to:
  - Projects without ramping information
  - Projects with unrealistically large first year capacity
- Group 2 and 3 project schedules shifted to 2028+




# Statewide Data Center Peak Demand Mid Case

## 2024 IEPR Mid Case



## 2025 IEPR Mid Case




Source: CEC




# Statewide Data Center Peak Demand High Case

## 2024 IEPR High Case




## 2025 IEPR High Case






# VEA Data Center Peak Demand

2025 IEPR Mid Case



2025 IEPR High Case



# Thank You!



Mathew Cooper (Mathew.Cooper@energy.ca.gov)  
Demand Analysis Branch  
Energy Assessments Division

# 2025 IEPR: Preliminary Hourly Data Center Forecast

October 30, 2025



Jeremy Smith

Deputy Director, Energy Assessments Division



# Hourly Methodology


	2024	2025
Data Source	AMI data from sample of 50 data centers	AMI data from sample of 50 data centers
Sample Service Territory	PG&E	PG&E
Aggregation Method	Weighted-average load factor profile	Weighted-average load factor profile
Unique Profiles	Daytype	Month and Daytype





# IEPR 2025 vs. 2024 (Weekday)

Weekday Data Center Hourly Load Factor Profiles  
(IEPR 2025 vs. IEPR 2024)




Source: CEC



# IEPR 2025 vs. 2024 (Weekend)

Weekend Data Center Hourly Load Factor Profiles  
(IEPR 2025 vs. IEPR 2024)




Source: CEC



# Historical Weather

FZ1 Weather Profiles (2023)



Source: CEC



# Next Steps

---

- Validate methodology and assumptions
- Develop regression framework to quantify weather sensitivity
- Explore differences between hyperscale and smaller data center load profiles
- Expand dataset to create a more robust sample
- Integrate hourly data center profiles into the statewide demand forecast

# Questions



Jeremy Smith ([Jeremy.Smith@energy.ca.gov](mailto:Jeremy.Smith@energy.ca.gov))

Deputy Director

Energy Assessments Division